

air pollution control district santa barbara county

ASSEMBLY BILL 617: BARCT ANALYSIS -RECIPROCATING INTERNAL COMBUSTION ENGINES

Community Advisory Council Santa Barbara County Air Pollution Control District

Our Mission: To protect the people and the environment of Santa Barbara County from the effects of air pollution.

Aeron Arlin Genet, Director / APCO Timothy Mitro, Air Quality Engineer

February 22, 2023



PRESENTATION TOPICS

- 1) Review Background Information
 - Assembly Bill 617 Best Available Retrofit Control Technology (BARCT)
 - $\circ~$ Engine Control Technology Review
 - District Rule 333 Reciprocating Internal Combustion Engines
- 2) BARCT Analysis for Reciprocating Engines
 - Updated Emission Standards
 - Industry Impacts
 - Implementation of BARCT



air pollution control district santa barbara county


BACKGROUND: ASSEMBLY BILL (AB) 617

- Enacted in 2017 for Community Air Protection.
- BARCT applies to large industrial facilities subject to Cap-and-Trade.
 - >25,000 metric tons/yr of GHGs as of 1/1/2017.
 - Requires maximum emission reduction achievable, taking into account environmental and economic impacts.
- BARCT Rule Development Schedule adopted by Board in 2018.



TECHNOLOGY REVIEW

- Non-Selective Catalytic Reduction (NSCR) "3-way catalyst"
 - Emissions reduced by at least 90% NOx, 80% CO, and 50% ROC.
 - Must operate near stoichiometric conditions. (All O₂ reacted & all fuel burned)
 - Air/Fuel Ratio Controller: Makes operational adjustments based on input from O₂ sensor.
 - Catalyst needs high exhaust temperatures & low sulfur fuel.





DISTRICT RULE 333 – ENGINES

- Rule 333 was initially adopted in 1991 (minor amendments in 1997 and 2008).
- Applies to engines with a max rated horsepower of 50 or greater.

Engine	Rule 333 Emission Limits (ppmv, corrected to 15% O ₂)				
_		NOx	ROC	CO	
Dich hum SI	Non-cyclical	50	250	4 500	
Rich-burn, SI	Cyclical	300	230	4,500	

- To comply with NOx standards:
 - Non-cyclical engines: Equip with a 3-way catalyst.
 - **Cyclical engines:** Properly tune or lean the air-fuel ratio.




Cyclical Oil Well Pump

PCEC – ORCUTT HILL

- 27 prime engines remaining
 - Manufacture Year: 1970s and 1980s
 - Original Max Horsepower: 130 200 hp
 - Derated Max Horsepower: 42 49.9 hp





BARCT ANALYSIS

- 1) Engines need to comply with the BARCT standards regardless of derating.
- 2) Lower BARCT standards are achievable.
 - Based on South Coast AQMD Rule 1110.2 and San Joaquin Valley APCD Rule 4702;
 - 95-98% NOx control for engines;
 - Difficulties maintaining high exhaust temperature on derated, cyclical engines.

Engine Type		Uncontrolled NOx EF (ppmv)	Rule 333 NOx Limits (ppmv)	NOx BARCT (ppmv)
	Non-cyclical		50	11
Rich-burn, SI	Cyclical	500	300	11
	Derated, Cyclical		N/A	25

TECHNOLOGY TRIALS

PCEC al coast #1 ND INSTRUMENTS INT. BOILER TEST ON MAIN SITE 12809163		HENRY LEASING & MANUFACTURING GAS ENGINES 3737 Gilmore Avenue Bakersfield, CA 93308 Phone: 661-395-3027 Fax: 661-395-3053							
"Sion No.: V1.10		EMISSION READINGS							
pe of fuel: Natural Gas ≀ analysia	_	Data			Inspection Data				
normalisation: en p: 30,11.21		Date: 11-30-21 Inspectors Name: 11. ctor A. Roperter.							
1 18:53:57		Limits			Measured Values			Within Limits?	Corrective Action Taken
Ta : 2775 F			Log the Time Readings Are Taken (5 Readings Within 15 Minutes				15 Minutes)	(yes or	(When limits are
634.2 PPM 0.16 %		Time	6:57 PM	6:56Pn	6:59PA	7:02Pn	7:05PM	no)	exceeded)
0.1 PPM 0.1 PPM 11.8 %		// ppmv	0,2	0.3	0.7	0.7	0.3	Yes	
0.2 ppm		9000 ppmv	674.2	587.1	672.9	549.5	594.8	Yes	
: 68.6 %	13	< 4%	0.16	0.16	0.16	0.15	0.14	yes.	
: 0.0 % : 15.0 %			Temp Inlet (°F)	Temp Outlet (^o F)	Temp Increase (^o F)	Comments / Corrective Actions Ta			
NE ON UNIT No. 01 IORE INFORMATION 01245 417691	Rea	adings	8839		+2%				
	-	PORTABLE EXHAUST GAS ANALYZER DATA							
Model: LANGOM II Date Last Calibrated: 6-22-21									

- PCEC initiated control technology trials on a few engines.
 - Installed catalysts and Air-Fuel Ratio Controllers.
 - NOx analyzer tests show that the lower limits are feasible.
- Decision to pursue controls on all engines.

COST-EFFECTIVENESS

	Per Engine Retrofit	Total (27 engines)		
Capital Costs:	\$60,000	\$1.62 million		
Catalyst and AFRC installation	\$30,000			
Powerpole extensions for AFRC	\$30,000			
On-Going Costs:	\$12,000/yr	\$324,000/yr		
Catalyst and O ₂ Sensor Replacement	\$4,000/yr			
Biennial Source Testing	\$4,000/yr			
Quarterly NOx Analyzer Testing	\$2,000/yr			
Added Maintenance & Recordkeeping	\$2,000/yr			
Emission Reductions:	2.6 - 2.7 tpy NOx	73 tpy NOx		
Cost-Effectiveness:	\$6,600 - \$6,800 per ton of NOx (15 year project life, 6% interest)			

BARCT IMPLEMENTATION

- PCEC submitted an Authority to Construct (ATC) application to incorporate BARCT directly into their operating permit.
 - Equipment installed no later than December 31, 2023.
- Amendments to District Rule 333 no longer necessary.
 - The BARCT Analysis will be presented to the District Board & forwarded to CARB.
 - The BARCT Analysis will continue to apply to existing and new equipment units at the AB 617 Industrial Facilities.

BARCT TIMELINE FOR IC ENGINES

- December 2018: BARCT Schedule adopted by District Board
- 2019 2022: Technology Trials at PCEC
- October 2022: ATC application submitted by PCEC
- February 2023: CAC Meeting to receive update on BARCT Analysis
 - Spring 2023: 1) ATC Permit issued

- 2) District Board Hearing to receive BARCT Analysis
- 3) Forward Analysis to CARB
- Dec 31, 2023: Implementation of BARCT Analysis

CONTACT INFORMATION

Timothy Mitro, Air Quality Engineer, Planning Division (805) 979-8329 / <u>MitroT@sbcapcd.org</u>



air pollution control district santa barbara county

12