



## MEMORANDUM

**TO:** Community Advisory Council Members

**FROM:** Rebecca Armstrong

**DATE:** August 29, 2007

**SUBJECT:** New Rule 361 – Small Boilers, Steam Generators, and Process Heaters  
Proposed Amended Rule 202 – Exemption to Rule 201 (Permits Required)

---

Enclosed please find Draft New Rule 361 and Proposed Amended Rule 202 currently scheduled for the October 18, 2007 APCD Board Hearing. Proposed amendments to Rule 202 and new Rule 361 will require permits and emission limit compliance for subject small boilers, steam generators, and process heaters. The primary objective of the rule is to reduce Oxides of Nitrogen from small boilers, steam generators, and process heaters (greater than 2 MM Btu/hr to less than 5 MM Btu/hr). We currently have rules for smaller (Rule 360 – 75,000 to 2 MM Btu/hr units) and larger (Rule 342 – 5 MM Btu/hr and greater units) units of this type. This rule will fulfill the Santa Barbara Air Pollution Control District's (APCD) "all feasible measures" requirements included in our 2007 Clean Air Plan.

APCD staff held two Public Workshops for this rulemaking process on August 28 and 29, 2007. At these workshops, we received public input including comments and questions regarding these two proposed rules. At this CAC meeting, we will give an overview of Draft New Rule 361 and Proposed Amended Rule 202. Additionally, we will discuss the public comments that we have received to date and get your input regarding these rules.