

Compliance Certification for Gasoline Tanks

The following federally enforceable requirements may apply to fuel storage at your facility. We have summarized each applicable requirement. Not all sections of each rule are included. The complete rules can be viewed online at www.sbcapcd.org/rules/dlrules.htm. For each requirement listed, you must check whether you are in compliance and if not, enter a proposed compliance date and include a separate attachment describing the actions you will take to achieve compliance by the proposed date. For assistance, contact your permit engineer or our Business Assistance Line, 961-8868.

Rule 316 – Storage and Transfer of Gasoline

C. Requirements – Gasoline Storage Containers

1. Any person transferring, permitting the transfer, or providing equipment for the transfer of gasoline into any gasoline storage container that has 250 gallons or more capacity shall use a permanently installed submerged fill pipe for such transfer.
5. Any above ground gasoline storage container with 250 gallons or more but less than 40,000 gallons capacity shall be equipped with a pressure-vacuum relief valve with minimum pressure and vacuum settings of 90% of the maximum safe pressure and vacuum ratings of the container.

Method used for determining compliance:

I have knowledge that all gasoline storage containers operated on the stationary source comply with the applicable stipulations of Rule 316.

Compliance Status:

- in compliance with rule 316 and will continue to comply with all requirements.
 not in compliance with rule 316 at this time, but I will be by: __/__/____ (submit plan per instructions)
 no activities subject to this requirement

Rule 326 – Storage of Reactive Organic Compounds and Liquids

For storage tanks with capacity \geq 5000 gallons containing reactive organic compound liquids with a vapor pressure $>$ 0.5 lbs./square inch absolute:

- D. Requirements – Emission Reduction
- E. Requirements for Vapor Loss Control Devices
- F. Requirements of All Closure Devices
- I. Requirements for Inspection and Reporting
- J. Requirements for Record Keeping

This Rule does not apply to storage of gasoline in tanks with capacities \leq 40,000 gallons and which are subject to Rule 316.

Method used for determining compliance:

I have knowledge that any storage of reactive organic solvents (except gasoline) in containers of 5,000 gallons or more comply with the stipulations of Rule 326.

Compliance Status:

- in compliance with rule 326 and will continue to comply with all requirements.
 not in compliance with rule 326 at this time, but I will be by: __/__/____ (submit plan per instructions).
 no activities subject to this requirement.