



**Rule 361 Tune-Up Report  
Form ENF -102**

Santa Barbara County Air Pollution Control District  
 260 N. San Antonio Road, Suite A  
 Santa Barbara, CA 93110-1315  
 TEL: (805) 961-8800 FAX: (805) 961-8801  
 Email: [enqr@sbcapcd.org](mailto:enqr@sbcapcd.org) Web Site: [www.sbcapcd.org](http://www.sbcapcd.org)

*Complete this Tune-Up Report each time a Rule 361 required tune-up is performed. Only Rule 361 Tune-Up Procedure A or Procedure B (or APCD-approved alternative) may be used. All portable NO<sub>x</sub>/CO analyzers must be pre-approved by the APCD. The current list of approved portable analyzers may be found online at <http://www.sbcapcd.org/eng/boiler/analyzers.htm>. Per Rule 361, the portable analyzer must be calibrated prior to each use per ATSM Test Method D-6522-00 (reapproved 2005). The portable analyzer readings must be taken in accordance with ATSM Test Method D-6522-00 (reapproved 2005). Be sure to follow the written notification requirements of Rule 361.F.4 for units that do not meet the required emission standards.*

**General Information:**

Tune-Up Date: \_\_\_\_\_ Facility Name: \_\_\_\_\_  
 Permit No: \_\_\_\_\_ Facility ID: \_\_\_\_\_  
 APCD Device ID: \_\_\_\_\_ Location: \_\_\_\_\_

Unit Subject to Rule 361.D.1 Emission Standards for NO<sub>x</sub>/CO?  Yes  No

**Tune-Up Procedure Used:**

Procedure A  Procedure B  
 APCD-Approved Alternative. Approval Number: \_\_\_\_\_

**Portable Analyzer Information:**

Manufacturer: \_\_\_\_\_  
 Model: \_\_\_\_\_  
 Serial No: \_\_\_\_\_

**Initial As-Found Conditions:**

Unit Firing Rate ->	High Fire	Medium Fire	Low Fire	Units
Stack Gas Temp				°F
Stack Gas O <sub>2</sub>				%
Stack Gas CO				ppmvd at 3% O <sub>2</sub>
Stack Gas NO <sub>x</sub>				ppmvd at 3% O <sub>2</sub>
Flame Condition				
Smoke-Spot No.				

Yes  No Complies with Rule 361.D.1 NO<sub>x</sub>/CO Emission Standards?



**Rule 361 Tune-Up Report  
Form ENF -102**

Santa Barbara County Air Pollution Control District  
 260 N. San Antonio Road, Suite A  
 Santa Barbara, CA 93110-1315  
 TEL: (805) 961-8800 FAX: (805) 961-8801  
 Email: [enqr@sbcapcd.org](mailto:enqr@sbcapcd.org) Web Site: [www.sbcapcd.org](http://www.sbcapcd.org)

**Final As-Tuned Conditions:**

Unit Firing Rate ->	High Fire	Medium Fire	Low Fire	Units
Stack Gas Temp				°F
Stack Gas O <sub>2</sub>				%
Stack Gas CO				ppmvd at 3% O <sub>2</sub>
Stack Gas NO <sub>x</sub>				ppmvd at 3% O <sub>2</sub>
Flame Condition				
Smoke-Spot No.				

Yes  No Complies with Rule 361.D.1 NO<sub>x</sub>/CO Emission Standards? **If No**, per Rule 361.F.4 the owner or operator of any unit found not to be in compliance with Section D.1 requirements as a result of the tune-up procedure shall notify the District in writing within 7 days. The notification shall include a copy of the Rule 361 Tune-Up Report, the actions taken to get the unit into compliance, and the next steps to achieve compliance. Failure to bring the unit into compliance with the requirements of Section D.1 within 15 days of the initial tune-up attempt shall constitute a violation of Rule 361.

**Form Completeness Checklist:**

- Yes  No Was the portable analyzer calibrated prior to use and are the calibration records attached?
- Yes  No Were all portable analyzer readings taken in accordance with ASTM Test Method D-6522-00 (reapproved 2005)?
- Yes  No Are copies of all recorded data and combustion analyzer data attached?

**Testing Company Information:** By signing this report, the tester certifies under penalty of perjury that all information herein is true and correct.

Company Name: \_\_\_\_\_

Testers Name (print): \_\_\_\_\_

Phone Number: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_