

February 21, 2025

Lindsay Cokeley
County of Santa Barbara - Public Works Dpt
130 E. Victoria Street, Suite 100
Santa Barbara, CA 93101

FID: 11480
Permit: P 14500
SSID: 03707

Re: Part 70 Permit Application 14500 Completeness

Dear Lindsay Cokeley:

On February 21, 2025, the Santa Barbara County Air Pollution Control District (District) determined that your application for Part 70 Permit 14500 for the Tajiguas ReSource Center project at Tajiguas Landfill was complete. The District will make a decision to either issue or deny the permit for the application within 180 days from the completeness date or 180 days after lead agency approval of the project, whichever time period is longer.

Please include the Facility Identification (FID) and Permit numbers shown above on all correspondence regarding this permit application. If you have any questions, please contact me at (805) 979-8314 or MountainC@sbcapcd.org.

Sincerely,



Charlotte Mountain
Engineering Division

cc: County of Santa Barbara - Tajiguas Anaerobic Digestion 11480 Project File
John Hancock
Engr Chron File

\\sbcapcd.org\shares\Groups\ENGR\WP\Landfills & WWT\03707 Tajiguas\FID 11480 Tajiguas Anaerobic Digestion\PTOs\PT-70 14500\Pt70 14500 - PTO Completeness - 2-21-2025.docx



17 Corporate Plaza Drive, Suite 200
Newport Beach, CA 92660
O: 805.259.9499

June 30, 2023

David Harris
Division Manager
Santa Barbara County Air Pollution Control District
260 N. San Antonio Road, Suite A
Santa Barbara, CA 93110

FID: 11480
Permit: ATC 14500-05(10)

RE: MSB Investors, LLC PTO Application

David,

Attached please find a Permit to Operate (PTO) application for the ReSource Center at the Tajiguas Landfill. Based on our discussions with Kevin Brown, we request the district to combine all outstanding ATC's and modifications into one, single PTO.

Please let us know if we can provide and additional information about this request.

Sincerely,

MSB Investors, LLC

A handwritten signature in blue ink that reads "John Dewey". The signature is fluid and cursive, with the first and last names clearly legible.

John Dewey
CEO & Managing Member



General Permit Application Form -01

Santa Barbara County Air Pollution Control District
260 N. San Antonio Road, Suite A
Santa Barbara, CA 93110-1315

1. APPLICATION TYPE (check all that apply):

- Authority to Construct (ATC) Transfer of Owner/Operator (use Form -01T)
 Permit to Operate (PTO) Emission Reduction Credits
 ATC Modification Increase in Production Rate or Throughput
 PTO Modification Decrease in Production Rate or Throughput
 Other (Specify)

Previous ATC/PTO Number (if known)

- Yes No Are Title 5 Minor Modification Forms Attached? (this applies to Title 5 sources only and applies to all application types except ATCs and Emission Reduction Credits). Complete Title 5 Form -1302 A1/A2, B, and M. Complete Title 5 Form -1302 C1/C2, D1/D2, E1/E2, F1/F2, G1/G2 as appropriate. <http://www.ourair.org/wp-content/uploads/t5-forms.pdf>

Mail or email the completed application to the APCD's Engineering Division at the address listed above or permits@sbcapcd.org.

2. FILING FEE:

A \$456 application filing fee must be included with each application. The application filing fee is COLA-adjusted every July 1st. Please ensure you are remitting the correct current fee (the current fee schedule is available on the APCD's webpage at: <http://www.ourair.org/district-fees>). This filing fee will not be refunded or applied to any subsequent application. Payment may also be made by credit card by submitting the Credit Card Authorization Form found here <https://www.ourair.org/wp-content/uploads/apcd-01c.pdf> via mail or calling 805-979-8050 to pay via phone.

Do not submit the Credit Card Authorization Form via email.

- 3. IS YOUR PROJECT'S PROPERTY BOUNDARY LOCATED OR PROPOSED TO BE LOCATED WITHIN 1,000 FEET FROM THE OUTER BOUNDARY OF A SCHOOL?** If yes, and the project results in an emissions increase, submit a completed Form -03 (*School Summary Form*) <http://www.ourair.org/wp-content/uploads/apcd-03.pdf> Yes No

If yes, provide the name of school(s)

Address of school(s)

City

Zip Code

- 4. DOES YOUR APPLICATION CONTAIN CONFIDENTIAL INFORMATION?** Yes No

If yes, please submit with a redacted duplicate application which shall be a public document. In order to be protected from disclosure to the public, all information claimed as confidential shall be submitted in accordance with APCD Policy & Procedure 6100-020 (*Handling of Confidential Information*): <http://www.ourair.org/wp-content/uploads/6100-020.pdf>, and meet the criteria of CA Govt Code Sec 6254.7. Failure to follow required procedures for submitting confidential information, or to declare it as confidential at the time of application, shall be deemed a waiver by the applicant of the right to protect such information from public disclosure. *Note: Part 70 permit applications may contain confidential information in accordance with the above procedures, however, the content of the permit documents must be public (no redactions).*

FOR APCD USE ONLY				DATE STAMP
FID	11480	Permit No.	PT-70 14500	Rec'vd 6/30/2023
Project Name	County of Santa Barbara - Tajiguas Landfill			
Filing Fee	\$456	202.E? YES / NO		

CC #6594 John Dewey

5. COMPANY/CONTACT INFORMATION:

Owner Info		<input type="radio"/> Yes <input type="radio"/> No	Use as Billing Contact?
Company Name	Santa Barbara County Public Works Department		
Doing Business As	Resource Recovery & Waste Management		
Contact Name	Marty Wilder	Position/Title	Deputy Director
Mailing Address	12110 East Victoria Street		
City	Santa Barbara	State	CA Zip Code 93101
Telephone	908-882-3600	Cell	Email mwilder@countyofsb.org

Operator Info		<input type="radio"/> Yes <input type="radio"/> No	Use as Billing Contact?
Company Name	MSB Investors, LLC		
Doing Business As			
Contact Name	John Dewey	Position/Title	CEO
Mailing Address	17 Corporate Plaza Dr.		
City	Newport Beach	State	CA Zip Code 92660
Telephone	805-259-9499	Cell	Email john@deweygroup.com

Authorized Agent Info*		<input checked="" type="radio"/> Yes <input type="radio"/> No	Use as Billing Contact?
Company Name	MSB Investors, LLC		
Doing Business As			
Contact Name	John Dewey	Position/Title	CEO
Mailing Address	17 Corporate Plaza Dr.		
City	Newport Beach	State	CA Zip Code 92660
Telephone	805-259-9499	Cell	Email john@deweygroup.com

*Use this section if the application is not submitted by the owner/operator. Complete APCD Form -01A (<http://www.ourair.org/wp-content/uploads/apcd-01a.pdf>). Owner/Operator information above is still required.

SEND PERMITTING CORRESPONDENCE TO (check all that apply):	
<input type="checkbox"/> Owner	<input type="checkbox"/> Operator
<input checked="" type="checkbox"/> Authorized Agent	<input type="checkbox"/> Other (attach mailing information)

6. GENERAL NATURE OF BUSINESS OR AGENCY:

The ReSource Center separates incoming MSW into organics, recyclables and residue. The organics are digested in the Anaerobic Digestion Facility (ADF). Digestate is processed/cured into soil amendments/compost. The recyclables are sent to market. The residue leftover is landfilled.

7. EQUIPMENT LOCATION (Address):

Specify the street address of the proposed or actual equipment location. If the location does not have a designated address, please specify the location by cross streets, or lease name, UTM coordinates, or township, range, and section.

Equipment Address	14470 Calle Real		
City	Goleta	State	CA
		Zip Code	93117
Work Site Phone			

- Incorporated (within city limits)
- Unincorporated (outside city limits)
- Used at Various Locations

Assessors Parcel No(s): 081-150-019

8. PROJECT DESCRIPTION:

(Describe the equipment to be constructed, modified and/or operated or the desired change in the existing permit. Attach a separate page if needed):

As set forth in ATC modification 14500-10, recently deemed completed by district engineering.

9. DO YOU REQUIRE A LAND USE PERMIT OR OTHER LEAD AGENCY PERMIT FOR THE PROJECT DESCRIBED IN THIS APPLICATION?: Yes No

A. If yes, please provide the following information

Agency Name	Permit #	Phone #	Permit Date
SB County Public Works	12EIR-00000-00002	805-568-3000	11/14/2017

* The lead agency is the public agency that has the principal discretionary authority to approve a project. The lead agency is responsible for determining whether the project will have a significant effect on the environment and determines what environmental review and environmental document will be necessary. The lead agency will normally be a city or county planning agency or similar, rather than the Air Pollution Control District.

B. If yes, has the lead agency permit application been deemed complete and is a copy of their completeness letter attached?

- Yes
- No

Please note that the APCD will not deem your application complete until the lead agency application is deemed complete.

C. If the lead agency permit application has not been deemed complete, please explain.

D. A copy of the final lead agency permit or other discretionary approval by the lead agency may be requested by the APCD as part of our completeness review process.

10. PROJECT STATUS:

A. Date of Equipment Installation

B. Have you been issued a Notice of Violation (NOV) for not obtaining a permit for this equipment/modification *and/or* have you installed this equipment without the required APCD permit(s)? Yes No
If yes, the application filing is double per Rule 210.

C. Is this application being submitted due to the loss of a Rule 202 exemption? Yes No

D. Will this project be constructed in multiple phases? If yes, attach a separate description of the nature and extent of each project phase, including the associated timing, equipment and emissions. Yes No

E. Is this application also for a change of owner/operator? If yes, please also include a completed APCD Form -01T. Yes No

11. APPLICANT/PREPARER STATEMENT:

The person who prepares the application also must sign the permit application. The preparer may be an employee of the owner/operator or an authorized agent (contractor/consultant) working on behalf of the owner/operator (an *Authorized Agent Form -01A* is required).

I certify pursuant to H&SC Section 42303.5 that all information contained herein and information submitted with this application is true and correct.

Signature of application preparer Date

Print name of application preparer Employer name

12. APPLICATION CHECKLIST (*check all that apply*)

- Application Filing Fee (Fee = \$456. The application filing fee is COLA adjusted every July 1st. Please ensure you are remitting the current fee.) As a convenience to applicants, the APCD will accept credit card payments. If you wish to use this payment option, please complete a *Credit Card Form-01C* <https://www.ourair.org/wp-content/uploads/apcd-01c.pdf> and submit it via mail or call 805-979-8050 to pay over the phone. **Do not submit the *Credit Card Form-01C* via email.**
- Existing permitted sources may request that the filing fee be deducted from their current reimbursable deposits by checking this box. Please deduct the filing fee from my existing reimbursement account.
- Form -01T (*Transfer of Owner/Operator*) attached if this application also addresses a change in owner and/or operator status from what is listed on the current permit. <http://www.ourair.org/wp-content/uploads/apcd-01t.pdf>
- Form -03 (*School Summary Form*) attached if the project's property boundary is within 1,000 feet of the outer boundary of a school (k-12) and the project results in an emissions increase. <http://www.ourair.org/wp-content/uploads/apcd-03.pdf>
- Information required by the APCD for processing the application as identified in APCD Rule 204 (*Applications*), the APCD's *General APCD Information Requirements List* (<https://www.ourair.org/wp-content/uploads/gen-info.pdf>), and any of the APCD's Process/Equipment Summary Forms (<http://www.ourair.org/permit-applications>) that apply to the project.
- Form -01A (*Authorized Agent Form*) attached if this application was prepared by and/or if correspondence is requested to be sent to an Authorized Agent (e.g., contractor or consultant). This form must accompany each application. <http://www.ourair.org/wp-content/uploads/apcd-01a.pdf>
- Confidential Information submitted according to APCD Policy & Procedure 6100-020. (*Failure to follow Policy and Procedure 6100-020 is a waiver of right to claim information as confidential.*)

13. NOTICE OF CERTIFICATION:

All applicants must complete the following Notice of Certification. This certification must be signed by the Authorized Company Representative representing the owner/operator. Signatures by Authorized Agents will not be accepted.

NOTICE of CERTIFICATION

I, , am employed by or represent
Type or Print Name of Authorized Company Representative

Type or Print Name of Business, Corporation, Company, Individual, or Agency

(hereinafter referred to as the applicant), and certify pursuant to H&SC Section 42303.5 that all information contained herein and information submitted with this application is true and correct and the equipment listed herein complies or can be expected to comply with said rules and regulations when operated in the manner and under the circumstances proposed. If the project fees are required to be funded by the cost reimbursement basis, as the responsible person, I agree that I will pay the Santa Barbara County Air Pollution Control District the actual recorded cost, plus administrative cost, incurred by the APCD in the processing of the application within 30 days of the billing date. If I withdraw my application, I further understand that I shall inform the APCD in writing and I will be charged for all costs incurred through closure of the APCD files on the project.

For applications submitted for Authority to Construct, modifications to existing Authority to Construct, and Authority to Construct/Permit to Operate permits, I hereby certify that all major stationary sources in the state and all stationary sources in the air basin which are owned or operated by the applicant, or by an entity controlling, controlled by, or under common control with the applicant, are in compliance, or are on approved schedule for compliance with all applicable emission limitations and standards under the Clean Air Act (42 USC 7401 *et seq.*) and all applicable emission limitations and standards which are part of the State Implementation Plan approved by the Environmental Protection Agency.

Completed By: Title:

Date: Phone:

Signature of Authorized Company Representative

**PLEASE NOTE THAT FAILURE TO COMPLETELY PROVIDE ALL REQUIRED INFORMATION OR FEES WILL
RESULT IN YOUR APPLICATION BEING RETURNED OR DEEMED INCOMPLETE.**



January 27, 2025

Charlotte Mountain
Santa Barbara County Air Pollution Control District
260 N San Antonio Rd Suite A
Santa Barbara, CA 93110

FID: 11480

Re: Response to Incompleteness Letter for Permit to Operate Application 14500

Dear Charlotte Mountain,

The County of Santa Barbara Public Works Resource Recovery and Waste Management Division is providing the below response to the Incomplete Permit to Operate Application 14500 letter which was received on January 9, 2024. Please see the list below for our responses to the incompleteness items referenced in the letter.

PTO 14500 Incompleteness Item List

1. *ATC Mod 14500-05 Condition C.21.b*

This permit condition requires submission of data for CEMS downtime and CEMS detected excess emissions on a quarterly basis. The District has not received this data since issuance of the ATC. Please submit a downtime report and an excess emissions report.

The quarterly CEMS downtime and CEMS detected excess emissions report has not been retrieved to date. The County is working with CEMTEK to develop a quarterly report as soon as possible and will send them as soon as they become available.

2. *ADF Ammonia CEMS Report*

On 9/12/2023, an Ammonia CEMS report was submitted by John Dewey in response to an incompleteness letter issued on 7/26/2023. This report shows exceedances in Ammonia (ppmv) per Table 4.5 of ATC Mod 14500-05. Please submit an ATC to increase the Ammonia limit or to install Ammonia controls. In addition, this report only includes data for the ADF facility. Please include the Ammonia CEMS report for the MRF facility.

ATC 14500-10 was issued for the Tajiguas Resource Center in May of 2024. Table 4.7 of ATC 14500-10 includes the same ammonia limits as ATC 14500-05 Table 4.5. The MRF CHP engines were source tested in November and did not exceed the ammonia limit specified in the permit. The ADF engines are due to be tested in March of this year.

Additionally, CEMS data for both the MRF and ADF engines are being transmitted to the district through monthly variance reports. The next report will be submitted on February 15, 2025.

3. CEMS Plan

a. Section 4.7.1 Calibration Procedures

Calibration of the analyzer is required on a monthly basis. Please provide calibration records.

The County is working with CEMTEK to provide the missing reports and information.

b. Section 6.2.3 Cylinder Gas Audit

Cylinder Gas Audit (CGA) Reports are required to be conducted on concentration analyzers for three out of four quarters. The following reports have been received by the District:

Q2 2022 CEMS CGA Report

Q3 2022 CEMS CGA Report

Q4 2022 CEMS CGA Report

Q1 2023 CEMS CGA Report

However, each of these reports are missing measurements for Ammonia in [lb/hr] and [ppmv]. Please provide the Ammonia measurements for each of these reports, and also the CGA Reports for Q2 – Q4 of 2023. In addition, these reports only include data for the ADF Engines. Please include the CGA Reports for concentration analyzers on the MRF Engines.

Please see attached email correspondence regarding the Cylinder Gas Audits in addition to the CGA reports we currently have on file. We are working with CEMTEK to ensure that the correct reports are compiled and submitted.

c. Data Acquisition and Reporting

Please submit all required reports per Section 7 of the CEMS Plan, including a quarterly written summary report, quarterly emission totals, data recovery efficiency, and audit reports.

The County is working with CEMTEK to provide the missing reports and information.

If you have any questions please contact me at LCokeley@countyofsb.org or John Hancock at jhancoc@countyofsb.org.

Sincerely,



Lindsay Cokeley
Regulatory Compliance Manager II
Santa Barbara County Public Works
Resource Recovery and Waste Management Division

Attachments: 2025.01 CEMTEK Report Email Correspondence
Q2 2023 Cylinder Gas Audit
Q3 2023 Cylinder Gas Audit
Q3 2024 Cylinder Gas Audit
Q4 2024 Cylinder Gas Audit

Continuous Emissions Monitoring System (CEMS)

Second Quarter Test Report

Cylinder Gas Audit

Test Date(s): June 29 and 30, 2023

CEMTEK Project No.: SN00170A

Prepared for:

Tajiguas Resource Recovery Project

Anaerobic Digesting Facility (ADF), Units A and B

Goleta, CA

Prepared by:

CEMTEK KVB-Enertec



3041 S. Orange Avenue, Santa Ana, CA 92707 • Phone: 714-437-7100 • Fax: 714-437-7177 • Toll Free: 888-400-0200
2849 Sterling Drive, Hatfield, PA 19440 • Phone: 215-996-9200 • Fax: 330-860-8982 • Tech Support Phone: 800-582-1670
Houston, TX Office • Phone: 281-729-8228

Contents

1	Introduction	1
2	Monitor Information	2
3	Summary of Results	2
4	Cylinder Gas Audit Test Procedure	3
5	Worksheets and Supporting Documentation	5
	Table 1: Unit A CGA Test Results Summary	2
	Table 2: Unit B CGA Test Results Summary	3

**Quarter Audit Test Report
Tajiguas Anaerobic Digester Facility**

1 Introduction

This quarterly audit report outlines the procedures and results of the Cylinder Gas Audit (CGA) check performed on the monitors at this facility. All testing was done in accordance with 40 CFR 60, Appendix F Procedure 1.

Tajiguas Landfill is located at 14470 Calle Real in Goleta, California that is approximately 26 miles west of the City of Santa Barbara. The landfill began receiving refuse in 1967 to serve the City of Santa Barbara, City of Goleta, unincorporated areas of Montecito and Summerland, rural areas of southern Santa Barbara County, the Santa Ynez Valley and Cuyama Valley. It is located in a canyon known as Cañada de la Pila. Immediately south of the landfill site are U.S. Highway 101, which provides access to the site, Union Pacific Railroad tracks, and the Pacific Ocean. The southern portion of the site is within the California Coastal Zone. For District regulatory purposes, the facility location is in the Southern Zone of Santa Barbara County.

Municipal solid waste (MSW) is delivered to a tipping area inside the Material Recovery Facility (MRF) building at Tajiguas. The material is subsequently sorted into organics, recyclables, and residue in the materials sorting area. Recyclables collected in the materials sorting area are sold to the market while waste residue is landfilled. The sorted organics are placed in the anaerobic digesters to generate biogas in the Anaerobic Digester Facility (ADF). The biogas is treated and combusted in combined heat and power (CHP) internal combustion (IC) engines for power generation, or an enclosed flare located at the ADF. Following biogas generation, the digestate is processed into soil amendments and compost at the Compost Management Unit (CMU). The MRF, ADF, and CMU are designed and constructed by MSB and owned by Santa Barbara County Public Works Department (SBCPWD). The MRF is operated by MarBorg Industries.

The ADF and CMU are operated by Mustang and Bekon. The waste residue placed in the landfill generates LFG in the subsurface landfill through anaerobic biological decomposition. The LFG is collected onsite using a vapor extraction system and handled using a collection and transportation system. A leachate management system collects the groundwater found in the landfill subsurface. The LFG is scrubbed of moisture, particulates, and hydrogen sulfide. The landfill, LFG collection system, hydrogen sulfide scrubber system, and leachate management system are owned and operated by the SBCPWD and permitted separately under PT-70/Reeval 9788-R4.

Currently, treated LFG is combusted on onsite enclosed flare or IC engine that are respectively owned and operated by NEO Tajiguas LLC (NEOT) and MM Tajiguas Energy LLC (MMTE). The LFG treatment system, two LFG-fired CHP engines, and MRF enclosed flare subject to the ATC 14500-02 permit will replace the existing equipment.

Two of the processes involved at the stationary source are as follows:

Anaerobic Digestion Facility: The organic (food and green) waste from the MRF is placed into digesters. An anaerobic digestion process generates biogas. This biogas is sent to the ADF combustion equipment. After the anaerobic digestion process is complete, the residual organic waste is sent to the CMU.

Anaerobic Digestion Facility Combustion Equipment: Biogas from the ADF digesters is sent to two CHP engines to produce electricity to the grid and for onsite needs. Treated LFG is used as a supplemental fuel. If one of the engines is offline or if one of the ADF digesters is being purged, biogas is routed to the ADF enclosed flare.

**Quarter Audit Test Report
Tajiguas Anaerobic Digester Facility**

2 Monitor Information

The following table provides information on the monitors that were subject to this test program.

ADF Unit A

Analyzer	Manufacturer/Model	Range(s)	Serial Number
Stack NO _x /O ₂	TAPI T200M	NO _x : 0-30/0-100 ppm O ₂ : 0-25%	1301
CO	TAPI T300M	0-150/0-300 ppm	668

ADF Unit B

Analyzer	Manufacturer/Model	Range(s)	Serial Number
Stack NO _x /O ₂	TAPI T200M	NO _x : 0-30/0-100 ppm O ₂ : 0-25%	1302
CO	TAPI T300M	0-150/0-300 ppm	669

3 Summary of Results

The results for the Cylinder Gas Audit (CGA) checks performed on the facility monitors are summarized in the following results table.

Table 1: Unit A CGA Test Results Summary

Analyzer	Results	Criteria	Status	Test Date
NO_x Low range	Low = 0.00% Mid = -0.97%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	6/30/23
NO_x High range	Low = 0.03% Mid = -0.61%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	6/29/23
CO Low range	Low = 1.57% Mid = 0.65%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	6/29/23
CO High range	Low = 2.49% Mid = 2.19	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	6/29/23
O₂	Low = 0.46% Mid = -0.33%	≤15% (40 CFR 60, Appendix F)	Pass	6/29/23

**Quarter Audit Test Report
Tajiguas Anaerobic Digester Facility**

Table 2: Unit B CGA Test Results Summary

Analyzer	Results	Criteria	Status	Test Date
NO_x Low range	Low = -0.42% Mid = -2.46%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	6/30/23
NO_x High range	Low = 6.18% Mid = 1.33%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	6/29/23
CO Low range	Low = -2.46% Mid = -2.16%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	6/29/23
CO High range	Low = 6.47% Mid = 6.03%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	6/29/23
O₂	Low = 0.86% Mid = 0.07%	≤15% (40 CFR 60, Appendix F)	Pass	6/29/23

4 Cylinder Gas Audit Test Procedure

The Cylinder Gas Audit (CGA) is performed for each pollutant concentration monitor at least once during each unit operating quarter based on the requirements of 40 CFR 60, Appendix F. CGAs are conducted in three consecutive quarters. Separate calibration gas cylinders are used for each concentration during the audit.

1. All audit gas cylinders are connected to the proper transport lines. EPA Protocol certified gases are used. Cylinders are checked to ensure that each audit gas has at least 200 psi.
2. The analyzers are challenged with an audit gas of known concentration at two points within the following concentration ranges (40 CFR 60, Appendix F):

Audit Point	Pollutant Monitors % of span	O₂ % by volume
Low level	20-30% of span	4-6% by volume
Mid Level	50-60% of span	8-12% by volume

3. The analyzers are challenged three times at each audit point. Calibration gas injections are done alternately between the two audit values. The average of the three responses for each audit point is used in determining accuracy. The monitor is challenged at each audit point for a sufficient time to assure that any absorption-desorption phenomena at the CEMS sample transport surfaces have stabilized. The injection time also takes into account the response time of the analyzers and sample system.

**Quarter Audit Test Report
Tajiguas Anaerobic Digester Facility**

4. Each monitor is operated in its normal sampling mode, that is, the audit gas passes through all filters, scrubbers, conditioners, and other monitor components used during normal sampling, and through as much of the sampling probe as is practical.
5. The difference between the actual concentration of the audit gas and the concentration indicated by the monitor will determine the accuracy of the CEMS.

The accuracy values for each concentration should not exceed 15% of reference value as the primary pass/fail criteria. As of May 30, 2023, the EPA has implemented an alternate pass/fail for pollutant analyzers using a tiered approach based on analyzer range as follows (reference 40 CFR 60, Appendix F, Procedure 1, section 5.2.3):

<i>Analyzer range</i>	<i>Alternate criteria, ppm difference</i>
>50 ppm	±5 ppm
≤50 ppm but >20 ppm	±3 ppm
≤20 ppm	±2 ppm

Cylinder Gas Audit Accuracy 40 CFR 60, Appendix F, Section 6.3	
$A = \frac{C_m - C_a}{C_a} \times 100$	<p>A = Percent accuracy of the CEM</p> <p>C_m = The average monitor response to the specific audit gas (high or low) in units of concentration</p> <p>C_a = Certified value of audit gas (value according to EPA Protocol certification) in units of concentration</p>

5 Worksheets and Supporting Documentation

The attached pages contain worksheets and supporting documentation for the CGA checks.

**Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA**

Project# SN00170A

Cylinder Gas Audit - NOx Low Range

For quarter ending: **06/30/23**

Manufacturer: TAPI
Model: T200M
Serial Number: 1301
Analyzer Range: 30
Test Date: 06/30/23

Reference Gas Value (C)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	7.99	26.63	OK	DT0036234	04/15/24	OK
Mid	17.2	57.33	OK	CC499039	06/23/25	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	07:48	8.54	07:53	17.25
2	07:56	7.83	08:02	16.92
3	08:05	7.60	08:10	16.93
Average Response (Cm)		7.99		17.03
Difference (Cm-Ca)		0.00		-0.17

Status (for alt. criteria of +/- 3 ppm difference) range >20 but ≤ 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100	0.00	-0.97
Status (for primary criteria of 15%)	PASS	PASS

Cylinder Gas Audit - NOx High Range

Analyzer Range: 100
Test Date: 06/29/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	25.8	25.80	OK	CC324929	04/16/24	OK
Mid	55.5	55.50	OK	DT0036914	03/29/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	16:30	25.95	16:36	55.23
2	16:42	25.75	16:46	55.18
3	16:57	25.72	17:02	55.07
Average Response (Cm)		25.81		55.16
Difference (Cm-Ca)		0.01		-0.34

Status (for alt. criteria of +/- 5 ppm difference) range > than 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100	0.03	-0.61
Status (for primary criteria of 15%)	PASS	PASS

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:

>50 ppm: +/- 5 ppm difference

>20 ppm and ≤ 50 ppm: +/- 3 ppm difference

<= 20 ppm: +/- 2 ppm difference

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA

Project# SN00170A

Cylinder Gas Audit - CO Low Range

For quarter ending: **06/30/23**

Manufacturer: TAPI
 Model: T300M
 Serial Number: 668
 Analyzer Range: 150
 Test Date: 06/29/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	40.3	26.87	OK	CC324929	04/16/24	OK
Mid	80.6	53.73	OK	DT0036914	03/29/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	16:31	40.87	16:35	81.06
2	16:42	40.92	16:47	81.12
3	16:56	41.01	17:01	81.18
Average Response (Cm)		40.93		81.12
Difference (Cm-Ca)		0.63		0.52

Status (for alt. criteria of +/-5 ppm difference) range > than 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100
 Status (for primary criteria of 15%)

Cylinder Gas Audit - CO High Range

Analyzer Range: 300
 Test Date: 06/29/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	80.4	26.80	OK	EB0012199	09/16/30	OK
Mid	169.1	56.37	OK	CC73183	03/19/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	15:38	82.5	15:43	172.7
2	15:46	82.5	15:51	172.8
3	15:55	82.2	15:58	172.9
Average Response (Cm)		82.40		172.80
Difference (Cm-Ca)		2.00		3.70

Status (for alt. criteria of +/-5 ppm difference) range > than 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100
 Status (for primary criteria of 15%)

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:
 >50 ppm: +/- 5 ppm difference
 >20 ppm and ≤ 50 ppm: +/- 3 ppm difference
 ≤ 20 ppm: +/- 2 ppm difference

**Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA**

Project# SN00170A

Cylinder Gas Audit - O2

For quarter ending: **06/30/23**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1301
 Analyzer Range: 25
 Test Date: 06/29/23

Reference Gas Value (Ca)	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	5.02	OK	EB0012199	09/16/30	OK
Mid	10.03	OK	CC73183	03/19/29	OK

Cal gas values must be between 4-6% by volume for low and 8-12% by volume for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	15:38	5.04	15:43	10.00
2	15:46	5.05	15:51	10.00
3	15:54	5.04	15:58	10.00
Average Response (Cm)		5.04		10.00
Difference (Cm-Ca)		0.02		-0.03
Accuracy %, ((Cm-Ca)/Ca) * 100		0.46		-0.30
Status (for primary criteria of 15%)		PASS		PASS

Notes:

Pass/Fail Criteria: +/- 15% of reference value (no alternate)
 (40 CFR 60, Appendix F)

Average Values Report
Generated: 6/30/2023 08:31

Company: ~~Cemtek KVB-Enertec~~ **Mustang Renewable Power Ventures**
Plant: **Tajiguas Landfill**
City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
Source: ADF2

Period Start: 6/30/2023 07:30
Period End: 6/30/2023 08:30
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average A2_O2 %	Average A2_NOxLo ppm	Average A2_NOxHi ppm	Average A2_COLo ppm	Average A2_COHi ppm
06/30/2023 07:30	0.00	11.22	11.80	10.87	11.9
06/30/2023 07:31	0.00	9.98	10.49	6.11	7.0
06/30/2023 07:32	0.18	9.72	10.20	12.62	13.8
06/30/2023 07:33	-0.01	15.92	16.73	9.50	10.6
06/30/2023 07:34	1.72	23.35	26.06	83.28	141.4
06/30/2023 07:35	-0.02	27.52	28.94	11.25	12.4
06/30/2023 07:36	-0.02	27.20	28.62	6.39	7.1
06/30/2023 07:37	-0.01	27.07	28.58	6.47	7.2
06/30/2023 07:38	8.22	22.90	24.28	39.36	69.8
06/30/2023 07:39	22.51	3.80	4.00	N/A	261.6
06/30/2023 07:40	22.53	1.01	1.05	N/A	269.9
06/30/2023 07:41	22.53	0.33	1.01	N/A	268.9
06/30/2023 07:42	7.40	14.56	15.88	59.12	149.0
06/30/2023 07:43	0.00	25.96	27.56	9.47	10.5
06/30/2023 07:44	1.27	26.13	27.73	8.49	50.5
06/30/2023 07:45	6.84	30.22	40.18	N/A	N/A
06/30/2023 07:46	0.05	21.37	22.86	46.54	78.2
06/30/2023 07:47	0.01	8.79	9.94	7.68	8.6
06/30/2023 07:48	0.00	8.30	9.49	6.37	7.3
06/30/2023 07:49	0.23	8.18	9.37	13.42	11.9
06/30/2023 07:50	0.11	13.26	14.56	23.62	24.5
06/30/2023 07:51	-0.01	16.93	18.29	6.76	7.6
06/30/2023 07:52	0.00	16.91	18.29	6.47	7.3
06/30/2023 07:53	-0.01	16.90	18.27	6.24	7.0
06/30/2023 07:54	0.11	12.46	13.72	15.49	16.9
06/30/2023 07:55	0.00	7.86	9.03	6.41	7.2
06/30/2023 07:56	0.00	7.82	8.99	6.11	6.9
06/30/2023 07:57	0.00	7.81	8.97	5.97	6.7
06/30/2023 07:58	0.00	10.01	11.21	6.25	7.0
06/30/2023 07:59	-0.02	16.72	18.11	6.07	7.0
06/30/2023 08:00	-0.01	16.76	18.12	5.96	6.8
06/30/2023 08:01	-0.01	16.77	18.11	5.97	6.9
06/30/2023 08:02	0.00	16.05	17.40	6.09	7.0
06/30/2023 08:03	0.00	7.84	9.00	6.05	6.9
06/30/2023 08:04	0.00	7.77	8.93	6.12	6.9
06/30/2023 08:05	0.00	7.76	8.92	6.11	6.8
06/30/2023 08:06	0.03	7.75	8.89	7.39	8.3
06/30/2023 08:07	0.07	14.42	15.72	14.73	16.1
06/30/2023 08:08	-0.01	16.68	18.03	6.23	7.1
06/30/2023 08:09	-0.01	16.66	18.02	5.96	6.8
06/30/2023 08:10	-0.01	16.65	18.00	5.99	6.7
06/30/2023 08:11	4.99	22.51	24.01	76.00	83.0
06/30/2023 08:12	5.43	0.00	39.56	0.00	0.0
06/30/2023 08:13	5.43	0.00	39.56	0.00	0.0
06/30/2023 08:14	5.43	0.00	39.56	0.00	0.0
06/30/2023 08:15	5.43	0.00	39.56	0.00	0.0
06/30/2023 08:16	7.64	N/A	51.15	N/A	N/A
06/30/2023 08:17	7.63	N/A	57.14	N/A	N/A
06/30/2023 08:18	7.60	N/A	62.39	N/A	N/A
06/30/2023 08:19	7.66	N/A	55.97	N/A	N/A
06/30/2023 08:20	7.64	N/A	53.05	N/A	N/A
06/30/2023 08:21	7.63	N/A	54.68	N/A	N/A
06/30/2023 08:22	7.61	N/A	57.49	N/A	N/A
06/30/2023 08:23	7.59	N/A	63.40	N/A	N/A
06/30/2023 08:24	7.64	N/A	58.18	N/A	N/A
06/30/2023 08:25	7.67	N/A	51.61	N/A	N/A
06/30/2023 08:26	7.63	N/A	52.20	N/A	N/A
06/30/2023 08:27	7.62	N/A	57.21	N/A	N/A
06/30/2023 08:28	7.61	N/A	62.70	N/A	N/A
06/30/2023 08:29	7.68	N/A	53.81	N/A	N/A
06/30/2023 08:30	7.69	N/A	50.10	N/A	N/A
Final Average*	3.85	13.43	27.49	13.78	37.0
Maximum*	22.53	30.22	63.40	83.28	269.9
	06/30/2023 7:41	06/30/2023 7:45	06/30/2023 8:23	06/30/2023 7:34	06/30/2023 7:40
Minimum*	-0.02	0.00	1.01	0.00	0.0
	06/30/2023 7:59	06/30/2023 8:15	06/30/2023 7:41	06/30/2023 8:15	06/30/2023 8:15

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 6/30/2023 08:22

Company: ~~Cemtek KVB-Enertec~~ **Mustang Renewable Power Ventures**
Plant: **Tajiguas Landfill**
City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
Source: ADF1

Period Start: 6/29/2023 15:20
Period End: 6/29/2023 18:00
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average	Average	Average	Average	Average
	A1_O2	A1_NOxLo	A1_NOxHi	A1_COLo	A1_COHi
	%	ppm	ppm	ppm	ppm
06/29/2023 15:20	11.04	26.15	31.88	143.38	193.9
06/29/2023 15:21	18.36	16.64	20.23	105.52	141.8
06/29/2023 15:22	17.69	12.50	15.15	86.89	116.0
06/29/2023 15:23	16.57	11.91	14.43	34.06	43.3
06/29/2023 15:24	18.43	2.90	3.32	14.23	17.8
06/29/2023 15:25	17.33	9.67	11.66	15.64	19.6
06/29/2023 15:26	20.85	0.56	0.42	5.18	6.4
06/29/2023 15:27	20.88	0.31	0.14	1.83	2.3
06/29/2023 15:28	20.89	0.27	0.09	1.33	1.6
06/29/2023 15:29	20.89	0.17	-0.06	1.04	1.4
06/29/2023 15:30	20.89	0.09	-0.14	0.93	1.2
06/29/2023 15:31	20.89	0.04	-0.20	0.94	1.2
06/29/2023 15:32	20.89	0.01	-0.24	0.91	1.2
06/29/2023 15:33	19.70	-0.03	-0.28	1.10	1.4
06/29/2023 15:34	5.64	0.55	0.46	53.58	69.1
06/29/2023 15:35	5.06	-0.13	-0.40	63.36	82.4
06/29/2023 15:36	5.05	-0.16	-0.43	63.42	82.5
06/29/2023 15:37	5.04	-0.17	-0.44	63.48	82.5
06/29/2023 15:38	5.04	-0.18	-0.47	63.48	82.5
06/29/2023 15:39	5.04	-0.20	-0.48	63.45	82.4
06/29/2023 15:40	7.81	-0.21	-0.51	84.86	112.5
06/29/2023 15:41	10.01	-0.23	-0.53	127.49	171.4
06/29/2023 15:42	10.00	-0.25	-0.55	128.53	172.7
06/29/2023 15:43	10.00	-0.26	-0.55	128.50	172.7
06/29/2023 15:44	7.07	-0.27	-0.55	81.42	107.9
06/29/2023 15:45	5.05	-0.26	-0.58	63.62	82.7
06/29/2023 15:46	5.05	-0.27	-0.57	63.44	82.5
06/29/2023 15:47	5.04	-0.28	-0.59	63.51	82.6
06/29/2023 15:48	9.27	-0.28	-0.61	96.09	128.0
06/29/2023 15:49	10.01	-0.29	-0.61	128.25	172.4
06/29/2023 15:50	10.00	-0.32	-0.62	128.49	172.7
06/29/2023 15:51	10.00	-0.31	-0.62	128.55	172.8
06/29/2023 15:52	9.62	-0.32	-0.62	117.06	157.2
06/29/2023 15:53	5.05	-0.33	-0.63	66.04	86.2
06/29/2023 15:54	5.04	-0.33	-0.64	63.54	82.6
06/29/2023 15:55	5.51	-0.32	-0.62	63.40	82.2
06/29/2023 15:56	10.20	-0.34	-0.65	108.14	145.1
06/29/2023 15:57	9.99	-0.34	-0.66	128.47	172.6
06/29/2023 15:58	10.00	-0.35	-0.68	128.59	172.9
06/29/2023 15:59	13.27	-0.35	-0.65	97.32	132.5
06/29/2023 16:00	20.79	-0.34	-0.66	5.35	8.0
06/29/2023 16:01	20.29	-0.32	-0.63	7.59	9.5
06/29/2023 16:02	20.75	-0.32	-0.65	4.66	5.9
06/29/2023 16:03	20.53	-0.35	-0.66	3.36	4.2
06/29/2023 16:04	1.25	18.40	22.38	31.57	40.0
06/29/2023 16:05	0.03	25.17	30.68	32.68	41.5
06/29/2023 16:06	0.03	25.31	30.85	32.67	41.4
06/29/2023 16:07	0.11	25.36	51.55	50.60	65.2
06/29/2023 16:08	8.24	25.63	37.16	18.52	23.4
06/29/2023 16:09	4.76	12.78	17.12	18.88	24.4
06/29/2023 16:10	0.03	-99.99	54.00	99.73	134.1
06/29/2023 16:11	0.01	-99.99	-99.99	103.81	139.5
06/29/2023 16:12	0.01	-99.99	-99.99	131.49	139.6
06/29/2023 16:13	7.30	1.00	1.00	97.88	101.2
06/29/2023 16:14	20.82	0.45	0.31	3.91	4.1
06/29/2023 16:15	6.34	10.66	12.85	28.61	29.1
06/29/2023 16:16	0.04	25.58	31.15	40.72	41.4
06/29/2023 16:17	0.02	25.61	31.19	40.72	41.3
06/29/2023 16:18	4.19	25.63	31.24	37.21	37.9
06/29/2023 16:19	2.63	18.06	44.15	59.42	60.6
06/29/2023 16:20	0.01	-99.99	67.07	80.74	82.6
06/29/2023 16:21	0.01	-99.99	67.21	80.91	82.6
06/29/2023 16:22	0.01	-99.99	67.22	80.91	82.6

Period Start:	Average	Average	Average	Average	Average
	Al_O2	Al_NOxLo	Al_NOxHi	Al_COLo	Al_COHi
	%	ppm	ppm	ppm	ppm
06/29/2023 16:23	5.23	28.25	48.86	79.46	81.0
06/29/2023 16:24	0.02	-99.99	-99.99	135.48	138.1
06/29/2023 16:25	0.02	-99.99	90.34	137.04	139.7
06/29/2023 16:26	0.02	-99.99	90.35	137.18	139.8
06/29/2023 16:27	6.72	-99.99	84.01	135.88	138.5
06/29/2023 16:28	16.86	16.39	22.22	134.47	179.8
06/29/2023 16:29	1.36	25.50	25.50	69.26	87.9
06/29/2023 16:30	0.03	25.96	25.95	42.45	43.3
06/29/2023 16:31	0.03	25.86	25.87	40.87	41.6
06/29/2023 16:32	0.06	25.76	25.75	41.07	41.9
06/29/2023 16:33	0.24	25.73	45.20	75.28	77.4
06/29/2023 16:34	0.01	-99.99	55.15	81.03	82.6
06/29/2023 16:35	0.02	-99.99	55.22	81.06	82.8
06/29/2023 16:36	0.02	-99.99	55.23	80.99	82.7
06/29/2023 16:37	0.00	-99.99	55.20	81.03	82.8
06/29/2023 16:38	0.00	-99.99	55.24	81.08	82.7
06/29/2023 16:39	0.05	-99.99	55.26	80.62	82.3
06/29/2023 16:40	0.02	25.97	28.46	44.40	45.1
06/29/2023 16:41	0.01	25.78	25.78	40.97	41.6
06/29/2023 16:42	0.02	25.75	25.75	40.92	41.6
06/29/2023 16:43	0.07	25.70	37.85	61.63	62.8
06/29/2023 16:44	0.02	-99.99	55.10	80.88	82.5
06/29/2023 16:45	0.01	-99.99	55.19	81.06	82.8
06/29/2023 16:46	0.01	-99.99	55.18	81.14	82.8
06/29/2023 16:47	0.01	-99.99	55.20	81.12	82.8
06/29/2023 16:48	4.20	-99.99	48.84	99.02	173.9
06/29/2023 16:49	0.02	-99.99	55.54	85.55	87.3
06/29/2023 16:50	2.93	-99.99	55.23	96.18	127.7
06/29/2023 16:51	4.68	-99.99	49.65	106.26	153.6
06/29/2023 16:52	0.02	-99.99	55.48	82.73	84.4
06/29/2023 16:53	0.02	-99.99	55.35	81.21	83.0
06/29/2023 16:54	0.08	26.02	50.35	72.64	74.2
06/29/2023 16:55	0.01	25.84	25.84	42.15	42.8
06/29/2023 16:56	0.02	25.72	25.72	41.01	41.6
06/29/2023 16:57	0.02	25.71	25.72	40.97	41.6
06/29/2023 16:58	0.06	25.68	32.94	59.73	60.9
06/29/2023 16:59	0.02	-99.99	54.98	80.79	82.4
06/29/2023 17:00	0.02	-99.99	55.10	81.08	82.8
06/29/2023 17:01	0.01	-99.99	55.05	81.18	82.8
06/29/2023 17:02	0.04	-99.99	55.07	81.24	83.0
06/29/2023 17:03	11.25	-99.99	41.36	148.95	191.9
06/29/2023 17:04	13.57	-99.99	36.88	-99.99	N/A
06/29/2023 17:05	13.00	32.23	41.31	161.35	322.7
06/29/2023 17:06	13.72	32.24	38.87	161.35	322.7
06/29/2023 17:07	13.52	32.24	37.76	161.27	322.6
06/29/2023 17:08	13.29	32.23	39.73	161.29	322.7
06/29/2023 17:09	13.37	32.23	38.36	161.33	322.6
06/29/2023 17:10	13.54	-77.95	37.86	-56.45	-779.5
06/29/2023 17:11	11.06	20.14	24.79	0.00	0.0
06/29/2023 17:12	13.71	32.24	36.65	161.37	322.8
06/29/2023 17:13	13.75	32.24	38.79	161.34	322.7
06/29/2023 17:14	14.02	32.24	37.47	161.35	322.7
06/29/2023 17:15	13.88	32.24	39.19	161.31	322.7
06/29/2023 17:16	13.55	-99.99	39.31	-99.99	N/A
06/29/2023 17:17	10.66	29.18	29.18	105.48	216.8
06/29/2023 17:18	6.54	-99.99	60.93	142.56	199.1
06/29/2023 17:19	13.78	32.24	35.01	161.33	322.7
06/29/2023 17:20	13.49	32.24	39.99	161.28	322.6
06/29/2023 17:21	14.08	32.23	36.57	161.29	322.6
06/29/2023 17:22	14.19	32.22	34.14	161.31	322.6
06/29/2023 17:23	14.06	32.23	35.71	161.33	322.6
06/29/2023 17:24	13.94	32.23	37.11	161.32	322.6
06/29/2023 17:25	13.83	32.23	38.43	161.31	322.6
06/29/2023 17:26	13.96	32.23	37.73	161.32	322.7
06/29/2023 17:27	14.11	32.24	37.69	161.26	322.6
06/29/2023 17:28	13.68	32.23	39.14	161.33	322.7
06/29/2023 17:29	13.46	32.24	42.30	161.32	322.6
06/29/2023 17:30	13.39	32.24	40.04	161.32	322.7
06/29/2023 17:31	14.24	32.23	42.70	161.35	322.7
06/29/2023 17:32	14.42	32.24	35.55	161.32	321.6
06/29/2023 17:33	13.92	32.23	40.21	161.32	322.7
06/29/2023 17:34	14.45	32.23	36.87	161.27	322.6

Period Start:	Average	Average	Average	Average	Average
	Al_O2	Al_NOxLo	Al_NOxHi	Al_COLo	Al_COHi
	%	ppm	ppm	ppm	ppm
06/29/2023 17:35	14.43	32.23	37.89	161.29	322.6
06/29/2023 17:36	16.80	20.38	34.79	107.27	177.2
06/29/2023 17:37	14.01	14.26	35.71	-99.99	261.6
06/29/2023 17:38	14.05	32.23	36.54	161.31	322.7
06/29/2023 17:39	13.95	32.24	35.98	161.30	322.6
06/29/2023 17:40	13.65	32.24	36.83	161.32	322.7
06/29/2023 17:41	13.81	32.23	37.82	161.30	322.5
06/29/2023 17:42	13.85	32.23	40.27	161.27	322.6
06/29/2023 17:43	13.67	32.24	37.62	161.34	322.7
06/29/2023 17:44	14.10	32.23	36.40	161.32	322.5
06/29/2023 17:45	13.64	32.24	40.27	161.26	322.6
06/29/2023 17:46	13.86	32.24	38.88	161.37	322.6
06/29/2023 17:47	14.09	32.23	39.41	161.32	322.6
06/29/2023 17:48	13.92	32.23	38.40	161.30	322.6
06/29/2023 17:49	14.22	32.25	37.51	161.28	322.6
06/29/2023 17:50	14.14	32.24	36.58	161.34	322.7
06/29/2023 17:51	14.05	32.23	39.18	161.35	322.7
06/29/2023 17:52	14.21	32.24	37.47	161.30	322.6
06/29/2023 17:53	14.15	32.23	40.04	161.32	322.6
06/29/2023 17:54	14.24	32.23	40.27	161.37	322.7
06/29/2023 17:55	14.32	32.24	36.91	161.38	322.7
06/29/2023 17:56	14.42	32.24	36.32	161.33	322.6
06/29/2023 17:57	14.11	32.25	35.75	161.28	322.6
06/29/2023 17:58	14.07	32.24	36.10	161.30	322.6
06/29/2023 17:59	13.62	32.24	39.53	161.37	322.7
06/29/2023 18:00	13.63	32.24	41.69	161.34	322.6
Final Average*	8.93	-6.80	27.60	93.67	153.7
Maximum*	20.89	32.25	90.35	161.38	322.8
	06/29/2023 15:32	06/29/2023 17:57	06/29/2023 16:26	06/29/2023 17:55	06/29/2023 17:12
Minimum*	0.00	-99.99	-99.99	-99.99	-779.5
	06/29/2023 16:38	06/29/2023 17:18	06/29/2023 16:24	06/29/2023 17:37	06/29/2023 17:10

* Does not include Invalid Averaging Periods ("N/A")

**Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit B
Goleta, CA**

Project# SN00170A

Cylinder Gas Audit - NOx Low Range

For quarter ending: **06/30/23**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1302
 Analyzer Range: 30
 Test Date: 06/30/23

Reference Gas Value (C)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	7.99	26.63	OK	DT0036234	04/15/24 OK
Mid	17.2	57.33	OK	CC499039	06/23/25 OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	07:48	8.30	07:53	16.90
2	07:57	7.81	08:01	16.77
3	08:05	7.76	08:09	16.66
Average Response (Cm)		7.96		16.78
Difference (Cm-Ca)		-0.03		-0.42

Status (for alt. criteria of +/- 3 ppm difference) PASS PASS range >20 but ≤ 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100 -0.42 -2.46
 Status (for primary criteria of 15%) PASS PASS

Cylinder Gas Audit - NOx High Range

Analyzer Range: 100
 Test Date: 06/29/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	25.8	25.80	OK	CC324929	04/16/24 OK
Mid	55.5	55.50	OK	DT0036914	03/29/29 OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	16:32	27.75	16:36	56.34
2	16:40	27.25	16:45	56.15
3	16:57	27.18	17:01	56.22
Average Response (Cm)		27.39		56.24
Difference (Cm-Ca)		1.59		0.74

Status (for alt. criteria of +/- 5 ppm difference) PASS PASS range > than 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100 6.18 1.33
 Status (for primary criteria of 15%) PASS PASS

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:

>50 ppm: +/- 5 ppm difference

>20 ppm and ≤ 50 ppm: +/- 3 ppm difference

<= 20 ppm: +/- 2 ppm difference

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit B
Goleta, CA

Project# SN00170A

Cylinder Gas Audit - CO Low Range

For quarter ending: **06/30/23**

Manufacturer: TAPI
 Model: T300M
 Serial Number: 669
 Analyzer Range: 150
 Test Date: 06/29/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	40.3	26.87	OK	CC324929	04/16/24	OK
Mid	80.6	53.73	OK	DT0036914	03/29/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	16:32	39.42	16:36	78.88
2	16:42	39.20	16:46	78.86
3	16:59	39.31	17:02	78.83
Average Response (Cm)		39.31		78.86
Difference (Cm-Ca)		-0.99		-1.74

Status (for alt. criteria of +/-5 ppm difference) PASS range > than 50 ppm PASS

Accuracy %, ((Cm-Ca)/Ca) * 100 -2.46 -2.16
 Status (for primary criteria of 15%) PASS PASS

Cylinder Gas Audit - CO High Range

Analyzer Range: 300
 Test Date: 06/29/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	80.4	26.80	OK	EB0012199	09/16/30	OK
Mid	169.1	56.37	OK	CC73183	03/19/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	15:37	85.5	15:42	179.4
2	15:47	85.5	15:51	179.3
3	15:54	85.8	15:58	179.2
Average Response (Cm)		85.60		179.30
Difference (Cm-Ca)		5.20		10.20

Status (for alt. criteria of +/-5 ppm difference) FAIL range > than 50 ppm FAIL

Accuracy %, ((Cm-Ca)/Ca) * 100 6.47 6.03
 Status (for primary criteria of 15%) PASS PASS

Note: passed by primary criteria

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:
 >50 ppm: +/- 5 ppm difference
 >20 ppm and ≤ 50 ppm: +/- 3 ppm difference
 </= 20 ppm: +/- 2 ppm difference

**Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit B
Goleta, CA**

Project# SN00170A

Cylinder Gas Audit - O2

For quarter ending: **06/30/23**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1302
 Analyzer Range: 25
 Test Date: 06/29/23

Reference Gas Value (Ca)	Status	Bottle #	Exp. Date	Status	
Low	5.02	OK	EB0012199	09/16/30	OK
Mid	10.03	OK	CC73183	03/19/29	OK

Cal gas values must be between 4-6% by volume for low and 8-12% by volume for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	15:38	5.06	15:42	10.04
2	15:46	5.06	15:50	10.04
3	15:55	5.07	15:57	10.03
Average Response (Cm)		5.06		10.04
Difference (Cm-Ca)		0.04		0.01
Accuracy %, ((Cm-Ca)/Ca) * 100		0.86		0.07
Status (for primary criteria of 15%)		PASS		PASS

Notes:

Pass/Fail Criteria: +/- 15% of reference value (no alternate)
 (40 CFR 60, Appendix F)

Average Values Report
Generated: 6/30/2023 08:31

Company: ~~Cemtek KVB-Enertec~~ **Mustang Renewable Power Ventures**
Plant: **Tajiguas Landfill**
City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
Source: ADF2

Period Start: 6/30/2023 07:30
Period End: 6/30/2023 08:30
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average A2_O2 %	Average A2_NOxLo ppm	Average A2_NOxHi ppm	Average A2_COLo ppm	Average A2_COHi ppm
06/30/2023 07:30	0.00	11.22	11.80	10.87	11.9
06/30/2023 07:31	0.00	9.98	10.49	6.11	7.0
06/30/2023 07:32	0.18	9.72	10.20	12.62	13.8
06/30/2023 07:33	-0.01	15.92	16.73	9.50	10.6
06/30/2023 07:34	1.72	23.35	26.06	83.28	141.4
06/30/2023 07:35	-0.02	27.52	28.94	11.25	12.4
06/30/2023 07:36	-0.02	27.20	28.62	6.39	7.1
06/30/2023 07:37	-0.01	27.07	28.58	6.47	7.2
06/30/2023 07:38	8.22	22.90	24.28	39.36	69.8
06/30/2023 07:39	22.51	3.80	4.00	N/A	261.6
06/30/2023 07:40	22.53	1.01	1.05	N/A	269.9
06/30/2023 07:41	22.53	0.33	1.01	N/A	268.9
06/30/2023 07:42	7.40	14.56	15.88	59.12	149.0
06/30/2023 07:43	0.00	25.96	27.56	9.47	10.5
06/30/2023 07:44	1.27	26.13	27.73	8.49	50.5
06/30/2023 07:45	6.84	30.22	40.18	N/A	N/A
06/30/2023 07:46	0.05	21.37	22.86	46.54	78.2
06/30/2023 07:47	0.01	8.79	9.94	7.68	8.6
06/30/2023 07:48	0.00	8.30	9.49	6.37	7.3
06/30/2023 07:49	0.23	8.18	9.37	13.42	11.9
06/30/2023 07:50	0.11	13.26	14.56	23.62	24.5
06/30/2023 07:51	-0.01	16.93	18.29	6.76	7.6
06/30/2023 07:52	0.00	16.91	18.29	6.47	7.3
06/30/2023 07:53	-0.01	16.90	18.27	6.24	7.0
06/30/2023 07:54	0.11	12.46	13.72	15.49	16.9
06/30/2023 07:55	0.00	7.86	9.03	6.41	7.2
06/30/2023 07:56	0.00	7.82	8.99	6.11	6.9
06/30/2023 07:57	0.00	7.81	8.97	5.97	6.7
06/30/2023 07:58	0.00	10.01	11.21	6.25	7.0
06/30/2023 07:59	-0.02	16.72	18.11	6.07	7.0
06/30/2023 08:00	-0.01	16.76	18.12	5.96	6.8
06/30/2023 08:01	-0.01	16.77	18.11	5.97	6.9
06/30/2023 08:02	0.00	16.05	17.40	6.09	7.0
06/30/2023 08:03	0.00	7.84	9.00	6.05	6.9
06/30/2023 08:04	0.00	7.77	8.93	6.12	6.9
06/30/2023 08:05	0.00	7.76	8.92	6.11	6.8
06/30/2023 08:06	0.03	7.75	8.89	7.39	8.3
06/30/2023 08:07	0.07	14.42	15.72	14.73	16.1
06/30/2023 08:08	-0.01	16.68	18.03	6.23	7.1
06/30/2023 08:09	-0.01	16.66	18.02	5.96	6.8
06/30/2023 08:10	-0.01	16.65	18.00	5.99	6.7
06/30/2023 08:11	4.99	22.51	24.01	76.00	83.0
06/30/2023 08:12	5.43	0.00	39.56	0.00	0.0
06/30/2023 08:13	5.43	0.00	39.56	0.00	0.0
06/30/2023 08:14	5.43	0.00	39.56	0.00	0.0
06/30/2023 08:15	5.43	0.00	39.56	0.00	0.0
06/30/2023 08:16	7.64	N/A	51.15	N/A	N/A
06/30/2023 08:17	7.63	N/A	57.14	N/A	N/A
06/30/2023 08:18	7.60	N/A	62.39	N/A	N/A
06/30/2023 08:19	7.66	N/A	55.97	N/A	N/A
06/30/2023 08:20	7.64	N/A	53.05	N/A	N/A
06/30/2023 08:21	7.63	N/A	54.68	N/A	N/A
06/30/2023 08:22	7.61	N/A	57.49	N/A	N/A
06/30/2023 08:23	7.59	N/A	63.40	N/A	N/A
06/30/2023 08:24	7.64	N/A	58.18	N/A	N/A
06/30/2023 08:25	7.67	N/A	51.61	N/A	N/A
06/30/2023 08:26	7.63	N/A	52.20	N/A	N/A
06/30/2023 08:27	7.62	N/A	57.21	N/A	N/A
06/30/2023 08:28	7.61	N/A	62.70	N/A	N/A
06/30/2023 08:29	7.68	N/A	53.81	N/A	N/A
06/30/2023 08:30	7.69	N/A	50.10	N/A	N/A
Final Average*	3.85	13.43	27.49	13.78	37.0
Maximum*	22.53	30.22	63.40	83.28	269.9
	06/30/2023 7:41	06/30/2023 7:45	06/30/2023 8:23	06/30/2023 7:34	06/30/2023 7:40
Minimum*	-0.02	0.00	1.01	0.00	0.0
	06/30/2023 7:59	06/30/2023 8:15	06/30/2023 7:41	06/30/2023 8:15	06/30/2023 8:15

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 6/30/2023 08:25

Company: ~~Cemtek KVB-Enertec~~ **Mustang Renewable Power Ventures**
 Plant: **Tajiguas Landfill**
 City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
 Source: ADF2

Period Start: 6/29/2023 15:20
 Period End: 6/29/2023 18:00
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

Period Start:	Average A2_O2 %	Average A2_NOxLo ppm	Average A2_NOxHi ppm	Average A2_COLo ppm	Average A2_COHi ppm
06/29/2023 15:20	7.68	N/A	65.90	N/A	N/A
06/29/2023 15:21	7.73	N/A	55.53	N/A	N/A
06/29/2023 15:22	7.66	N/A	58.27	N/A	N/A
06/29/2023 15:23	7.69	N/A	54.49	N/A	N/A
06/29/2023 15:24	7.68	N/A	53.95	N/A	N/A
06/29/2023 15:25	7.67	N/A	57.08	N/A	N/A
06/29/2023 15:26	7.65	N/A	59.66	N/A	N/A
06/29/2023 15:27	7.73	N/A	56.48	N/A	N/A
06/29/2023 15:28	7.73	N/A	56.14	N/A	N/A
06/29/2023 15:29	7.70	N/A	55.29	N/A	N/A
06/29/2023 15:30	7.70	N/A	54.10	N/A	N/A
06/29/2023 15:31	7.70	N/A	52.06	N/A	N/A
06/29/2023 15:32	7.68	N/A	57.52	N/A	N/A
06/29/2023 15:33	6.76	N/A	57.12	N/A	N/A
06/29/2023 15:34	5.04	14.57	22.05	102.68	138.2
06/29/2023 15:35	5.07	2.80	2.98	78.42	86.4
06/29/2023 15:36	5.06	2.19	2.27	77.65	85.5
06/29/2023 15:37	5.07	2.06	2.15	77.58	85.5
06/29/2023 15:38	5.06	1.87	1.95	77.55	85.5
06/29/2023 15:39	5.51	4.80	5.04	86.61	95.4
06/29/2023 15:40	9.53	12.97	13.57	N/A	219.1
06/29/2023 15:41	10.04	1.79	1.89	N/A	181.2
06/29/2023 15:42	10.04	1.46	1.53	N/A	179.4
06/29/2023 15:43	9.85	1.39	1.48	N/A	185.2
06/29/2023 15:44	5.30	1.70	1.79	97.97	122.5
06/29/2023 15:45	5.07	1.35	1.45	78.32	86.3
06/29/2023 15:46	5.06	1.30	1.40	77.68	85.5
06/29/2023 15:47	5.05	1.26	1.36	77.64	85.5
06/29/2023 15:48	8.03	1.32	1.37	122.68	150.1
06/29/2023 15:49	10.04	1.16	1.20	N/A	179.2
06/29/2023 15:50	10.04	1.12	1.17	N/A	179.3
06/29/2023 15:51	10.03	1.07	1.13	N/A	179.3
06/29/2023 15:52	7.87	1.08	1.15	122.52	171.3
06/29/2023 15:53	5.07	1.19	1.24	83.27	91.7
06/29/2023 15:54	5.06	1.10	1.15	77.85	85.8
06/29/2023 15:55	5.07	1.07	1.13	77.65	85.5
06/29/2023 15:56	9.02	1.54	1.77	140.12	173.6
06/29/2023 15:57	10.03	1.05	1.09	N/A	179.6
06/29/2023 15:58	10.02	0.99	1.04	N/A	179.2
06/29/2023 15:59	9.36	3.67	3.85	N/A	202.6
06/29/2023 16:00	7.72	16.94	40.73	N/A	N/A
06/29/2023 16:01	7.74	N/A	46.77	N/A	N/A
06/29/2023 16:02	7.72	N/A	49.82	N/A	N/A
06/29/2023 16:03	6.08	N/A	44.30	N/A	293.3
06/29/2023 16:04	0.92	28.75	39.83	87.64	131.6
06/29/2023 16:05	0.01	27.21	28.45	42.10	46.1
06/29/2023 16:06	0.01	26.61	27.85	38.93	42.6
06/29/2023 16:07	0.06	26.43	43.84	66.35	73.1
06/29/2023 16:08	1.26	N/A	62.89	123.40	192.4
06/29/2023 16:09	0.00	N/A	88.79	131.61	146.3
06/29/2023 16:10	0.08	N/A	89.01	130.68	145.1
06/29/2023 16:11	0.09	N/A	88.62	136.42	152.3
06/29/2023 16:12	0.10	N/A	88.64	135.21	149.6
06/29/2023 16:13	4.00	N/A	78.15	139.42	160.7
06/29/2023 16:14	7.66	N/A	53.76	N/A	N/A
06/29/2023 16:15	2.50	N/A	52.73	98.71	149.6
06/29/2023 16:16	0.02	27.73	29.01	50.12	53.7
06/29/2023 16:17	0.00	26.71	27.92	39.58	42.6
06/29/2023 16:18	2.33	26.62	27.82	64.15	115.3
06/29/2023 16:19	1.10	24.80	38.88	111.72	195.6
06/29/2023 16:20	0.00	N/A	56.38	82.85	89.6
06/29/2023 16:21	0.00	N/A	56.10	79.08	85.5
06/29/2023 16:22	-0.01	N/A	56.04	78.97	85.3

Period Start:	Average	Average	Average	Average	Average
	A2_O2	A2_NOxLo	A2_NOxHi	A2_COLo	A2_COHi
	%	ppm	ppm	ppm	ppm
06/29/2023 16:23	1.25	N/A	59.39	83.99	187.6
06/29/2023 16:24	0.14	N/A	86.92	145.53	159.1
06/29/2023 16:25	0.06	N/A	89.48	138.95	151.9
06/29/2023 16:26	0.01	N/A	90.29	133.44	145.2
06/29/2023 16:27	3.51	N/A	79.43	131.70	143.2
06/29/2023 16:28	7.69	N/A	51.05	N/A	N/A
06/29/2023 16:29	1.10	29.33	46.25	85.48	152.4
06/29/2023 16:30	0.01	27.22	28.74	44.15	47.5
06/29/2023 16:31	0.00	26.53	27.94	39.46	42.5
06/29/2023 16:32	0.01	26.32	27.75	39.42	42.3
06/29/2023 16:33	0.05	26.10	48.72	73.03	78.8
06/29/2023 16:34	-0.01	N/A	56.20	78.77	85.2
06/29/2023 16:35	0.00	N/A	56.26	78.91	85.3
06/29/2023 16:36	-0.01	N/A	56.34	78.88	85.4
06/29/2023 16:37	-0.01	N/A	56.33	78.79	85.1
06/29/2023 16:38	0.07	26.99	42.87	65.26	70.4
06/29/2023 16:39	0.00	25.98	27.34	39.81	42.8
06/29/2023 16:40	0.00	25.87	27.25	39.22	42.3
06/29/2023 16:41	0.01	25.84	27.21	39.17	42.1
06/29/2023 16:42	0.00	25.81	27.18	39.20	42.2
06/29/2023 16:43	0.31	25.79	29.56	75.63	81.7
06/29/2023 16:44	-0.01	N/A	56.06	80.52	87.2
06/29/2023 16:45	0.00	N/A	56.15	78.82	85.2
06/29/2023 16:46	-0.01	N/A	56.13	78.86	85.3
06/29/2023 16:47	-0.01	N/A	56.13	78.78	85.2
06/29/2023 16:48	1.29	N/A	56.44	90.42	180.0
06/29/2023 16:49	-0.01	N/A	56.82	92.21	99.8
06/29/2023 16:50	-0.01	N/A	56.37	79.49	85.9
06/29/2023 16:51	1.61	N/A	53.20	129.53	204.3
06/29/2023 16:52	0.00	N/A	56.60	84.02	90.7
06/29/2023 16:53	0.00	N/A	56.30	79.23	85.7
06/29/2023 16:54	0.17	N/A	56.31	84.52	91.5
06/29/2023 16:55	0.00	26.01	29.87	46.19	49.8
06/29/2023 16:56	0.00	25.82	27.18	39.37	42.5
06/29/2023 16:57	0.00	25.78	27.18	39.12	42.1
06/29/2023 16:58	0.00	25.75	27.15	39.09	42.1
06/29/2023 16:59	0.01	25.70	27.08	39.31	42.2
06/29/2023 17:00	-0.01	25.67	48.44	66.70	72.1
06/29/2023 17:01	0.00	N/A	56.22	78.79	85.2
06/29/2023 17:02	-0.01	N/A	56.26	78.83	85.2
06/29/2023 17:03	7.04	N/A	52.40	N/A	196.3
06/29/2023 17:04	7.68	N/A	53.05	N/A	N/A
06/29/2023 17:05	7.67	N/A	55.74	N/A	N/A
06/29/2023 17:06	7.68	N/A	54.72	N/A	N/A
06/29/2023 17:07	7.69	N/A	52.82	N/A	N/A
06/29/2023 17:08	7.69	N/A	50.75	N/A	N/A
06/29/2023 17:09	7.67	N/A	54.27	N/A	N/A
06/29/2023 17:10	7.67	N/A	55.07	N/A	N/A
06/29/2023 17:11	7.66	N/A	56.04	N/A	N/A
06/29/2023 17:12	7.67	N/A	55.58	N/A	N/A
06/29/2023 17:13	7.68	N/A	53.73	N/A	N/A
06/29/2023 17:14	7.66	N/A	56.74	N/A	N/A
06/29/2023 17:15	7.67	N/A	58.27	N/A	N/A
06/29/2023 17:16	7.69	N/A	59.19	N/A	N/A
06/29/2023 17:17	7.71	N/A	56.80	N/A	N/A
06/29/2023 17:18	7.72	N/A	55.23	N/A	N/A
06/29/2023 17:19	7.74	N/A	57.00	N/A	N/A
06/29/2023 17:20	7.74	N/A	52.30	N/A	N/A
06/29/2023 17:21	7.72	N/A	53.15	N/A	N/A
06/29/2023 17:22	7.69	N/A	55.71	N/A	N/A
06/29/2023 17:23	7.70	N/A	54.78	N/A	N/A
06/29/2023 17:24	7.69	N/A	55.90	N/A	N/A
06/29/2023 17:25	7.70	N/A	53.06	N/A	N/A
06/29/2023 17:26	7.68	N/A	53.78	N/A	N/A
06/29/2023 17:27	7.65	N/A	61.42	N/A	N/A
06/29/2023 17:28	7.66	N/A	58.92	N/A	N/A
06/29/2023 17:29	7.67	N/A	56.73	N/A	N/A
06/29/2023 17:30	7.67	N/A	57.66	N/A	N/A
06/29/2023 17:31	7.67	N/A	58.26	N/A	N/A
06/29/2023 17:32	7.69	N/A	58.17	N/A	N/A
06/29/2023 17:33	7.68	N/A	58.56	N/A	N/A
06/29/2023 17:34	7.68	N/A	57.21	N/A	N/A

Period Start:	Average	Average	Average	Average	Average
	A2_O2	A2_NOxLo	A2_NOxHi	A2_COLo	A2_COHi
	%	ppm	ppm	ppm	ppm
06/29/2023 17:35	7.66	N/A	60.49	N/A	N/A
06/29/2023 17:36	7.73	N/A	50.61	N/A	N/A
06/29/2023 17:37	7.68	N/A	50.21	N/A	N/A
06/29/2023 17:38	7.65	N/A	50.27	N/A	N/A
06/29/2023 17:39	7.62	N/A	57.72	N/A	N/A
06/29/2023 17:40	7.66	N/A	56.15	N/A	N/A
06/29/2023 17:41	7.67	N/A	52.33	N/A	N/A
06/29/2023 17:42	7.66	N/A	51.56	N/A	N/A
06/29/2023 17:43	7.63	N/A	54.00	N/A	N/A
06/29/2023 17:44	7.62	N/A	56.97	N/A	N/A
06/29/2023 17:45	7.65	N/A	53.78	N/A	N/A
06/29/2023 17:46	7.63	N/A	53.74	N/A	N/A
06/29/2023 17:47	7.64	N/A	52.46	N/A	N/A
06/29/2023 17:48	7.61	N/A	57.69	N/A	N/A
06/29/2023 17:49	7.63	N/A	61.23	N/A	N/A
06/29/2023 17:50	7.66	N/A	56.53	N/A	N/A
06/29/2023 17:51	7.66	N/A	59.63	N/A	N/A
06/29/2023 17:52	7.68	N/A	61.07	N/A	N/A
06/29/2023 17:53	7.74	N/A	54.44	N/A	N/A
06/29/2023 17:54	7.71	N/A	51.52	N/A	N/A
06/29/2023 17:55	7.68	N/A	52.43	N/A	N/A
06/29/2023 17:56	7.69	N/A	51.45	N/A	N/A
06/29/2023 17:57	7.66	N/A	54.84	N/A	N/A
06/29/2023 17:58	7.64	N/A	58.98	N/A	N/A
06/29/2023 17:59	7.65	N/A	58.61	N/A	N/A
06/29/2023 18:00	7.67	N/A	56.68	N/A	N/A
Final Average*	5.02	14.35	45.12	82.27	112.7
Maximum*	10.04	29.33	90.29	145.53	293.3
	06/29/2023 15:50	06/29/2023 16:29	06/29/2023 16:26	06/29/2023 16:24	06/29/2023 16:03
Minimum*	-0.01	0.99	1.04	38.93	42.1
	06/29/2023 17:02	06/29/2023 15:58	06/29/2023 15:58	06/29/2023 16:06	06/29/2023 16:58

* Does not include Invalid Averaging Periods ("N/A")

DocNumber: 407481

SV7
CGA3



Praxair Distribution, Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22021

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PRAXAIR PKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA 93455-1123
Customer Reference: DIANI

Certificate Issuance Date: 04/15/2021
Praxair Order Number: 71635562
Part Number: 18 NOBME-A5
Customer PO Number: 79633960

Fill Date: 03/24/2021
Lot Number: 70088108309
Cylinder Style & Outlet: A5 CGA 600
Cylinder Pressure and Volume: 2000 psig 140.63

Certified Concentration

Expiration Date:	04/15/2024	NIST Traceable
Cylinder Number:	DT0036234	Expanded Uncertainty
7.99 ppm	Nitric oxide	± 0.04 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only:

NOx 8.06 ppm

Certification Information:

Certification Date: 04/15/2021

Term: 36 Months

Expiration Date: 04/15/2024

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component:

Nitric oxide

Requested Concentration: 8 ppm
Certified Concentration: 7.99 ppm
Instrument Used: Thermo Electron 42i-LS S/N 1030645077
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 03/25/2021

Reference Standard: Type / Cylinder #: GMS / DT0036016
Concentration / Uncertainty: 10.28 ppm ± 0.05 ppm
Expiration Date: 08/27/2023
Traceable to: SRM # / Sample # / Cylinder #: PHM / C1837210.02 / APEX1324301
SRM Concentration (enter with units) / SRM Expiration Date: 10.00 ppm / ± 0.05 ppm / 04/17/2022

First Analysis Data:				Date	04/06/2021		
Z:	0	R:	10.28	C:	7.96	Conc:	7.96
R:	10.29	Z:	0	C:	7.98	Conc:	7.98
Z:	0	C:	7.98	R:	10.27	Conc:	7.98
UOM:	ppm		Mean Test Assay:		7.97	ppm	

Second Analysis Data:				Date	04/15/2021		
Z:	0	R:	10.28	C:	8.01	Conc:	8.02
R:	10.25	Z:	0	C:	8.01	Conc:	8.02
Z:	0	C:	8	R:	10.27	Conc:	8.01
UOM:	ppm		Mean Test Assay:		8.02	ppm	

Analyzed By

Henry Koung

Certified By

Leanna Flores



Making our world
more productive

DocNumber: 477019



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22022

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

LGEPKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA93455-1123

Customer Reference: MUSTANG

Certificate Issuance Date: 06/23/2022

Linde Order Number: 9903972087130

Part Number: NI NO17ME-AS

Customer PO Number: 80090728

Fill Date: 06/10/2022

Lot Number: 70086216106

Cylinder Style & Outlet: AS

CGA 660

Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration

Expiration Date:	06/23/2025	NIST Traceable
Cylinder Number:	CC499039	Expanded Uncertainty
17.2 ppm	Nitric oxide	± 0.2 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only: NOx 17.2 ppm

Certification Information:

Certification Date: 06/23/2022

Term: 36 Months

Expiration Date: 06/23/2025

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-400/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component:

Nitric oxide

Requested Concentration: 17 ppm

Certified Concentration: 17.2 ppm

Instrument Used: Thermo Electron 42i-LS S/N 1030645077

Analytical Method: Chemiluminescence

Last Multipoint Calibration: 05/27/2022

Reference Standard:

Type / Cylinder #: GMIS / DT0037183

Concentration / Uncertainty: 19.97 ppm ± 0.20 ppm

Expiration Date: 04/12/2025

Traceable to: SRM # / Sample # / Cylinder #: 2629a / 50-G-17 / FF31691

SRM Concentration / Uncertainty: 18.99 ppm / ± 0.19 ppm

SRM Expiration Date: 10/21/2023

First Analysis Data:				Date			
Z:	0	R:	20	C: 17.16	Conc:	17.1	
R:	20	Z:	0	C: 17.19	Conc:	17.2	
Z:	0	C:	17.18	R:	20	Conc:	17.2
UOM: ppm		Mean Test Assay:		17.2 ppm			

Second Analysis Data:				Date			
Z:	0	R:	20	C: 17.18	Conc:	17.2	
R:	19.9	Z:	0	C: 17.18	Conc:	17.2	
Z:	0	C:	17.2	R:	20	Conc:	17.2
UOM: ppm		Mean Test Assay:		17.2 ppm			

Analyzed By

Henry Koung

Certified By

Erzsette Morales

SU9 CGAS



DocNumber: 407533



Praxair Distribution, Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22021

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PRAXAIR PKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA 93455-1123

Certificate Issuance Date: 04/16/2021

Praxair Order Number: 71835190

Part Number: NI CO40MN20E-AS

Customer PO Number: 79632556

Fill Date: 04/01/2021

Lot Number: 70086109106

Cylinder Style & Outlet: AS

CGA 660

Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration

Expiration Date:	04/16/2024	NIST Traceable
Cylinder Number:	CC324929	Expanded Uncertainty
40.3 ppm	Carbon monoxide	± 0.2 ppm
25.8 ppm	Nitric oxide	± 0.1 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only:

NOx 25.9 ppm

Certification Information:

Certification Date: 04/16/2021

Term: 36 Months

Expiration Date: 04/16/2024

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon monoxide

Requested Concentration: 40 ppm
Certified Concentration: 40.3 ppm
Instrument Used: Horiba VIA-510 S/N 43627990042
Analytical Method: NDIR
Last Multipoint Calibration: 03/26/2021

First Analysis Data:				Date			
Z:	0	R:	98.1	C:	40.2	Conc:	40.2
R:	98.2	Z:	0	C:	40.4	Conc:	40.4
Z:	0	C:	40.3	R:	98.2	Conc:	40.3
UOM: ppm				Mean Test Assay:	40.3	ppm	

Reference Standard: Type / Cylinder #: GMIS / DT0019705

Concentration / Uncertainty: 98.1 ppm ± 0.4 ppm

Expiration Date: 01/23/2028

Traceable to: SRM # / Sample # / Cylinder #: SRM 1679c / 3-4-45 / FF26593

SRM Concentration (enter with units) / 98.40 ppm / ± 0.40 ppm

SRM Expiration Date: 01/26/2020

Second Analysis Data:				Date			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM: ppm				Mean Test Assay:	ppm		

2. Component: Nitric oxide

Requested Concentration: 25 ppm
Certified Concentration: 25.8 ppm
Instrument Used: Thermo Electron 42-LS S/N 1030645077
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 03/25/2021

First Analysis Data:				Date			
Z:	0	R:	50	C:	25.7	Conc:	25.7
R:	50	Z:	0	C:	25.8	Conc:	25.8
Z:	0	C:	25.8	R:	49.9	Conc:	25.8
UOM: ppm				Mean Test Assay:	25.8	ppm	

Reference Standard: Type / Cylinder #: PRM / APEX1324323

Concentration / Uncertainty: 50.04 ppm ± 0.20 ppm

Expiration Date: 12/09/2022

Traceable to: SRM # / Sample # / Cylinder #: PRM / C1765710 01 / APEX1324323

SRM Concentration (enter with units) / 50.04 ppm / ± 0.20 ppm

SRM Expiration Date: 12/09/2022

Second Analysis Data:				Date			
Z:	0	R:	50	C:	25.8	Conc:	25.9
R:	49.8	Z:	0	C:	25.7	Conc:	25.8
Z:	0	C:	25.7	R:	49.8	Conc:	25.8
UOM: ppm				Mean Test Assay:	25.8	ppm	

Analyzed By

Henry Koung

Certified By

Lesanna Flores



CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PRAXAIR PKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA 93455-1123

Certificate Issuance Date: 03/29/2021
Praxair Order Number: 71635196
Part Number: NI C080MNTE-AS
Customer PO Number: 79632562

Fill Date: 03/17/2021
Lot Number: 70066107611
Cylinder Style & Outlet: AS CGA 660
Cylinder Pressure and Volume: 2000 psig 140 B3

Certified Concentration

Expiration Date:	03/29/2029	NIST Traceable
Cylinder Number:	DT0036914	Expanded Uncertainty
80.6 ppm	Carbon monoxide	± 0.3 ppm
55.5 ppm	Nitric oxide	± 0.3 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only: NOx 55.8 ppm

Certification Information: Certification Date: 03/29/2021 Term: 96 Months Expiration Date: 03/29/2029

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon monoxide

Requested Concentration: 80 ppm
 Certified Concentration: 80.6 ppm
 Instrument Used: Horiba VIA-510 S/N 43627990042
 Analytical Method: NDIR
 Last Multipoint Calibration: 02/26/2021

First Analysis Data:				Date	
Z:	R:	C:	Conc:		
0	98	80.7	80.6	03/22/2021	
0	0	80.5	80.5		
0	0	80.7	80.7		
UOM: ppm			Mean Test Assay:	80.6 ppm	

Reference Standard: Type / Cylinder #: GMIS / DT0019705
 Concentration / Uncertainty: 98.1 ppm ± 0.4 ppm
 Expiration Date: 01/23/2028

Traceable to: SRM # / Sample # / Cylinder #: SRM 1579c / 3-4-45 / FF28593
 SRM Concentration (enter with units): 98.40 ppm / ± 0.40 ppm
 SRM Expiration Date: 01/28/2029

Second Analysis Data:				Date	
Z:	R:	C:	Conc:		
0	0	0	0	03/29/2021	
0	0	0	0		
0	0	0	0		
UOM: ppm			Mean Test Assay:	ppm	

2. Component: Nitric oxide

Requested Concentration: 55 ppm
 Certified Concentration: 55.5 ppm
 Instrument Used: Thermo Electron 42i-LS S/N 1030645077
 Analytical Method: Chemiluminescence
 Last Multipoint Calibration: 03/15/2021

First Analysis Data:				Date	
Z:	R:	C:	Conc:		
0	49	55.4	55.4	03/22/2021	
49	0	55.5	55.5		
0	0	55.5	55.5		
UOM: ppm			Mean Test Assay:	55.5 ppm	

Reference Standard: Type / Cylinder #: GMIS / DT0037649
 Concentration / Uncertainty: 49.01 ppm ± 0.21 ppm
 Expiration Date: 01/07/2029

Traceable to: SRM # / Sample # / Cylinder #: PRM / C1765710.01 / APEX1324323
 SRM Concentration (enter with units): 50.04 PPM / ± 0.20 PPM
 SRM Expiration Date: 12/05/2022

Second Analysis Data:				Date	
Z:	R:	C:	Conc:		
0	49	55.4	55.6	03/29/2021	
48.8	0	55.4	55.6		
0	0	55.1	55.3		
UOM: ppm			Mean Test Assay:	55.5 ppm	

Analyzed By

Henry Koung

Certified By

Leeanna Flores



Making our world more productive

DocNumber: 503350



Linde Gas & Equipment Inc. 5700 S. Alameda Street Los Angeles CA 90058 Tel: 323-585-2154 Fax: 714-542-6689 PGVP ID: F22022

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

LGEPKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA 93455-1123

Certificate Issuance Date: 09/16/2022
Linde Order Number: 72180572
Part Number: NI CO80MO14E-AS
Customer PO Number: 80185295

Fill Date: 09/06/2022
Lot Number: 70086224903
Cylinder Style & Outlet: AS CGA 350
Cylinder Pressure and Volume: 2000 psig 140 ft3

Certified Concentration

Expiration Date:	09/16/2030	NIST Traceable
Cylinder Number:	EB0012199	Expanded Uncertainty
80.4 ppm	Carbon monoxide	± 0.7 ppm
5.02 %	Oxygen	± 0.02 %
Balance	Nitrogen	

ProSpec EZ Cert



Certification Information:

Certification Date: 09/16/2022

Term: 96 Months

Expiration Date: 09/16/2030

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component:

Carbon monoxide

Requested Concentration: 80 ppm
Certified Concentration: 80.4 ppm
Instrument Used: Horiba VIA-510 S/N 576876015
Analytical Method: NDIR
Last Multipoint Calibration: 08/30/2022

First Analysis Data:				Date			
Z:	0	R:	100.1	C:	80.5	Conc:	80.4
R:	100.2	Z:	0	C:	80.5	Conc:	80.4
Z:	0	C:	80.5	R:	100.2	Conc:	80.4
UOM:	ppm	Mean Test Assay:		80.4	ppm		

Reference Standard:

Type / Cylinder #: NTRM / CC105919

Concentration / Uncertainty: 100.1 ppm ±0.8 ppm

Expiration Date: 07/09/2027

Traceable to:

SRM # / Sample # / Cylinder #: NTRM / 190703 / CC8737

SRM Concentration / Uncertainty: 100.1 ppm / ±0.8 ppm

SRM Expiration Date: 07/09/2027

Second Analysis Data:				Date			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM:	ppm	Mean Test Assay:			ppm		

2. Component:

Oxygen

Requested Concentration: 5 %
Certified Concentration: 5.02 %
Instrument Used: Siemens Oxymat 6E S/N 7M820211AA000CA1
Analytical Method: Paramagnetic
Last Multipoint Calibration: 08/30/2022

First Analysis Data:				Date			
Z:	0	R:	4.97	C:	5.02	Conc:	5.02
R:	4.97	Z:	0	C:	5.02	Conc:	5.02
Z:	0	C:	5.02	R:	4.97	Conc:	5.02
UOM:	%	Mean Test Assay:		5.02	%		

Reference Standard:

Type / Cylinder #: GMIS / CC163512

Concentration / Uncertainty: 4.97 % ±0.02 %

Expiration Date: 07/17/2029

Traceable to:

SRM # / Sample # / Cylinder #: SRM 2658a / 72-D-28 / CAL016862

SRM Concentration / Uncertainty: 9.918% / ±0.022%

SRM Expiration Date: 02/03/2024

Second Analysis Data:				Date			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM:	%	Mean Test Assay:			%		

Analyzed By

Courtney Ziegler

Certified By

Lisette Morales

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

DocNumber: 406153



Praxair Distribution, Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22021

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PRAXAIR PKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA 93455-1123

Certificate Issuance Date: 03/22/2021
Praxair Order Number: 71635262
Part Number: NI CO170010E-AS
Customer PO Number: 70632626

Fill Date: 03/12/2021
Lot Number: 70066107102
Cylinder Style & Outlet: AS CGA 590
Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration

Expiration Date:	03/19/2029	NIST Traceable
Cylinder Number:	CC73183	Expanded Uncertainty
169.1 ppm	Carbon monoxide	± 0.8 ppm
10.03 %	Oxygen	± 0.04 %
Balance	Nitrogen	

ProSpec EZ Cert



Certification Information:

Certification Date: 03/19/2021

Term: 96 Months

Expiration Date: 03/19/2029

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-800/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor $k = 2$. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon monoxide

Requested Concentration: 170 ppm
Certified Concentration: 169.1 ppm
Instrument Used: Horiba VIA-510 S/N 576876015
Analytical Method: NDIR
Last Multipoint Calibration: 03/01/2021

First Analysis Data:		Date	
Z:	R:	C:	Conc:
0	497.5	169.1	169.1
497.6	0	169.2	169.2
0	169.1	497.6	169.1
UOM: ppm		Mean Test Assay: 169.1 ppm	

Reference Standard: Type / Cylinder #: GMIS / CC319383
Concentration / Uncertainty: 497.5 ppm ± 2.0 ppm
Expiration Date: 04/26/2025
Traceable to: SRM # / Sample # / Cylinder #: SRM 1680b / 2-J-15 / CAL018072
SRM Concentration (enter with units): 490.4 ppm / ± 2.0 ppm
SRM Expiration Date: 09/29/2021

Second Analysis Data:		Date	
Z:	R:	C:	Conc:
0	0	0	0
0	0	0	0
0	0	0	0
UOM: ppm		Mean Test Assay: ppm	


2. Component: Oxygen

Requested Concentration: 10 %
Certified Concentration: 10.03 %
Instrument Used: 7MB20211AA000CA1
Analytical Method: Paramagnetic
Last Multipoint Calibration: 03/15/2021

First Analysis Data:		Date	
Z:	R:	C:	Conc:
0	9.875	10.02	10.02
9.875	0	10.03	10.03
0	10.03	9.876	10.03
UOM: %		Mean Test Assay: 10.03 %	

Reference Standard: Type / Cylinder #: NTRM / DT0010287
Concentration / Uncertainty: 9.875 % ± 0.040 %
Expiration Date: 11/18/2022
Traceable to: SRM # / Sample # / Cylinder #: NTRM / 170701 / DT0010287
SRM Concentration (enter with units): 9.875 % / ± 0.040 %
SRM Expiration Date: 11/18/2022

Second Analysis Data:		Date	
Z:	R:	C:	Conc:
0	0	0	0
0	0	0	0
0	0	0	0
UOM: %		Mean Test Assay: %	

Analyzed By 
Amelia Real

Certified By 
Jose Vasquez

Third Quarter Test Report

Cylinder Gas Audit

Test Date(s): August 22, 2024
CEMTEK Project No.: SN00192

Prepared for:

Tajiguas Landfill

**Anaerobic Digesting Facility (ADF), Units A and B
Goleta, CA**

Prepared by:
CEMTEK KVB-Enertec



Contents

1	Introduction	1
2	Monitor Information	2
3	Summary of Results	2
4	Cylinder Gas Audit Test Procedure	3
5	Worksheets and Supporting Documentation	5
	Table 1: Unit A CGA Test Results Summary	2
	Table 2: Unit B CGA Test Results Summary	3

**Quarter Audit Test Report
Tajiguas Landfill**

1 Introduction

This quarterly audit report outlines the procedures and results of the Cylinder Gas Audit (CGA) check performed on the monitors at this facility. All testing was done in accordance with 40 CFR 60, Appendix F Procedure 1.

Tajiguas Landfill is located at 14470 Calle Real in Goleta, California that is approximately 26 miles west of the City of Santa Barbara. The landfill began receiving refuse in 1967 to serve the City of Santa Barbara, City of Goleta, unincorporated areas of Montecito and Summerland, rural areas of southern Santa Barbara County, the Santa Ynez Valley and Cuyama Valley. It is located in a canyon known as Cañada de la Pila. Immediately south of the landfill site are U.S. Highway 101, which provides access to the site, Union Pacific Railroad tracks, and the Pacific Ocean. The southern portion of the site is within the California Coastal Zone. For District regulatory purposes, the facility location is in the Southern Zone of Santa Barbara County.

Municipal solid waste (MSW) is delivered to a tipping area inside the Material Recovery Facility (MRF) building at Tajiguas. The material is subsequently sorted into organics, recyclables, and residue in the materials sorting area. Recyclables collected in the materials sorting area are sold to the market while waste residue is landfilled. The sorted organics are placed in the anaerobic digesters to generate biogas in the Anaerobic Digester Facility (ADF). The biogas is treated and combusted in combined heat and power (CHP) internal combustion (IC) engines for power generation, or an enclosed flare located at the ADF. Following biogas generation, the digestate is processed into soil amendments and compost at the Compost Management Unit (CMU). The MRF, ADF, and CMU are designed and constructed by MSB and owned by Santa Barbara County Public Works Department (SBCPWD).

The waste residue placed in the landfill generates LFG in the subsurface landfill through anaerobic biological decomposition. The LFG is collected onsite using a vapor extraction system and handled using a collection and transportation system. A leachate management system collects the groundwater found in the landfill subsurface. The LFG is scrubbed of moisture, particulates, and hydrogen sulfide. The landfill, LFG collection system, hydrogen sulfide scrubber system, and leachate management system are owned and operated by the SBCPWD and permitted separately under PT-70/Reeval 9788-R4.

Currently, treated LFG is combusted in an onsite enclosed flare or IC engine. The LFG treatment system, two LFG-fired CHP engines, and MRF enclosed flare subject to the ATC 14500-02 permit will replace the existing equipment.

Two of the processes involved at the stationary source are as follows:

Anaerobic Digestion Facility: The organic (food and green) waste from the MRF is placed into digesters. An anaerobic digestion process generates biogas. This biogas is sent to the ADF combustion equipment. After the anaerobic digestion process is complete, the residual organic waste is sent to the CMU.

Anaerobic Digestion Facility Combustion Equipment: Biogas from the ADF digesters is sent to two CHP engines to produce electricity to the grid and for onsite needs. Treated LFG is used as a supplemental fuel. If one of the engines is offline or if one of the ADF digesters is being purged, biogas is routed to the ADF enclosed flare.

**Quarter Audit Test Report
Tajiguas Landfill**

2 Monitor Information

The following table provides information on the monitors that were subject to this test program.

ADF Unit A

Analyzer	Manufacturer/Model	Range(s)	Serial Number
Stack NO _x /O ₂	TAPI T200M	NO _x : 0-30/0-100 ppm O ₂ : 0-25%	1301
CO	TAPI T300M	0-150/0-300 ppm	668

ADF Unit B

Analyzer	Manufacturer/Model	Range(s)	Serial Number
Stack NO _x /O ₂	TAPI T200M	NO _x : 0-30/0-100 ppm O ₂ : 0-25%	1302
CO	TAPI T300M	0-150/0-300 ppm	669

3 Summary of Results

The results for the Cylinder Gas Audit (CGA) checks performed on the facility monitors are summarized in the following results table.

Table 1: Unit A CGA Test Results Summary

Analyzer	Results	Criteria	Status	Test Date
NO _x Low range	Low = -10.45% Mid = -6.51%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	8/22/24
NO _x High range	Low = -1.40% Mid = -0.87%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	8/22/24
CO Low range	Low = -2.96% Mid = -2.17%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	8/22/24
CO High range	Low = 0.17% Mid = 0.75%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	8/22/24
O ₂	Low = -1.50% Mid = -0.07%	≤15% (40 CFR 60, Appendix F)	Pass	8/22/24

**Quarter Audit Test Report
Tajiguas Landfill**

Table 2: Unit B CGA Test Results Summary

Analyzer	Results	Criteria	Status	Test Date
NO_x Low range	Low = -3.57% Mid = -5.14%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	8/22/24
NO_x High range	Low = -1.45% Mid = -1.65%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	8/22/24
CO Low range	Low = -2.26% Mid = -0.05%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	8/22/24
CO High range	Low = 4.48% Mid = 5.62%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	8/22/24
O₂	Low = 3.59% Mid = 1.30%	≤15% (40 CFR 60, Appendix F)	Pass	8/22/24

4 Cylinder Gas Audit Test Procedure

The Cylinder Gas Audit (CGA) is performed for each pollutant concentration monitor at least once during each unit operating quarter based on the requirements of 40 CFR 60, Appendix F. CGAs are conducted in three consecutive quarters. Separate calibration gas cylinders are used for each concentration during the audit.

1. All audit gas cylinders are connected to the proper transport lines. EPA Protocol certified gases are used. Cylinders are checked to ensure that each audit gas has at least 200 psi.
2. The analyzers are challenged with an audit gas of known concentration at two points within the following concentration ranges (40 CFR 60, Appendix F):

Audit Point	Pollutant Monitors % of span	O₂ % by volume
Low level	20-30% of span	4-6% by volume
Mid Level	50-60% of span	8-12% by volume

3. The analyzers are challenged three times at each audit point. Calibration gas injections are done alternately between the two audit values. The average of the three responses for each audit point is used in determining accuracy. The monitor is challenged at each audit point for a sufficient time to assure that any absorption-desorption phenomena at the CEMS sample transport surfaces have stabilized. The injection time also takes into account the response time of the analyzers and sample system.

**Quarter Audit Test Report
Tajiguas Landfill**

4. Each monitor is operated in its normal sampling mode, that is, the audit gas passes through all filters, scrubbers, conditioners, and other monitor components used during normal sampling, and through as much of the sampling probe as is practical.
5. The difference between the actual concentration of the audit gas and the concentration indicated by the monitor will determine the accuracy of the CEMS.

The accuracy values for each concentration should not exceed 15% of reference value as the primary pass/fail criteria. As of May 30, 2023, the EPA has implemented an alternate pass/fail for pollutant analyzers using a tiered approach based on analyzer range as follows (reference 40 CFR 60, Appendix F, Procedure 1, section 5.2.3):

<i>Analyzer range</i>	<i>Alternate criteria, ppm difference</i>
>50 ppm	±5 ppm
≤50 ppm but >20 ppm	±3 ppm
≤20 ppm	±2 ppm

Cylinder Gas Audit Accuracy 40 CFR 60, Appendix F, Section 6.3	
$A = \frac{C_m - C_a}{C_a} \times 100$	<p>A = Percent accuracy of the CEM</p> <p>C_m = The average monitor response to the specific audit gas (high or low) in units of concentration</p> <p>C_a = Certified value of audit gas (value according to EPA Protocol certification) in units of concentration</p>

5 Worksheets and Supporting Documentation

The attached pages contain worksheets and supporting documentation for the CGA checks.

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA

Project# SN00192

Cylinder Gas Audit - NOx Low Range

For quarter ending: **09/30/24**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1301
 Analyzer Range: 30
 Test Date: 08/22/24

	Reference Gas Value (C)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	8.04	26.80	OK	SA19336	08/29/25		OK
Mid	17.2	57.33	OK	CC499039	06/23/25		OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response	
1	10:57	6.97	11:02	15.96	
2	11:07	7.31	11:13	16.09	
3	11:22	7.32	11:29	16.19	
Average Response (Cm)		7.20		16.08	
Difference (Cm-Ca)		-0.84		-1.12	
Status (for alt. criteria of +/- 3 ppm difference)		PASS		PASS	range >20 but ≤ 50 ppm
Accuracy %, ((Cm-Ca)/Ca) * 100		-10.45		-6.51	
Status (for primary criteria of 15%)		PASS		PASS	

Cylinder Gas Audit - NOx High Range

Analyzer Range: 100
 Test Date: 08/22/24

	Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	24.6	24.60	OK	CC748576	05/31/27		OK
Mid	54.5	54.50	OK	CC3035	11/16/29		OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response	
1	11:33	24.10	11:37	53.87	
2	11:43	24.28	11:48	54.05	
3	11:53	24.39	11:58	54.15	
Average Response (Cm)		24.26		54.02	
Difference (Cm-Ca)		-0.34		-0.48	
Status (for alt. criteria of +/- 5 ppm difference)		PASS		PASS	range > than 50 ppm
Accuracy %, ((Cm-Ca)/Ca) * 100		-1.40		-0.87	
Status (for primary criteria of 15%)		PASS		PASS	

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:

>50 ppm: +/- 5 ppm difference

>20 ppm and ≤ 50 ppm: +/- 3 ppm difference

<= 20 ppm: +/- 2 ppm difference

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA

Project# SN00192

Cylinder Gas Audit - CO Low Range

For quarter ending: **09/30/24**

Manufacturer: TAPI
 Model: T300M
 Serial Number: 668
 Analyzer Range: 150
 Test Date: 08/22/24

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	40.1	26.73	OK	CC748576	05/31/27 OK
Mid	82.8	55.20	OK	CC3035	11/16/29 OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	11:32	38.92	11:39	80.98
2	11:43	38.93	11:49	80.97
3	11:54	38.89	11:59	81.05
Average Response (Cm)		38.91		81.00
Difference (Cm-Ca)		-1.19		-1.80
Status (for alt. criteria of +/- 5 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		-2.96		-2.17
Status (for primary criteria of 15%)		PASS		PASS

range > than 50 ppm

Cylinder Gas Audit - CO High Range

Analyzer Range: 300
 Test Date: 08/22/24

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	79.7	26.57	OK	CC283311	01/13/31 OK
Mid	169.1	56.37	OK	CC73183	03/19/29 OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	10:25	79.9	10:31	170.5
2	10:36	79.8	10:41	170.4
3	10:46	79.8	10:51	170.2
Average Response (Cm)		79.83		170.36
Difference (Cm-Ca)		0.13		1.26
Status (for alt. criteria of +/- 5 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		0.17		0.75
Status (for primary criteria of 15%)		PASS		PASS

range > than 50 ppm

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:
 >50 ppm: +/- 5 ppm difference
 >20 ppm and ≤ 50 ppm: +/- 3 ppm difference
 <= 20 ppm: +/- 2 ppm difference

**Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA**

Project# SN00192

Cylinder Gas Audit - O2

For quarter ending: **09/30/24**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1301
 Analyzer Range: 25
 Test Date: 08/22/24

Reference Gas Value (Ca)	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	5.10	OK	CC283311	01/13/31	OK
Mid	10.03	OK	CC73183	03/19/29	OK

Cal gas values must be between 4-6% by volume for low and 8-12% by volume for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	10:25	5.03	10:30	10.03
2	10:35	5.02	10:40	10.02
3	10:46	5.02	10:51	10.02
Average Response (Cm)		5.02		10.02
Difference (Cm-Ca)		-0.08		-0.01
Accuracy %, ((Cm-Ca)/Ca) * 100		-1.50		-0.07
Status (for primary criteria of 15%)		PASS		PASS

Notes:

Pass/Fail Criteria: +/- 15% of reference value (no alternate)
 (40 CFR 60, Appendix F)

Average Values Report
 Generated: 8/22/2024 12:04

Santa Barbara County Public Works

Company: ~~Cemtek KVB-Enertec~~
 Plant: **Tajiguas Landfill**
 City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
 Source: ADF1

Period Start: 8/22/2024 10:50
 Period End: 8/22/2024 11:35
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

Period Start:	Average A1_NOx ppm	Average A1_NOxLo ppm	Average A1_CO ppm	Average A1_COLo ppm
08/22/2024 10:50	-0.65	-0.65	170.23	161.27
08/22/2024 10:51	-0.67	-0.67	170.22	161.25
08/22/2024 10:52	-0.68	-0.68	170.30	161.28
08/22/2024 10:53	-0.67	-0.67	170.35	161.27
08/22/2024 10:54	1.51	1.51	103.50	65.04
08/22/2024 10:55	7.02	7.02	1.57	1.57
08/22/2024 10:56	6.96	6.96	-0.55	-0.55
08/22/2024 10:57	6.97	6.97	-0.58	-0.58
08/22/2024 10:58	7.00	7.00	-0.63	-0.63
08/22/2024 10:59	9.11	9.11	-0.55	-0.55
08/22/2024 11:00	15.81	15.81	-0.56	-0.56
08/22/2024 11:01	15.93	15.93	-0.63	-0.63
08/22/2024 11:02	15.96	15.96	-0.63	-0.63
08/22/2024 11:03	16.00	16.00	-0.56	-0.55
08/22/2024 11:04	15.47	15.47	-0.46	-0.46
08/22/2024 11:05	8.74	8.74	-0.39	-0.39
08/22/2024 11:06	7.35	7.36	-0.56	-0.56
08/22/2024 11:07	7.31	7.31	-0.55	-0.55
08/22/2024 11:08	7.26	7.26	-0.56	-0.56
08/22/2024 11:09	7.25	7.25	-0.54	-0.54
08/22/2024 11:10	14.27	14.27	-0.41	-0.41
08/22/2024 11:11	16.12	16.12	-0.60	-0.60
08/22/2024 11:12	16.10	16.10	-0.63	-0.63
08/22/2024 11:13	16.09	16.09	-0.66	-0.66
08/22/2024 11:14	16.11	16.11	-0.67	-0.68
08/22/2024 11:15	13.73	13.73	-0.68	-0.68
08/22/2024 11:16	18.59	18.59	-0.56	-0.56
08/22/2024 11:17	16.49	16.48	-0.43	-0.44
08/22/2024 11:18	16.41	16.41	-0.69	-0.69
08/22/2024 11:19	12.17	12.17	-0.51	-0.51
08/22/2024 11:20	7.44	7.44	-0.56	-0.56
08/22/2024 11:21	7.34	7.34	-0.65	-0.64
08/22/2024 11:22	7.32	7.32	-0.54	-0.56
08/22/2024 11:23	7.29	7.29	-0.61	-0.61
08/22/2024 11:24	7.97	7.97	-0.60	-0.60
08/22/2024 11:25	15.20	15.20	-0.61	-0.61
08/22/2024 11:26	16.09	16.09	-0.66	-0.67
08/22/2024 11:27	16.12	16.12	-0.62	-0.62
08/22/2024 11:28	16.18	16.18	-0.59	-0.59
08/22/2024 11:29	16.19	16.19	-0.40	-0.40
08/22/2024 11:30	23.81	23.81	32.87	32.88
08/22/2024 11:31	24.15	24.15	38.89	38.89
08/22/2024 11:32	24.05	24.05	38.92	38.92
08/22/2024 11:33	23.95	23.95	38.99	38.99
08/22/2024 11:34	23.88	23.88	39.02	39.02
08/22/2024 11:35	40.67	23.89	60.59	60.76
Final Average*	12.75	12.39	22.09	20.47
Maximum*	40.67	24.15	170.35	161.28
	08/22/2024	08/22/2024	08/22/2024	08/22/2024
	11:35	11:31	10:53	10:52
Minimum*	-0.68	-0.68	-0.69	-0.69
	08/22/2024	08/22/2024	08/22/2024	08/22/2024
	10:52	10:52	11:18	11:18

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
 Generated: 8/22/2024 12:02

Company: **Santa Barbara County Public Works**
~~Cemtek KVB-Enertec~~
 Plant: **Tajiguas Landfill**
 City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
 Source: ADF1

Period Start: 8/22/2024 11:30
 Period End: 8/22/2024 12:02
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

Period Start:	Average A1_NOx ppm	Average A1_NOxHi ppm	Average A1_CO ppm	Average A1_COLo ppm
08/22/2024 11:30	23.81	23.93	32.87	32.88
08/22/2024 11:31	24.15	24.28	38.89	38.89
08/22/2024 11:32	24.05	24.19	38.92	38.92
08/22/2024 11:33	23.95	24.10	38.99	38.99
08/22/2024 11:34	23.88	24.02	39.02	39.02
08/22/2024 11:35	40.67	40.72	60.59	60.76
08/22/2024 11:36	53.85	53.85	80.85	80.84
08/22/2024 11:37	53.87	53.87	80.92	80.92
08/22/2024 11:38	53.99	53.99	80.98	80.98
08/22/2024 11:39	54.04	54.06	80.98	80.98
08/22/2024 11:40	42.63	42.64	64.23	64.23
08/22/2024 11:41	24.55	24.67	39.20	39.20
08/22/2024 11:42	24.23	24.36	38.94	38.94
08/22/2024 11:43	24.15	24.28	38.93	38.93
08/22/2024 11:44	24.07	24.20	38.97	38.97
08/22/2024 11:45	31.90	31.99	51.51	52.13
08/22/2024 11:46	54.18	54.18	80.40	80.40
08/22/2024 11:47	54.05	54.05	80.99	80.99
08/22/2024 11:48	54.05	54.05	81.13	81.13
08/22/2024 11:49	54.07	54.07	80.97	80.97
08/22/2024 11:50	51.79	51.79	69.91	69.91
08/22/2024 11:51	24.57	24.70	39.71	39.71
08/22/2024 11:52	24.30	24.42	39.04	39.04
08/22/2024 11:53	24.26	24.39	38.96	38.96
08/22/2024 11:54	24.20	24.30	38.90	38.89
08/22/2024 11:55	24.12	24.27	41.97	41.97
08/22/2024 11:56	52.21	52.21	77.82	77.82
08/22/2024 11:57	54.13	54.13	81.01	81.01
08/22/2024 11:58	54.16	54.15	81.08	81.08
08/22/2024 11:59	54.18	54.18	81.04	81.05
08/22/2024 12:00	54.21	54.21	71.49	71.49
08/22/2024 12:01	67.43	67.43	6.71	6.71
08/22/2024 12:02	N/A	N/A	N/A	N/A
Final Average*	39.80	39.87	57.37	57.40
Maximum*	67.43	67.43	81.13	81.13
	08/22/2024 12:01	08/22/2024 12:01	08/22/2024 11:48	08/22/2024 11:48
Minimum*	23.81	23.93	6.71	6.71
	08/22/2024 11:30	08/22/2024 11:30	08/22/2024 12:01	08/22/2024 12:01

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
 Generated: 8/22/2024 10:55

Santa Barbara County Public Works

Company: ~~Cemtek KVB-Enertec~~
 Plant: **Tajiguas Landfill**
 City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
 Source: ADF1

Period Start: 8/22/2024 10:20
 Period End: 8/22/2024 10:55
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

Period Start:	Average A1_COHi ppm	Average A1_CO ppm	Average A1_O2 %
08/22/2024 10:20	79.8	78.75	5.03
08/22/2024 10:21	34.2	33.66	6.53
08/22/2024 10:22	54.7	54.03	5.44
08/22/2024 10:23	78.8	77.77	5.03
08/22/2024 10:24	79.8	78.78	5.03
08/22/2024 10:25	79.9	78.77	5.03
08/22/2024 10:26	79.9	78.81	5.02
08/22/2024 10:27	103.3	102.21	7.00
08/22/2024 10:28	168.6	168.57	10.03
08/22/2024 10:29	170.4	170.38	10.03
08/22/2024 10:30	170.6	170.55	10.03
08/22/2024 10:31	170.5	170.47	10.03
08/22/2024 10:32	128.2	127.54	7.38
08/22/2024 10:33	80.8	79.73	5.03
08/22/2024 10:34	79.9	78.81	5.02
08/22/2024 10:35	79.8	78.72	5.02
08/22/2024 10:36	79.8	78.77	5.02
08/22/2024 10:37	92.9	91.73	6.27
08/22/2024 10:38	145.9	146.69	9.68
08/22/2024 10:39	170.3	170.30	10.03
08/22/2024 10:40	170.5	170.48	10.02
08/22/2024 10:41	170.4	170.42	10.02
08/22/2024 10:42	159.4	159.10	9.49
08/22/2024 10:43	88.0	85.58	5.18
08/22/2024 10:44	80.0	78.90	5.02
08/22/2024 10:45	79.9	78.82	5.03
08/22/2024 10:46	79.8	78.76	5.02
08/22/2024 10:47	79.7	78.71	5.01
08/22/2024 10:48	79.8	78.74	5.03
08/22/2024 10:49	144.3	143.83	9.11
08/22/2024 10:50	170.2	170.23	10.02
08/22/2024 10:51	170.2	170.22	10.02
08/22/2024 10:52	170.3	170.30	10.02
08/22/2024 10:53	170.3	170.35	10.03
08/22/2024 10:54	100.5	103.50	5.20
08/22/2024 10:55	N/A	N/A	N/A
Final Average*	115.5	114.94	7.20
Maximum*	170.6	170.55	10.03
	08/22/2024 10:30	08/22/2024 10:30	08/22/2024 10:53
Minimum*	34.2	33.66	5.01
	08/22/2024 10:21	08/22/2024 10:21	08/22/2024 10:47

* Does not include Invalid Averaging Periods ("N/A")

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit B
Goleta, CA

Project# SN00192

Cylinder Gas Audit - NOx Low Range

For quarter ending: **09/30/24**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1302
 Analyzer Range: 30
 Test Date: 08/22/24

Reference Gas Value (C)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	8.04	26.80	OK	SA19336	08/29/25	OK
Mid	17.2	57.33	OK	CC499039	06/23/25	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	08:07	7.74	08:12	16.39
2	08:18	7.77	08:24	16.29
3	08:30	7.75	08:34	16.27
Average Response (Cm)		7.75		16.32
Difference (Cm-Ca)		-0.29		-0.88
Status (for alt. criteria of +/- 3 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		-3.57		-5.14
Status (for primary criteria of 15%)		PASS		PASS

range >20 but ≤ 50 ppm

Cylinder Gas Audit - NOx High Range

Analyzer Range: 100
 Test Date: 08/22/24

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	24.6	24.60	OK	CC748576	05/31/27	OK
Mid	54.5	54.50	OK	CC3035	11/16/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	08:40	24.19	08:46	53.61
2	08:51	24.31	08:57	53.61
3	09:03	24.23	09:10	53.59
Average Response (Cm)		24.24		53.60
Difference (Cm-Ca)		-0.36		-0.90
Status (for alt. criteria of +/- 5 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		-1.45		-1.65
Status (for primary criteria of 15%)		PASS		PASS

range > than 50 ppm

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:

>50 ppm: +/- 5 ppm difference

>20 ppm and ≤ 50 ppm: +/- 3 ppm difference

<= 20 ppm: +/- 2 ppm difference

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit B
Goleta, CA

Project# SN00192

Cylinder Gas Audit - CO Low Range

For quarter ending: **09/30/24**

Manufacturer: TAPI
 Model: T300M
 Serial Number: 669
 Analyzer Range: 150
 Test Date: 08/22/24

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Status	
Low	40.1	26.73	OK	CC748576	05/31/27	OK
Mid	82.8	55.20	OK	CC3035	11/16/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	08:41	39.23	08:47	82.89
2	08:51	39.15	08:57	82.77
3	09:04	39.20	09:10	82.61
Average Response (Cm)		39.19		82.76
Difference (Cm-Ca)		-0.91		-0.04
Status (for alt. criteria of +/- 5 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		-2.26		-0.05
Status (for primary criteria of 15%)		PASS		PASS

range > than 50 ppm

Cylinder Gas Audit - CO High Range

Analyzer Range: 300
 Test Date: 08/22/24

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Status	
Low	79.7	26.57	OK	CC283311	01/13/31	OK
Mid	169.1	56.37	OK	CC73183	03/19/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	07:26	83.1	07:32	178.5
2	07:38	83.3	07:43	178.6
3	07:48	83.4	08:02	178.7
Average Response (Cm)		83.27		178.60
Difference (Cm-Ca)		3.57		9.50
Status (for alt. criteria of +/- 5 ppm difference)		PASS		FAIL
Accuracy %, ((Cm-Ca)/Ca) * 100		4.48		5.62
Status (for primary criteria of 15%)		PASS		PASS

range > than 50 ppm

Note: passed by primary criteria

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:

>50 ppm: +/- 5 ppm difference

>20 ppm and ≤ 50 ppm: +/- 3 ppm difference

≤ 20 ppm: +/- 2 ppm difference

**Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit B
Goleta, CA**

Project# SN00192

Cylinder Gas Audit - O2

For quarter ending: **09/30/24**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1302
 Analyzer Range: 25
 Test Date: 08/22/24

Reference Gas Value (Ca)	Status	Bottle #	Exp. Date	Status	
Low	5.10	OK	CC283311	01/13/31	OK
Mid	10.03	OK	CC73183	03/19/29	OK

Cal gas values must be between 4-6% by volume for low and 8-12% by volume for mic

Run Number	Run Time	Low Response	Run Time	Mid Response
1	07:26	5.29	07:32	10.15
2	07:38	5.28	07:43	10.16
3	07:47	5.28	08:01	10.17
Average Response (Cm)		5.28		10.16
Difference (Cm-Ca)		0.18		0.13
Accuracy %, ((Cm-Ca)/Ca) * 100		3.59		1.30
Status (for primary criteria of 15%)		PASS		PASS

Notes:

Pass/Fail Criteria: +/- 15% of reference value (no alternate)
 (40 CFR 60, Appendix F)

Average Values Report
Generated: 8/22/2024 11:07

Company: ~~Cemtek KVB-Enertec~~
Plant: **Tajiguas Landfill**
City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
Source: ADF2

Period Start: 8/22/2024 08:00
Period End: 8/22/2024 08:40
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average A2_NOx ppm	Average A2_NOxLo ppm	Average A2_O2 %
08/22/2024 08:00	0.01	0.00	10.17
08/22/2024 08:01	0.00	-0.01	10.17
08/22/2024 08:02	0.00	-0.01	10.15
08/22/2024 08:03	0.00	-0.01	10.94
08/22/2024 08:04	1.80	1.79	11.47
08/22/2024 08:05	7.61	7.61	0.23
08/22/2024 08:06	7.73	7.73	0.21
08/22/2024 08:07	7.74	7.74	0.20
08/22/2024 08:08	7.75	7.75	0.19
08/22/2024 08:09	7.78	7.78	0.19
08/22/2024 08:10	11.16	11.16	0.31
08/22/2024 08:11	16.38	16.38	0.18
08/22/2024 08:12	16.39	16.39	0.18
08/22/2024 08:13	16.42	16.42	0.19
08/22/2024 08:14	16.42	16.42	0.19
08/22/2024 08:15	15.71	15.71	0.19
08/22/2024 08:16	7.85	7.85	0.20
08/22/2024 08:17	7.77	7.77	0.19
08/22/2024 08:18	7.77	7.77	0.19
08/22/2024 08:19	7.76	7.76	0.20
08/22/2024 08:20	7.74	7.74	0.20
08/22/2024 08:21	12.66	12.66	0.20
08/22/2024 08:22	16.27	16.27	0.19
08/22/2024 08:23	16.29	16.29	0.19
08/22/2024 08:24	16.29	16.29	0.17
08/22/2024 08:25	16.31	16.31	0.17
08/22/2024 08:26	14.23	14.23	0.19
08/22/2024 08:27	7.83	7.83	0.19
08/22/2024 08:28	7.77	7.77	0.20
08/22/2024 08:29	7.75	7.75	0.19
08/22/2024 08:30	7.75	7.75	0.20
08/22/2024 08:31	7.74	7.74	0.18
08/22/2024 08:32	14.08	14.08	0.19
08/22/2024 08:33	16.27	16.27	0.18
08/22/2024 08:34	16.27	16.27	0.18
08/22/2024 08:35	16.27	16.27	0.19
08/22/2024 08:36	16.28	16.28	0.18
08/22/2024 08:37	16.73	16.73	0.28
08/22/2024 08:38	23.31	23.31	0.19
08/22/2024 08:39	23.51	23.50	0.18
08/22/2024 08:40	23.50	23.50	0.18
Final Average*	11.44	11.44	1.46
Maximum*	23.51	23.50	11.47
	08/22/2024 8:39	08/22/2024 8:40	08/22/2024 8:04
Minimum*	0.00	-0.01	0.17
	08/22/2024 8:03	08/22/2024 8:03	08/22/2024 8:25

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
 Generated: 8/22/2024 11:09

Santa Barbara County Public Works

Company: ~~Cemtek KVB-Enertec~~
 Plant: **Tajiguas Landfill**
 City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
 Source: ADF2

Period Start: 8/22/2024 08:30
 Period End: 8/22/2024 09:12
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

Period Start:	Average A2_NOx ppm	Average A2_NOxHi ppm	Average A2_COLo ppm
08/22/2024 08:30	7.75	8.03	-0.42
08/22/2024 08:31	7.74	7.98	-0.45
08/22/2024 08:32	14.08	14.50	-0.40
08/22/2024 08:33	16.27	16.77	-0.47
08/22/2024 08:34	16.27	16.74	-0.51
08/22/2024 08:35	16.27	16.73	-0.44
08/22/2024 08:36	16.28	16.73	-0.51
08/22/2024 08:37	16.73	17.25	6.18
08/22/2024 08:38	23.31	24.01	37.18
08/22/2024 08:39	23.51	24.23	39.15
08/22/2024 08:40	23.50	24.19	39.25
08/22/2024 08:41	23.49	24.14	39.23
08/22/2024 08:42	23.51	24.19	39.41
08/22/2024 08:43	41.08	41.31	75.00
08/22/2024 08:44	53.62	53.62	82.83
08/22/2024 08:45	53.63	53.63	82.93
08/22/2024 08:46	53.62	53.61	83.01
08/22/2024 08:47	53.63	53.63	82.89
08/22/2024 08:48	41.32	41.56	60.72
08/22/2024 08:49	23.70	24.41	39.63
08/22/2024 08:50	23.63	24.31	39.16
08/22/2024 08:51	23.63	24.31	39.15
08/22/2024 08:52	23.58	24.28	39.17
08/22/2024 08:53	23.55	24.25	39.14
08/22/2024 08:54	23.55	24.22	41.73
08/22/2024 08:55	50.68	50.68	77.74
08/22/2024 08:56	53.58	53.58	82.79
08/22/2024 08:57	53.61	53.61	82.77
08/22/2024 08:58	53.63	53.63	77.96
08/22/2024 08:59	12.21	12.40	10.17
08/22/2024 09:00	4.09	4.26	16.31
08/22/2024 09:01	23.56	24.24	38.89
08/22/2024 09:02	23.54	24.27	39.30
08/22/2024 09:03	23.53	24.23	39.10
08/22/2024 09:04	23.51	24.21	39.20
08/22/2024 09:05	23.50	24.20	39.09
08/22/2024 09:06	30.99	31.44	56.20
08/22/2024 09:07	53.47	53.47	82.03
08/22/2024 09:08	53.57	53.57	82.61
08/22/2024 09:09	53.59	53.59	82.76
08/22/2024 09:10	53.59	53.59	82.61
08/22/2024 09:11	53.63	53.63	82.65
08/22/2024 09:12	45.12	45.12	53.68
Final Average*	31.55	31.92	45.78
Maximum*	53.63	53.63	83.01
	08/22/2024	08/22/2024	08/22/2024
	9:11	9:11	8:46
Minimum*	4.09	4.26	-0.51
	08/22/2024	08/22/2024	08/22/2024
	9:00	9:00	8:36

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
 Generated: 8/22/2024 10:57

Santa Barbara County Public Works

Company: ~~Cemtek KVB-Enertec~~
 Plant: **Tajiguas Landfill**
 City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
 Source: ADF2

Period Start: 8/22/2024 07:20
 Period End: 8/22/2024 08:05
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

Period Start:	Average A2_CO ppm	Average A2_COHi ppm	Average A2_O2 %
08/22/2024 07:20	0.00	-0.2	20.98
08/22/2024 07:21	0.00	-0.3	20.98
08/22/2024 07:22	0.00	-0.3	20.98
08/22/2024 07:23	7.66	7.6	17.65
08/22/2024 07:24	75.00	77.2	5.29
08/22/2024 07:25	80.64	83.0	5.29
08/22/2024 07:26	80.75	83.1	5.29
08/22/2024 07:27	80.84	83.2	5.28
08/22/2024 07:28	80.76	83.2	5.27
08/22/2024 07:29	118.75	120.8	8.31
08/22/2024 07:30	176.87	176.9	10.15
08/22/2024 07:31	178.53	178.5	10.15
08/22/2024 07:32	178.48	178.5	10.15
08/22/2024 07:33	178.45	178.4	10.14
08/22/2024 07:34	178.20	178.2	10.01
08/22/2024 07:35	101.99	103.6	5.38
08/22/2024 07:36	81.08	83.5	5.28
08/22/2024 07:37	80.86	83.3	5.28
08/22/2024 07:38	80.86	83.3	5.28
08/22/2024 07:39	86.37	89.0	6.05
08/22/2024 07:40	169.18	169.2	10.14
08/22/2024 07:41	178.45	178.5	10.15
08/22/2024 07:42	178.57	178.6	10.17
08/22/2024 07:43	178.60	178.6	10.16
08/22/2024 07:44	159.35	159.9	8.39
08/22/2024 07:45	85.00	87.5	5.28
08/22/2024 07:46	80.93	83.4	5.28
08/22/2024 07:47	80.96	83.4	5.28
08/22/2024 07:48	80.95	83.4	5.27
08/22/2024 07:49	80.94	83.4	5.29
08/22/2024 07:50	80.83	83.3	5.28
08/22/2024 07:51	80.92	83.3	5.29
08/22/2024 07:52	80.85	83.3	5.27
08/22/2024 07:53	80.91	83.4	5.27
08/22/2024 07:54	80.94	83.4	5.28
08/22/2024 07:55	80.92	83.3	5.27
08/22/2024 07:56	80.87	83.2	5.28
08/22/2024 07:57	63.88	65.7	11.20
08/22/2024 07:58	2.83	2.4	20.96
08/22/2024 07:59	105.43	108.8	11.64
08/22/2024 08:00	177.52	177.5	10.17
08/22/2024 08:01	178.57	178.6	10.17
08/22/2024 08:02	178.72	178.7	10.15
08/22/2024 08:03	172.60	172.6	10.94
08/22/2024 08:04	38.89	39.7	11.47
08/22/2024 08:05	2.57	2.8	0.23
Final Average*	100.14	101.4	8.75
Maximum*	178.72	178.7	20.98
	08/22/2024 8:02	08/22/2024 8:02	08/22/2024 7:22
Minimum*	0.00	-0.3	0.23
	08/22/2024 7:22	08/22/2024 7:22	08/22/2024 8:05

* Does not include Invalid Averaging Periods ("N/A")



Making our world more productive

DocNumber: 491479



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22022

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

LGEPKG BAKERSFIELD CA HPS
3505 BUCK OWENS BLVD
BAKERSFIELD CA 93308-4919

Certificate Issuance Date: 08/29/2022
Linde Order Number: 72163095
Pan Number: NI NOBME-AS
Customer PO Number: 80167623

Fill Date: 08/12/2022
Lot Number: 70088222A05
Cylinder Style & Outlet: AS CGA 680
Cylinder Pressure and Volume: 2000 psig 140 R3

Certified Concentration

Expiration Date:	08/29/2025	NIST Traceable
Cylinder Number:	SA19336	Expanded Uncertainty
8.04 ppm	Nitric oxide	± 0.04 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only:

NOx 8.09 ppm

Certification Information:

Certification Date: 08/29/2022

Term: 36 Months

Expiration Date: 08/29/2025

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EP-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do not use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component:

Nitric oxide

Requested Concentration: 8 ppm
Certified Concentration: 8.04 ppm
Instrument Used: Thermo Electron 42i-LS S/N 1030645077
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 08/11/2022

Reference Standard:

Type / Cylinder #: GMIS / DT0038022

Concentration / Uncertainty: 9.42 ppm ±0.05 ppm

Expiration Date: 04/08/2025

Traceable to:

SRM # / Sample # / Cylinder #: PRM / C1837210.02 / APEX1324301

SRM Concentration / Uncertainty: 10.00 ppm ±0.05 ppm

SRM Expiration Date: 04/17/2022

First Analysis Data:				Date				
Z:	0	R:	9.42	C:	8.03	Conc:	8.03	
R:	9.42	Z:	0	C:	8.05	Conc:	8.05	
Z:	0	C:	8.04	R:	9.41	Conc:	8.04	
UOM: ppm							Mean Test Assay:	8.04 ppm

Second Analysis Data:				Date				
Z:	0	R:	9.42	C:	8.05	Conc:	8.04	
R:	9.44	Z:	0	C:	8.06	Conc:	8.05	
Z:	0	C:	8.04	R:	9.43	Conc:	8.03	
UOM: ppm							Mean Test Assay:	8.04 ppm

Analyzed By

Lissette Morales

Certified By

Henry Koung

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analysis performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

IN CASE OF EMERGENCY: CALL 1-800-645-4633

SDS ID: P-18-1884-NI

DO NOT REMOVE THIS LABEL

Lot No. 70086216106
Cylinder No. CC499039
Part No. NI NO17ME-AS
Volume: 140 ft³
Fill Date: 06/10/2022
Expiration Date: 06/23/2025
Cust. Ref. # MUSTANG



ProSpec
By Linde



Linde Gas & Equipment Inc.
5700 Alameda Street
Los Angeles, CA USA 90058

UN1956

Compressed gas, n.o.s. (Nitrogen, Nitric oxide)



EPA Protocol		CAS
Water Concentration	Component	10102-43-9
17.2 ppm	- Nitric oxide	7727-37-9
Balance	Nitrogen	

Warning



CONTAINS GAS UNDER PRESSURE; MAY EXPLODE IF HEATED. MAY DISPLACE OXYGEN AND CAUSE RAPID SUFFOCATION.

TLV:
Nitric oxide 25 ppm

Use and store only outdoors or in a well-ventilated place; Use a back flow preventive device in the piping; Use only with equipment rated for outdoor or in a well-ventilated place; Close valve after each use and when empty; Protect from sunlight when ambient temperature exceeds 52°C (125°F); Do not handle until all safety precautions have been read and understood; If inhaled, remove person to fresh air and rest; Get medical advice/attention; Do not open valve if connected to equipment; Do not use.

FIRST AID

If inhaled: If breathing is difficult, rest in a position comfortable for breathing. If not breathing, give artificial respiration. If breathing is normal, rest and call a physician. Call a physician. If eye contact, immediately flush thoroughly with water for at least 15 minutes. Hold the eyelids open and away from the face. Contact an ophthalmologist immediately.



Making our world more productive

DocNumber: 573298



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22024

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

LGEPKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA 93455-1123

Certificate Issue Date: 05/31/2024

Linde Order Number: 72814852

Part Number: NI CO40MN20E-AS

Customer PO Number: 80828173

Fill Date: 05/15/2024

Lot Number: 70085413603

Cylinder Style & Offset: AS CGA 560

Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration

Expiration Date:	05/31/2027	NIST Traceable
Cylinder Number:	CC748576	Expanded Uncertainty
40.1 ppm	Carbon monoxide	± 0.2 ppm
24.6 ppm	Nitric oxide	± 0.1 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only:

NOx 24.7 ppm

Certification Information:

Certification Date: 05/31/2024

Term: 36 Months

Expiration Date: 05/31/2027

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do not use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component:

Carbon monoxide

Requested Concentration: 40 ppm
Certified Concentration: 40.1 ppm
Instrument Used: Horiba VIA-510 S/N 576876015
Analytical Method: NDIR
Last Multipoint Calibration: 04/30/2024

First Analysis Data:				Date	05/21/2024		
Z:	0	R:	50.4	C:	40.1	Conc:	40.1
R:	50.5	Z:	0	C:	40.2	Conc:	40.2
Z:	0	C:	40.2	R:	50.4	Conc:	40.2
UOM:	ppm		Mean Test Assay:	40.1 ppm			

Reference Standard:

Type / Cylinder #: GMIS / DT0013574

Concentration / Uncertainty: 50.4 ppm ±0.2 ppm

Expiration Date: 09/19/2031

Traceable to:

SRM # / Sample # / Cylinder #: SRM 1678c / 4-L-41 / FF18402

SRM Concentration / Uncertainty: 49.136 PPM / ±0.065 PPM

SRM Expiration Date: 04/22/2029

Second Analysis Data:

Second Analysis Data:				Date			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM:	ppm		Mean Test Assay:	ppm			

Reference Standard:

Type / Cylinder #: GMIS / ND67519

Concentration / Uncertainty: 49.6 ppm ±0.2 ppm

Expiration Date: 02/09/2032

Traceable to:

SRM # / Sample # / Cylinder #: PRM / C2305301.04 / APE1516820

SRM Concentration / Uncertainty: 50.20 ppm / ±0.20 ppm

SRM Expiration Date: 02/22/2026

Second Analysis Data:

Second Analysis Data:				Date	05/31/2024		
Z:	0	R:	49.6	C:	24.5	Conc:	24.5
R:	49.7	Z:	0	C:	24.6	Conc:	24.6
Z:	0	C:	24.6	R:	49.7	Conc:	24.6
UOM:	ppm		Mean Test Assay:	24.5 ppm			

2. Component:

Nitric oxide

Requested Concentration: 25 ppm
Certified Concentration: 24.6 ppm
Instrument Used: Thermo Electron 42i-LS S/N 1030645077
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 05/09/2024

First Analysis Data:				Date	05/21/2024		
Z:	0	R:	49.6	C:	24.5	Conc:	24.5
R:	49.6	Z:	0	C:	24.6	Conc:	24.6
Z:	0	C:	24.6	R:	49.5	Conc:	24.6
UOM:	ppm		Mean Test Assay:	24.6 ppm			

Analyzed By

Henry Koung

Certified By

Lissette Morales

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

Lot No. 70086129501
Cylinder No. CC3035
Part No. NI COS0MN7E-AS
Volume: 140 R3
Fill Date: 10/22/2021
Expiration Date: 11/16/2029



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles, CA USA 90058

UN1956 Compressed gas, n.o.s. (Nitrogen, Carbon monoxide)



Mixt. Concentration	EPA Protocol	Component	CAS
82.8 ppm		Carbon monoxide	630-08-0
54.5 ppm		Nitric oxide	10102-43-9
Balance		Nitrogen	7727-37-9

Warning



CONTAINS GAS UNDER PRESSURE; MAY EXPLODE IF HEATED. MAY DISPLACE OXYGEN AND CAUSE RAPID SUFFOCATION.

TLV:

Carbon monoxide 25 ppm
Nitric oxide 25 ppm

Do not handle until all safety precautions have been read and understood; Use and store only outdoors or in a well-ventilated place; Use a back flow preventive device in the piping; Use only with equipment rated for cylinder pressure; Do not open valve until connected to equipment prepared for use; Close valve after each use and when empty; Protect from sunlight when ambient temperature exceeds 52°C (125°F); IF INHALED: Remove person to fresh air and keep comfortable for breathing. Get medical advice/attention.

FIRST AID

IF INHALED: Remove to fresh air and keep at rest in a position comfortable for breathing. If not breathing, give artificial respiration. If breathing is difficult, trained personnel should give oxygen. Call a physician.
IF EYES ARE CONTACTED: Immediately flush eyes thoroughly with water for at least 15 minutes. Hold the eyelids open and away from the face. Immediately flush eyes thoroughly. Contact an ophthalmologist immediately.
IF ON SKIN: Remove contaminated clothing and shoes. Wash thoroughly with soap and water. Contact an ophthalmologist immediately to ensure that all surfaces are flushed thoroughly.



Making our world more productive

DocNumber: 531956



Linde Gas & Equipment Inc. 5700 S. Alameda Street Los Angeles CA 90058 Tel: 323-585-2154 Fax: 714-542-6689 PGVP ID: F22023

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

1065 PG SANTA MARIA CA HPB 916 W BETTERAVIA RD SANTA MARIA CA 93455-1123

Certificate Issuance Date: 01/17/2023

Linde Order Number: 72303369

Part Number: NI CO80MQ14E-A5

Customer PO Number: 80309977

Fill Date: 12/21/2022

Lot Number: 10085235102

Cylinder Style & Outlet: A5

CGA 350

Cylinder Pressure and Volume: 2000 psig 140 RB

Certified Concentration

Expiration Date:	01/13/2031	NIST Traceable
Cylinder Number:	CC283311	Expanded Uncertainty
79.7 ppm	Carbon monoxide	± 0.7 ppm
5.10 %	Oxygen	± 0.04 %
Balance	Nitrogen	

ProSpec EZ Cert



Certification Information:

Certification Date: 01/13/2023

Term: 96 Months

Expiration Date: 01/13/2031

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use the Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Certificate)

1. Component

Carbon monoxide

Requested Concentration: 80 ppm
Certified Concentration: 79.7 ppm
Instrument Used: Horiba VIA-510 S/N 576876015
Analytical Method: NDIR
Last Multipoint Calibration: 12/15/2022

First Analysis Data:		Date	
Z:	0	R:	100.1
R:	100.1	Z:	0
Z:	0	C:	79.8
C:	79.8	R:	100.4
R:	100.4	C:	79.7
C:	79.7	Conc:	79.7
UOM: ppm		Mean Test Assay: 79.7 ppm	

Reference Standard:

Type / Cylinder #: NTRM / CC105919

Concentration / Uncertainty: 100.1 ppm ± 0.8 ppm

Expiration Date: 07/09/2027

Traceable to: SRM # / Sample # / Cylinder #: NTRM / 190703 / CC8737

SRM Concentration / Uncertainty: 100.1 ppm / ± 0.8 ppm

SRM Expiration Date: 07/09/2027

Second Analysis Data:		Date	
Z:	0	R:	0
R:	0	Z:	0
Z:	0	C:	0
C:	0	R:	0
R:	0	C:	0
C:	0	Conc:	0
UOM: ppm		Mean Test Assay: ppm	

2. Component

Oxygen

Requested Concentration: 5 %
Certified Concentration: 5.10 %
Instrument Used: Siemens Oxymat 6E S/N 7M820211AA000CA1
Analytical Method: Paramagnetic
Last Multipoint Calibration: 12/15/2022

First Analysis Data:		Date	
Z:	0	R:	9.978
R:	9.988	Z:	0
Z:	0	C:	5.105
C:	5.105	R:	9.988
R:	9.988	C:	5.1
C:	5.1	Conc:	5.1
UOM: %		Mean Test Assay: 5.1 %	

Reference Standard:

Type / Cylinder #: GMIS / DT0018893

Concentration / Uncertainty: 9.978 % ± 0.024 %

Expiration Date: 12/20/2030

Traceable to: SRM # / Sample # / Cylinder #: SRM 2858a / 72-D-28 / CAL016862

SRM Concentration / Uncertainty: 9.918 % / ± 0.022 %

SRM Expiration Date: 02/03/2024

Second Analysis Data:		Date	
Z:	0	R:	0
R:	0	Z:	0
Z:	0	C:	0
C:	0	R:	0
R:	0	C:	0
C:	0	Conc:	0
UOM: %		Mean Test Assay: %	

Analyzed By

Courney Ziehl

Certified By

Amalia Real

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

IN CASE OF EMERGENCY: CALL 1-800-645-4633

SDS ID: P-18-0267

DO NOT REMOVE THIS LABEL

Lot No. 70086107192
Cylinder No. CC73183
Part No. NI CO170010E-AS
Volume: 140 ft³
Fill Date: 03/12/2021
Expiration Date: 03/19/2029



ProSpec
by Praxair



Praxair Distribution, Inc.
5700 S. Alameda Street
Los Angeles, CA USA 90058

UN1956

Compressed gas, n.o.s. (Nitrogen, Oxygen)



EPA Protocol		
Molar Concentration	Component	CAS
169.1 ppm	Carbon monoxide	630-08-0
10.03 %	Oxygen	7782-44-7
Balance	Nitrogen	7727-37-9

Warning



CONTAINS GAS UNDER PRESSURE; MAY EXPLODE IF HEATED. MAY DISPLACE OXYGEN AND CAUSE RAPID SUFFOCATION.

TLV:

Carbon monoxide 25 ppm

Protect from sunlight when ambient temperature exceeds 52°C (125°F); Use and store only outdoors or in a well-ventilated place.

FIRST AID

IF INHALED: Remove to fresh air and keep at rest in a position comfortable for breathing. If not breathing, give artificial respiration. If breathing is difficult, trained personnel should give oxygen. Call a physician.
IF IN EYES: Immediately flush eyes thoroughly with water for at least 15 minutes. Hold the eyelids open and away from the eyeballs to ensure that all surfaces are flushed thoroughly. Contact an ophthalmologist immediately.

Third Quarter Test Report

Cylinder Gas Audit

Test Date(s): September 26 and 27, 2023

CEMTEK Project No.: SN00170A

Prepared for:

Tajiguas Resource Recovery Project

Anaerobic Digesting Facility (ADF), Units A and B

Goleta, CA

Prepared by:

CEMTEK KVB-Enertec



Contents

1	Introduction	1
2	Monitor Information	2
3	Summary of Results	2
4	Cylinder Gas Audit Test Procedure	3
5	Worksheets and Supporting Documentation	5
	Table 1: Unit A CGA Test Results Summary	2
	Table 2: Unit B CGA Test Results Summary	3

**Quarter Audit Test Report
Tajiguas Anaerobic Digester Facility**

1 Introduction

This quarterly audit report outlines the procedures and results of the Cylinder Gas Audit (CGA) check performed on the monitors at this facility. All testing was done in accordance with 40 CFR 60, Appendix F Procedure 1.

Tajiguas Landfill is located at 14470 Calle Real in Goleta, California that is approximately 26 miles west of the City of Santa Barbara. The landfill began receiving refuse in 1967 to serve the City of Santa Barbara, City of Goleta, unincorporated areas of Montecito and Summerland, rural areas of southern Santa Barbara County, the Santa Ynez Valley and Cuyama Valley. It is located in a canyon known as Cañada de la Pila. Immediately south of the landfill site are U.S. Highway 101, which provides access to the site, Union Pacific Railroad tracks, and the Pacific Ocean. The southern portion of the site is within the California Coastal Zone. For District regulatory purposes, the facility location is in the Southern Zone of Santa Barbara County.

Municipal solid waste (MSW) is delivered to a tipping area inside the Material Recovery Facility (MRF) building at Tajiguas. The material is subsequently sorted into organics, recyclables, and residue in the materials sorting area. Recyclables collected in the materials sorting area are sold to the market while waste residue is landfilled. The sorted organics are placed in the anaerobic digesters to generate biogas in the Anaerobic Digester Facility (ADF). The biogas is treated and combusted in combined heat and power (CHP) internal combustion (IC) engines for power generation, or an enclosed flare located at the ADF. Following biogas generation, the digestate is processed into soil amendments and compost at the Compost Management Unit (CMU). The MRF, ADF, and CMU are designed and constructed by MSB and owned by Santa Barbara County Public Works Department (SBCPWD). The MRF is operated by MarBorg Industries.

The ADF and CMU are operated by Mustang and Bekon. The waste residue placed in the landfill generates LFG in the subsurface landfill through anaerobic biological decomposition. The LFG is collected onsite using a vapor extraction system and handled using a collection and transportation system. A leachate management system collects the groundwater found in the landfill subsurface. The LFG is scrubbed of moisture, particulates, and hydrogen sulfide. The landfill, LFG collection system, hydrogen sulfide scrubber system, and leachate management system are owned and operated by the SBCPWD and permitted separately under PT-70/Reeval 9788-R4.

Currently, treated LFG is combusted on onsite enclosed flare or IC engine that are respectively owned and operated by NEO Tajiguas LLC (NEOT) and MM Tajiguas Energy LLC (MMTE). The LFG treatment system, two LFG-fired CHP engines, and MRF enclosed flare subject to the ATC 14500-02 permit will replace the existing equipment.

Two of the processes involved at the stationary source are as follows:

Anaerobic Digestion Facility: The organic (food and green) waste from the MRF is placed into digesters. An anaerobic digestion process generates biogas. This biogas is sent to the ADF combustion equipment. After the anaerobic digestion process is complete, the residual organic waste is sent to the CMU.

Anaerobic Digestion Facility Combustion Equipment: Biogas from the ADF digesters is sent to two CHP engines to produce electricity to the grid and for onsite needs. Treated LFG is used as a supplemental fuel. If one of the engines is offline or if one of the ADF digesters is being purged, biogas is routed to the ADF enclosed flare.

**Quarter Audit Test Report
Tajiguas Anaerobic Digester Facility**

2 Monitor Information

The following table provides information on the monitors that were subject to this test program.

ADF Unit A

Analyzer	Manufacturer/Model	Range(s)	Serial Number
Stack NO _x /O ₂	TAPI T200M	NO _x : 0-30/0-100 ppm O ₂ : 0-25%	1301
CO	TAPI T300M	0-150/0-300 ppm	668

ADF Unit B

Analyzer	Manufacturer/Model	Range(s)	Serial Number
Stack NO _x /O ₂	TAPI T200M	NO _x : 0-30/0-100 ppm O ₂ : 0-25%	1302
CO	TAPI T300M	0-150/0-300 ppm	669

3 Summary of Results

The results for the Cylinder Gas Audit (CGA) checks performed on the facility monitors are summarized in the following results table.

Table 1: Unit A CGA Test Results Summary

Analyzer	Results	Criteria	Status	Test Date
NO_x Low range	Low = -3.44% Mid = -5.10%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	9/26/23
NO_x High range	Low = -0.78% Mid = -2.39%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	9/27/23
CO Low range	Low = 0.70% Mid = 0.58%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	9/27/23
CO High range	Low = 2.78% Mid = 2.47%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	9/26/23
O₂	Low = 1.66% Mid = -0.56%	≤15% (40 CFR 60, Appendix F)	Pass	9/26/23

**Quarter Audit Test Report
Tajiguas Anaerobic Digester Facility**

Table 2: Unit B CGA Test Results Summary

Analyzer	Results	Criteria	Status	Test Date
NO_x Low range	Low = -8.71% Mid = -6.26%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	9/26/23
NO_x High range	Low = -4.60% Mid = -3.84%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	9/27/23
CO Low range	Low = -2.21% Mid = 0.70%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	9/27/23
CO High range	Low = 6.18% Mid = 5.95%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	9/26/23
O₂	Low = 1.73% Mid = 0.47%	≤15% (40 CFR 60, Appendix F)	Pass	9/26/23

4 Cylinder Gas Audit Test Procedure

The Cylinder Gas Audit (CGA) is performed for each pollutant concentration monitor at least once during each unit operating quarter based on the requirements of 40 CFR 60, Appendix F. CGAs are conducted in three consecutive quarters. Separate calibration gas cylinders are used for each concentration during the audit.

1. All audit gas cylinders are connected to the proper transport lines. EPA Protocol certified gases are used. Cylinders are checked to ensure that each audit gas has at least 200 psi.
2. The analyzers are challenged with an audit gas of known concentration at two points within the following concentration ranges (40 CFR 60, Appendix F):

Audit Point	Pollutant Monitors % of span	O₂ % by volume
Low level	20-30% of span	4-6% by volume
Mid Level	50-60% of span	8-12% by volume

3. The analyzers are challenged three times at each audit point. Calibration gas injections are done alternately between the two audit values. The average of the three responses for each audit point is used in determining accuracy. The monitor is challenged at each audit point for a sufficient time to assure that any absorption-desorption phenomena at the CEMS sample transport surfaces have stabilized. The injection time also takes into account the response time of the analyzers and sample system.

**Quarter Audit Test Report
Tajiguas Anaerobic Digester Facility**

4. Each monitor is operated in its normal sampling mode, that is, the audit gas passes through all filters, scrubbers, conditioners, and other monitor components used during normal sampling, and through as much of the sampling probe as is practical.
5. The difference between the actual concentration of the audit gas and the concentration indicated by the monitor will determine the accuracy of the CEMS.

The accuracy values for each concentration should not exceed 15% of reference value as the primary pass/fail criteria. As of May 30, 2023, the EPA has implemented an alternate pass/fail for pollutant analyzers using a tiered approach based on analyzer range as follows (reference 40 CFR 60, Appendix F, Procedure 1, section 5.2.3):

<i>Analyzer range</i>	<i>Alternate criteria, ppm difference</i>
>50 ppm	±5 ppm
≤50 ppm but >20 ppm	±3 ppm
≤20 ppm	±2 ppm

Cylinder Gas Audit Accuracy 40 CFR 60, Appendix F, Section 6.3	
$A = \frac{C_m - C_a}{C_a} \times 100$	<p>A = Percent accuracy of the CEM</p> <p>C_m = The average monitor response to the specific audit gas (high or low) in units of concentration</p> <p>C_a = Certified value of audit gas (value according to EPA Protocol certification) in units of concentration</p>

5 Worksheets and Supporting Documentation

The attached pages contain worksheets and supporting documentation for the CGA checks.

**Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA**

Project# SN00170A

Cylinder Gas Audit - NOx Low Range

For quarter ending: **09/30/23**

Manufacturer: TAPI
Model: T200M
Serial Number: 1301
Analyzer Range: 30
Test Date: 09/26/23

Reference Gas Value (C)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	8.04	26.80	OK	SA19336	08/29/25 OK
Mid	17.2	57.33	OK	CC499039	06/23/25 OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	14:47	8.49	14:51	16.58
2	14:56	7.50	15:01	16.23
3	15:06	7.30	15:12	16.16
Average Response (Cm)		7.76		16.32
Difference (Cm-Ca)		-0.28		-0.88

Status (for alt. criteria of +/- 3 ppm difference) range >20 but ≤ 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100
Status (for primary criteria of 15%)

Cylinder Gas Audit - NOx High Range

Analyzer Range: 100
Test Date: 09/27/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	25.8	25.80	OK	CC324929	04/16/24 OK
Mid	55.5	55.50	OK	DT0036914	03/29/29 OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	08:19	26.38	08:23	54.20
2	08:30	25.21	08:33	54.15
3	08:38	25.21	08:43	54.17
Average Response (Cm)		25.60		54.17
Difference (Cm-Ca)		-0.20		-1.33

Status (for alt. criteria of +/- 5 ppm difference) range > than 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100
Status (for primary criteria of 15%)

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:

>50 ppm: +/- 5 ppm difference

>20 ppm and ≤ 50 ppm: +/- 3 ppm difference

<= 20 ppm: +/- 2 ppm difference

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA

Project# SN00170A

Cylinder Gas Audit - CO Low Range

For quarter ending: **09/30/23**

Manufacturer: TAPI
 Model: T300M
 Serial Number: 668
 Analyzer Range: 150
 Test Date: 09/27/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	40.3	26.87	OK	CC324929	04/16/24	OK
Mid	80.6	53.73	OK	DT0036914	03/29/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	08:20	40.71	08:23	81.07
2	08:28	40.52	08:33	81.07
3	08:39	40.52	08:43	81.07
Average Response (Cm)		40.58		81.07
Difference (Cm-Ca)		0.28		0.47

Status (for alt. criteria of +/-5 ppm difference) range > than 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100
 Status (for primary criteria of 15%)

Cylinder Gas Audit - CO High Range

Analyzer Range: 300
 Test Date: 09/26/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	80.4	26.80	OK	EB0012199	09/16/30	OK
Mid	169.1	56.37	OK	CC73183	03/19/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	13:57	82.8	14:03	173.3
2	14:07	82.4	14:12	173.3
3	14:16	82.7	14:21	173.3
Average Response (Cm)		82.63		173.28
Difference (Cm-Ca)		2.23		4.18

Status (for alt. criteria of +/-5 ppm difference) range > than 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100
 Status (for primary criteria of 15%)

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:
 >50 ppm: +/- 5 ppm difference
 >20 ppm and ≤ 50 ppm: +/- 3 ppm difference
 ≤ 20 ppm: +/- 2 ppm difference

**Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA**

Project# SN00170A

Cylinder Gas Audit - O2

For quarter ending: **09/30/23**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1301
 Analyzer Range: 25
 Test Date: 09/26/23

Reference Gas Value (Ca)	Status	Bottle #	Exp. Date	Status	
Low	5.02	OK	EB0012199	09/16/30	OK
Mid	10.03	OK	CC73183	03/19/29	OK

Cal gas values must be between 4-6% by volume for low and 8-12% by volume for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	13:56	5.10	14:02	10.08
2	14:07	5.10	14:11	10.09
3	14:16	5.11	14:21	10.09
Average Response (Cm)		5.10		10.09
Difference (Cm-Ca)		0.08		0.06
Accuracy %, ((Cm-Ca)/Ca) * 100		1.66		0.56
Status (for primary criteria of 15%)		PASS		PASS

Notes:

Pass/Fail Criteria: +/- 15% of reference value (no alternate)
 (40 CFR 60, Appendix F)

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit B
Goleta, CA

Project# SN00170A

Cylinder Gas Audit - NOx Low Range

For quarter ending: **09/30/23**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1302
 Analyzer Range: 30
 Test Date: 09/26/23

Reference Gas Value (C)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	8.04	26.80	OK	SA19336	08/29/25	OK
Mid	17.2	57.33	OK	CC499039	06/23/25	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	14:47	7.44	14:52	16.18
2	14:57	7.34	15:02	16.12
3	15:06	7.24	15:11	16.07
Average Response (Cm)		7.34		16.12
Difference (Cm-Ca)		-0.70		-1.08

Status (for alt. criteria of +/- 3 ppm difference) PASS PASS range >20 but ≤ 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100 -8.71 -6.26
 Status (for primary criteria of 15%) PASS PASS

Cylinder Gas Audit - NOx High Range

Analyzer Range: 100
 Test Date: 09/27/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	25.8	25.80	OK	CC324929	04/16/24	OK
Mid	55.5	55.50	OK	DT0036914	03/29/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	08:19	24.68	08:24	52.99
2	08:28	24.53	08:33	53.45
3	08:40	24.63	08:43	53.66
Average Response (Cm)		24.61		53.37
Difference (Cm-Ca)		-1.19		-2.13

Status (for alt. criteria of +/- 5 ppm difference) PASS PASS range > than 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100 -4.60 -3.84
 Status (for primary criteria of 15%) PASS PASS

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:

>50 ppm: +/- 5 ppm difference

>20 ppm and ≤ 50 ppm: +/- 3 ppm difference

<= 20 ppm: +/- 2 ppm difference

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit B
Goleta, CA

Project# SN00170A

Cylinder Gas Audit - CO Low Range

For quarter ending: **09/30/23**

Manufacturer: TAPI
 Model: T300M
 Serial Number: 669
 Analyzer Range: 150
 Test Date: 09/27/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	40.3	26.87	OK	CC324929	04/16/24	OK
Mid	80.6	53.73	OK	DT0036914	03/29/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	08:19	39.43	08:24	80.82
2	08:29	39.34	08:35	81.02
3	08:39	39.46	08:44	81.66
Average Response (Cm)		39.41		81.17
Difference (Cm-Ca)		-0.89		0.57

Status (for alt. criteria of +/-5 ppm difference) PASS PASS range > than 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100 -2.21 0.70
 Status (for primary criteria of 15%) PASS PASS

Cylinder Gas Audit - CO High Range

Analyzer Range: 300
 Test Date: 09/26/23

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	80.4	26.80	OK	EB0012199	09/16/30	OK
Mid	169.1	56.37	OK	CC73183	03/19/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	13:57	84.5	14:03	178.5
2	14:07	85.5	14:13	179.3
3	14:17	86.1	14:21	179.7
Average Response (Cm)		85.37		179.17
Difference (Cm-Ca)		4.97		10.07

Status (for alt. criteria of +/-5 ppm difference) PASS FAIL range > than 50 ppm

Accuracy %, ((Cm-Ca)/Ca) * 100 6.18 5.95
 Status (for primary criteria of 15%) PASS PASS

Note: passed by primary criteria

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:
 >50 ppm: +/- 5 ppm difference
 >20 ppm and ≤ 50 ppm: +/- 3 ppm difference
 ≤ 20 ppm: +/- 2 ppm difference

**Tajiguas Landfill
 Anaerobic Digesting Facility (ADF), Unit B
 Goleta, CA**

Project# SN00170A

Cylinder Gas Audit - O2

For quarter ending: **09/30/23**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1302
 Analyzer Range: 25
 Test Date: 09/26/23

Reference Gas Value (Ca)	Status	Bottle #	Exp. Date	Status	
Low	5.02	OK	EB0012199	09/16/30	OK
Mid	10.03	OK	CC73183	03/19/29	OK

Cal gas values must be between 4-6% by volume for low and 8-12% by volume for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	13:57	5.11	14:02	10.08
2	14:07	5.11	14:11	10.07
3	14:17	5.10	14:21	10.08
Average Response (Cm)		5.11		10.08
Difference (Cm-Ca)		0.09		0.05
Accuracy %, ((Cm-Ca)/Ca) * 100		1.73		0.47
Status (for primary criteria of 15%)		PASS		PASS

Notes:

Pass/Fail Criteria: +/- 15% of reference value (no alternate)
 (40 CFR 60, Appendix F)

Average Values Report
 Generated: 9/26/2023 15:45

Company: ~~Cemtek KVB-Enertec~~ **Mustang Renewable Power Ventures**
 Plant: **Tajiguas Landfill**
 City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
 Source: ADF1, ADF2

Period Start: 9/26/2023 14:44
 Period End: 9/26/2023 15:15
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

Period Start:	Average	Average	Average
	A1_NOxLo	A2_NOxLo	A1_CO
	ppm	ppm	ppm
09/26/2023 14:44	N/A	31.10	149.51
09/26/2023 14:45	13.96	11.16	11.46
09/26/2023 14:46	9.06	7.48	0.65
09/26/2023 14:47	8.49	7.44	0.46
09/26/2023 14:48	8.31	7.42	0.29
09/26/2023 14:49	10.07	9.37	0.16
09/26/2023 14:50	16.56	16.13	0.04
09/26/2023 14:51	16.58	16.18	0.03
09/26/2023 14:52	16.55	16.18	0.10
09/26/2023 14:53	16.50	16.19	0.04
09/26/2023 14:54	14.22	16.17	-0.02
09/26/2023 14:55	7.52	8.12	0.06
09/26/2023 14:56	7.50	7.32	0.06
09/26/2023 14:57	7.48	7.34	0.06
09/26/2023 14:58	7.42	7.33	0.08
09/26/2023 14:59	11.78	8.04	0.11
09/26/2023 15:00	16.26	15.37	0.04
09/26/2023 15:01	16.23	16.11	0.03
09/26/2023 15:02	16.24	16.12	0.01
09/26/2023 15:03	15.51	16.10	0.00
09/26/2023 15:04	8.10	8.28	0.02
09/26/2023 15:05	7.32	7.24	0.02
09/26/2023 15:06	7.30	7.24	0.06
09/26/2023 15:07	7.29	7.25	0.02
09/26/2023 15:08	7.28	7.23	0.01
09/26/2023 15:09	15.35	10.91	0.03
09/26/2023 15:10	16.14	16.07	0.00
09/26/2023 15:11	16.16	16.07	0.07
09/26/2023 15:12	16.16	16.06	-0.02
09/26/2023 15:13	16.16	16.08	61.66
09/26/2023 15:14	N/A	16.11	N/A
09/26/2023 15:15	N/A	7.05	N/A
Final Average*	12.19	12.26	7.50
Maximum*	16.58	31.10	149.51
	09/26/2023	09/26/2023	09/26/2023
	14:51	14:44	14:44
Minimum*	7.28	7.05	-0.02
	09/26/2023	09/26/2023	09/26/2023
	15:08	15:15	15:12

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2023 08:55

Company: ~~Cemtek KVB-Enertec~~ **Mustang Renewable Power Ventures**
Plant: **Tajiguas Landfill**
City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
Source: ADF1, ADF2

Period Start: 9/27/2023 08:16
Period End: 9/27/2023 08:48
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average	Average	Average	Average
	A1_COLo	A1_NOxHi	A2_COLo	A2_NOxHi
	ppm	ppm	ppm	ppm
09/27/2023 08:16	81.49	39.99	118.86	54.56
09/27/2023 08:17	46.07	30.03	48.26	27.82
09/27/2023 08:18	40.97	26.93	39.43	24.79
09/27/2023 08:19	40.79	26.38	39.43	24.68
09/27/2023 08:20	40.71	26.02	39.60	24.55
09/27/2023 08:21	63.88	41.70	54.72	31.52
09/27/2023 08:22	80.88	54.16	80.13	52.93
09/27/2023 08:23	81.07	54.20	80.77	52.99
09/27/2023 08:24	81.13	54.13	80.82	52.99
09/27/2023 08:25	80.77	54.06	80.94	53.10
09/27/2023 08:26	49.17	32.70	60.22	41.31
09/27/2023 08:27	40.56	25.30	40.05	24.52
09/27/2023 08:28	40.52	25.21	39.49	24.53
09/27/2023 08:29	40.47	25.23	39.34	24.52
09/27/2023 08:30	41.13	25.21	39.31	24.54
09/27/2023 08:31	75.96	51.52	68.47	45.84
09/27/2023 08:32	81.00	54.15	80.46	53.46
09/27/2023 08:33	81.07	54.15	80.89	53.45
09/27/2023 08:34	81.05	54.19	81.03	53.49
09/27/2023 08:35	75.77	51.86	81.02	53.52
09/27/2023 08:36	42.22	27.71	61.27	39.26
09/27/2023 08:37	40.60	25.26	39.72	24.73
09/27/2023 08:38	40.52	25.21	39.28	24.66
09/27/2023 08:39	40.52	25.15	39.46	24.62
09/27/2023 08:40	44.62	25.11	39.86	24.63
09/27/2023 08:41	78.84	51.65	74.68	51.07
09/27/2023 08:42	81.10	54.19	81.50	53.65
09/27/2023 08:43	81.07	54.17	81.61	53.66
09/27/2023 08:44	81.02	54.24	81.66	53.68
09/27/2023 08:45	81.06	54.18	88.89	53.69
09/27/2023 08:46	N/A	N/A	139.21	43.17
09/27/2023 08:47	N/A	N/A	140.56	44.79
09/27/2023 08:48	N/A	N/A	129.40	38.77
Final Average*	61.87	40.13	70.01	40.29
Maximum*	81.49	54.24	140.56	54.56
	09/27/2023	09/27/2023	09/27/2023	09/27/2023
	8:16	8:44	8:47	8:16
Minimum*	40.47	25.11	39.28	24.52
	09/27/2023	09/27/2023	09/27/2023	09/27/2023
	8:29	8:40	8:38	8:29

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/26/2023 14:25

Company: ~~Cemtek KVB-Enertec~~ **Mustang Renewable Power Ventures**
Plant: **Tajiguas Landfill**
City/St: ~~Santa Ana, CA 92707~~ **Goleta, CA**
Source: ADF1, ADF2

Period Start: 9/26/2023 13:54
Period End: 9/26/2023 14:23
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average A1_O2 %	Average A1_CO ppm	Average A1_COHi ppm	Average A2_CO ppm	Average A2_COHi ppm	Average A2_O2 %
09/26/2023 13:54	5.09	83.66	84.7	132.43	133.7	11.71
09/26/2023 13:55	5.10	81.89	83.0	88.20	91.1	5.12
09/26/2023 13:56	5.10	81.81	82.9	81.77	84.5	5.11
09/26/2023 13:57	5.11	81.74	82.8	81.66	84.5	5.11
09/26/2023 13:58	5.10	81.55	82.6	81.60	84.4	5.11
09/26/2023 13:59	5.09	81.59	82.6	81.06	83.8	5.10
09/26/2023 14:00	8.04	122.39	123.2	112.46	114.5	8.26
09/26/2023 14:01	10.08	172.82	172.8	176.28	176.3	10.08
09/26/2023 14:02	10.08	173.30	173.3	179.07	179.1	10.08
09/26/2023 14:03	10.09	173.28	173.3	178.47	178.5	10.09
09/26/2023 14:04	8.68	156.13	153.9	170.72	170.7	9.17
09/26/2023 14:05	5.12	84.38	85.4	91.45	94.7	5.12
09/26/2023 14:06	5.10	81.52	82.6	82.15	85.0	5.11
09/26/2023 14:07	5.10	81.45	82.4	82.57	85.5	5.11
09/26/2023 14:08	5.09	81.45	82.5	82.84	85.7	5.11
09/26/2023 14:09	8.86	139.99	142.8	119.53	122.2	7.87
09/26/2023 14:10	10.09	173.07	173.0	176.65	176.6	10.07
09/26/2023 14:11	10.09	173.25	173.3	179.30	179.3	10.07
09/26/2023 14:12	10.09	173.27	173.3	179.75	179.8	10.08
09/26/2023 14:13	9.59	169.40	169.4	179.30	179.3	10.08
09/26/2023 14:14	5.22	91.04	91.9	120.58	120.6	6.01
09/26/2023 14:15	5.10	81.54	82.7	83.94	86.9	5.11
09/26/2023 14:16	5.11	81.56	82.7	83.25	86.1	5.10
09/26/2023 14:17	5.10	81.53	82.5	83.19	86.1	5.10
09/26/2023 14:18	7.82	123.00	123.8	98.57	101.2	6.86
09/26/2023 14:19	10.09	172.68	172.7	174.73	175.5	10.07
09/26/2023 14:20	10.09	173.28	173.3	179.57	179.6	10.09
09/26/2023 14:21	10.09	173.28	173.3	179.67	179.7	10.08
09/26/2023 14:22	10.09	173.40	173.4	179.30	179.3	10.09
09/26/2023 14:23	9.44	219.17	219.2	161.37	162.1	13.20
Final Average*	7.49	127.28	127.8	129.38	130.9	7.84
Maximum*	10.09	219.17	219.2	179.75	179.8	13.20
	09/26/2023 14:22	09/26/2023 14:23	09/26/2023 14:23	09/26/2023 14:12	09/26/2023 14:12	09/26/2023 14:23
Minimum*	5.09	81.45	82.4	81.06	83.8	5.10
	09/26/2023 14:08	09/26/2023 14:08	09/26/2023 14:07	09/26/2023 13:59	09/26/2023 13:59	09/26/2023 14:17

* Does not include Invalid Averaging Periods ("N/A")



Making our world
more productive

DocNumber: 491479



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22022

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

LGEPKG BAKERSFIELD CA HPS
3505 BUCK OWENS BLVD
BAKERSFIELD CA 93308-4919

Certificate Issuance Date: 08/29/2022

Linde Order Number: 72163095

Pari Number: NI NO8ME-AS

Customer PO Number: 80167623

Fill Date: 08/12/2022

Lot Number: 7008622405

Cylinder Style & Outlet: AS CGA 660

Cylinder Pressure and Volume: 2000 psig 140 ft3

Certified Concentration

Expiration Date:	08/29/2025	NIST Traceable
Cylinder Number:	SA19336	Expanded Uncertainty
8.04 ppm	Nitric oxide	± 0.04 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only:

NOx 8.09 ppm

Certification Information:

Certification Date: 08/29/2022

Term: 36 Months

Expiration Date: 08/29/2025

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Nitric oxide
Requested Concentration: 8 ppm
Certified Concentration: 8.04 ppm
Instrument Used: Thermo Electron 42i-LS S/N 1030645077
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 08/11/2022

Reference Standard: Type / Cylinder #: GMIS / DT0038022
Concentration / Uncertainty: 9.42 ppm ±0.05 ppm
Expiration Date: 04/08/2025
Traceable to: SRM # / Sample # / Cylinder #: PRM / C1837210.02 / APEX1324301
SRM Concentration / Uncertainty: 10.00 ppm / ±0.05 ppm
SRM Expiration Date: 04/17/2022

First Analysis Data:				Date
Z:	0	R:	9.42	08/22/2022
C:	8.03	Conc:	8.03	
R:	9.42	Z:	0	
C:	8.05	Conc:	8.05	
Z:	0	C:	8.04	
R:	9.41	Conc:	8.04	
Mean Test Assay:				8.04 ppm
UOM: ppm				

Second Analysis Data:				Date
Z:	0	R:	9.42	08/29/2022
C:	8.05	Conc:	8.04	
R:	9.44	Z:	0	
C:	8.06	Conc:	8.05	
Z:	0	C:	8.04	
R:	9.43	Conc:	8.03	
Mean Test Assay:				8.04 ppm
UOM: ppm				

Analyzed By

Lissette Morales

Certified By

Henry Koung

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.



DocNumber: 477019



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22022

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

LGEPKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA93455-1123
Customer Reference: MUSTANG

Certificate Issuance Date: 06/23/2022
Linde Order Number: 9903972087130
Part Number: NI NO17ME-AS
Customer PO Number: 80090728

Fill Date: 06/10/2022
Lot Number: 70086216106
Cylinder Style & Outlet: AS CGA 660
Cylinder Pressure and Volume: 2000 psig 140.63

Certified Concentration

Expiration Date:	06/23/2025	NIST Traceable
Cylinder Number:	CC499039	Expanded Uncertainty
17.2 ppm	Nitric oxide	± 0.2 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only: NOx 17.2 ppm

Certification Information: Certification Date: 06/23/2022 Term: 36 Months Expiration Date: 06/23/2025

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-400/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Nitric oxide
 Requested Concentration: 17 ppm
 Certified Concentration: 17.2 ppm
 Instrument Used: Thermo Electron 42-LS S/N 1030645077
 Analytical Method: Chemiluminescence
 Last Multipoint Calibration: 05/27/2022

Reference Standard: Type / Cylinder #: GMIS / DT0037153
 Concentration / Uncertainty: 19.97 ppm ± 0.20 ppm
 Expiration Date: 04/12/2025
 Traceable to: SRM # / Sample # / Cylinder #: 2629a / 50-G-17 / FF31691
 SRM Concentration / Uncertainty: 18.99 ppm / ± 0.19 ppm
 SRM Expiration Date: 10/21/2023

First Analysis Data:				Date
Z:	0	R:	20	C: 17.16 Conc: 17.1
R:	20	Z:	0	C: 17.19 Conc: 17.2
Z:	0	C:	17.18	R: 20 Conc: 17.2
UOM:	ppm	Mean Test Assay:		17.2 ppm

Second Analysis Data:				Date
Z:	0	R:	20	C: 17.18 Conc: 17.2
R:	19.9	Z:	0	C: 17.18 Conc: 17.2
Z:	0	C:	17.2	R: 20 Conc: 17.2
UOM:	ppm	Mean Test Assay:		17.2 ppm

Analyzed By

Henry Koung

Certified By

Elisette Morales

SU9 CGAS

DocNumber: 407533



Praxair Distribution, Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22021

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PRAXAIR PKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA 93455-1123

Certificate Issuance Date: 04/16/2021
Praxair Order Number: 71635190
Part Number: NI CO40MN20E-AS
Customer PO Number: 79632556

Fill Date: 04/01/2021
Lot Number: 70086109106
Cylinder Style & Outlet: AS CGA 660
Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration

Expiration Date:	04/16/2024	NIST Traceable
Cylinder Number:	CC324929	Expanded Uncertainty
40.3 ppm	Carbon monoxide	± 0.2 ppm
25.8 ppm	Nitric oxide	± 0.1 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only:

NOx 25.9 ppm

Certification Information:

Certification Date: 04/16/2021

Term: 36 Months

Expiration Date: 04/16/2024

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use This Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon monoxide

Requested Concentration: 40 ppm
Certified Concentration: 40.3 ppm
Instrument Used: Horiba VIA-510 S/N 4362790042
Analytical Method: NDIR
Last Multipoint Calibration: 03/26/2021

First Analysis Data:		Date: 04/09/2021	
Z: 0	R: 98.1	C: 40.2	Conc: 40.2
R: 98.2	Z: 0	C: 40.4	Conc: 40.4
Z: 0	C: 40.3	R: 98.2	Conc: 40.3
UOM: ppm		Mean Test Assay: 40.3 ppm	

Reference Standard: Type / Cylinder #: GMIS / DT0019705
Concentration / Uncertainty: 98.1 ppm ± 0.4 ppm
Expiration Date: 01/23/2028
Traceable to: SRM # / Sample # / Cylinder #: SRM 1679c / 3-4-45 / FF26593
SRM Concentration (enter with units) / 98.40 ppm / ± 0.40 ppm
SRM Expiration Date: 01/26/2020

Second Analysis Data:		Date	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: ppm		Mean Test Assay: ppm	

2. Component: Nitric oxide

Requested Concentration: 25 ppm
Certified Concentration: 25.8 ppm
Instrument Used: Thermo Electron 42-LS S/N 1030645077
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 03/25/2021

First Analysis Data:		Date: 04/09/2021	
Z: 0	R: 50	C: 25.7	Conc: 25.7
R: 50	Z: 0	C: 25.8	Conc: 25.8
Z: 0	C: 25.8	R: 49.9	Conc: 25.8
UOM: ppm		Mean Test Assay: 25.8 ppm	

Reference Standard: Type / Cylinder #: PRM / APEX1324323
Concentration / Uncertainty: 50.04 ppm ± 0.20 ppm
Expiration Date: 12/09/2022
Traceable to: SRM # / Sample # / Cylinder #: PRM / C1765710.01 / APEX1324323
SRM Concentration (enter with units) / 50.04 ppm / ± 0.20 ppm
SRM Expiration Date: 12/09/2022

Second Analysis Data:		Date: 04/16/2021	
Z: 0	R: 50	C: 25.8	Conc: 25.9
R: 49.8	Z: 0	C: 25.7	Conc: 25.8
Z: 0	C: 25.7	R: 49.8	Conc: 25.8
UOM: ppm		Mean Test Assay: 25.8 ppm	

Analyzed By

Henry Koung

Certified By

Lesann Flores



CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PRAXAIR PKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA 93455-1123

Certificate Issuance Date: 03/29/2021

Praxair Order Number: 71635196

Part Number: NI CO80M7E-AS

Customer PO Number: 79632562

Fill Date: 03/17/2021

Lot Number: 70066107611

Cylinder Style & Outlet: AS

Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration

Expiration Date:	03/29/2029	NIST Traceable
Cylinder Number:	DT0036914	Expanded Uncertainty
80.6 ppm	Carbon monoxide	± 0.3 ppm
55.5 ppm	Nitric oxide	± 0.3 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only:

NOx 55.8 ppm

Certification Information:

Certification Date: 03/29/2021

Term: 96 Months

Expiration Date: 03/29/2029

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Certificate)

1. Component:

Carbon monoxide

Requested Concentration: 80 ppm
Certified Concentration: 80.6 ppm
Instrument Used: Horba VIA-510 S/N 43627990042
Analytical Method: NDIR
Last Multipoint Calibration: 02/26/2021

First Analysis Data:				Date			
Z:	0	R:	98.1	C:	80.6	Conc:	80.6
R:	98	Z:	0	C:	80.5	Conc:	80.5
Z:	0	C:	80.7	R:	98.2	Conc:	80.7
UOM:	ppm		Mean Test Assay:	80.6		ppm	

Reference Standard:

Type / Cylinder #: GMIS / DT0019705

Concentration / Uncertainty: 98.1 ppm ± 0.4 ppm

Expiration Date: 01/23/2028

Traceable to: SRM # / Sample # / Cylinder #: SRM 1679c / 3-4-45 / FF28593

SRM Concentration (enter with units) / 98.40 ppm / ± 0.40 ppm

SRM Expiration Date: 01/26/2020

Second Analysis Data:				Date			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM:	ppm		Mean Test Assay:			ppm	

2. Component:

Nitric oxide

Requested Concentration: 55 ppm
Certified Concentration: 55.5 ppm
Instrument Used: Thermo Electron 42i-L5 S/N 1030645077
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 03/15/2021

First Analysis Data:				Date			
Z:	0	R:	49	C:	55.4	Conc:	55.4
R:	49	Z:	0	C:	55.5	Conc:	55.5
Z:	0	C:	55.5	R:	48.9	Conc:	55.5
UOM:	ppm		Mean Test Assay:	55.5		ppm	

Reference Standard:

Type / Cylinder #: GMIS / DT0037649

Concentration / Uncertainty: 49.01 ppm ± 0.21 ppm

Expiration Date: 01/07/2029

Traceable to: SRM # / Sample # / Cylinder #: PRM / C1765710 01 / APEX1324323

SRM Concentration (enter with units) / 50.04 PPM / ± 0.20 PPM

SRM Expiration Date: 12/05/2022

Second Analysis Data:				Date			
Z:	0	R:	49	C:	55.4	Conc:	55.6
R:	48.8	Z:	0	C:	55.4	Conc:	55.6
Z:	0	C:	55.1	R:	48.8	Conc:	55.3
UOM:	ppm		Mean Test Assay:	55.5		ppm	

Analyzed By

Henry Koung

Certified By

Leeanna Flores



Making our world more productive

DocNumber: 503350



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-8689
PGVP ID: F22022

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

1 GEPKG SANTA MARIA CA HPS
918 W BETTERAVIA RD
SANTA MARIA CA93455-1123

Certificate Issuance Date: 09/16/2022
Linde Order Number: 72180572
Part Number: NI CO80MO14E-AS
Customer PO Number: 80185295

Fill Date: 09/06/2022
Lot Number: 70086224903
Cylinder Style & Outlet: AS CGA 350
Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration

Expiration Date:	09/16/2030	NIST Traceable
Cylinder Number:	EB0012199	Expanded Uncertainty
80.4 ppm	Carbon monoxide	± 0.7 ppm
5.02 %	Oxygen	± 0.02 %
Balance	Nitrogen	

ProSpec EZ Cert



Certification Information:

Certification Date: 09/16/2022

Term: 96 Months

Expiration Date: 09/16/2030

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon monoxide

Requested Concentration: 80 ppm
Certified Concentration: 80.4 ppm
Instrument Used: Horiba VIA-510 S/N 576876015
Analytical Method: NDIR
Last Multipoint Calibration: 08/30/2022

First Analysis Data:				Date			
Z:	0	R:	100.1	C:	80.5	Conc:	80.4
R:	100.2	Z:	0	C:	80.5	Conc:	80.4
Z:	0	C:	80.5	R:	100.2	Conc:	80.4
UOM:	ppm		Mean Test Assay:		80.4		ppm

Reference Standard: Type / Cylinder #: NTRM / CC105919
Concentration / Uncertainty: 100.1 ppm ±0.8 ppm
Expiration Date: 07/09/2027
Traceable to: SRM # / Sample # / Cylinder #: NTRM / 190703 / CC8737
SRM Concentration / Uncertainty: 100.1 ppm / ±0.8 ppm
SRM Expiration Date: 07/09/2027

Second Analysis Data:				Date			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM:	ppm		Mean Test Assay:				ppm

2. Component: Oxygen

Requested Concentration: 5 %
Certified Concentration: 5.02 %
Instrument Used: Siemens Oxymat 6E S/N 7M820211AA000CA1
Analytical Method: Paramagnetic
Last Multipoint Calibration: 08/30/2022

First Analysis Data:				Date			
Z:	0	R:	4.97	C:	5.02	Conc:	5.02
R:	4.97	Z:	0	C:	5.02	Conc:	5.02
Z:	0	C:	5.02	R:	4.97	Conc:	5.02
UOM:	%		Mean Test Assay:		5.02		%

Reference Standard: Type / Cylinder #: GMIS / CC163512
Concentration / Uncertainty: 4.97 % ±0.02 %
Expiration Date: 07/17/2029
Traceable to: SRM # / Sample # / Cylinder #: SRM 2658a / 72-D-20 / CAL016862
SRM Concentration / Uncertainty: 9.918% / ±0.022%
SRM Expiration Date: 02/03/2024

Second Analysis Data:				Date			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM:	%		Mean Test Assay:				%

Analyzed By

Courtney Ziegler

Certified By

Lisotto Morales

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

DocNumber: 406153



Praxair Distribution, Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22021

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PRAXAIR PKG SANTA MARIA CA HPS
915 W BETTERAVIA RD
SANTA MARIA CA 93455-1123

Certificate Issuance Date: 03/22/2021
Praxair Order Number: 71635262
Part Number: NI CO170010E-AS
Customer PO Number: 79632626

Fill Date: 03/12/2021
Lot Number: 70066107102
Cylinder Style & Outlet: AS CGA 590
Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration

Expiration Date:	03/19/2029	NIST Traceable
Cylinder Number:	CC73183	Expanded Uncertainty
169.1 ppm	Carbon monoxide	± 0.8 ppm
10.03 %	Oxygen	± 0.04 %
Balance	Nitrogen	

ProSpec EZ Cert



Certification Information:

Certification Date: 03/19/2021

Term: 96 Months

Expiration Date: 03/19/2029

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-800/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component:

Carbon monoxide

Requested Concentration: 170 ppm
Certified Concentration: 169.1 ppm
Instrument Used: Horiba VIA-510 S/N 576876015
Analytical Method: NDIR
Last Multipoint Calibration: 03/01/2021

First Analysis Data:		Date	
Z:	R:	C:	Conc:
0	497.5	169.1	169.1
R:	497.6	Z:	0
		C:	169.2
Z:	0	R:	497.6
		C:	169.1
UOM: ppm		Mean Test Assay: 169.1 ppm	

Reference Standard:

Type / Cylinder #: GMIS / CC319383
Concentration / Uncertainty: 497.5 ppm ± 2.0 ppm
Expiration Date: 04/26/2025

Traceable to:

SRM # / Sample # / Cylinder #: SRM 1660b / 2-J-15 / CAL018072
SRM Concentration (enter with units): 490.4 ppm / ± 2.0 ppm
SRM Expiration Date: 09/29/2021

Second Analysis Data:		Date	
Z:	R:	C:	Conc:
0	0	0	0
R:	0	Z:	0
		C:	0
Z:	0	R:	0
		C:	0
UOM: ppm		Mean Test Assay: ppm	

2. Component:

Oxygen

Requested Concentration: 10 %
Certified Concentration: 10.03 %
Instrument Used: 7MB20211AA000CA1
Analytical Method: Paramagnetic
Last Multipoint Calibration: 03/18/2021

First Analysis Data:		Date	
Z:	R:	C:	Conc:
0	9.875	10.02	10.02
R:	9.875	Z:	0
		C:	10.03
Z:	0	R:	9.876
		C:	10.03
UOM: %		Mean Test Assay: 10.03 %	

Reference Standard:

Type / Cylinder #: NTRM / DT0010287
Concentration / Uncertainty: 9.875 % ± 0.040 %
Expiration Date: 11/18/2022

Traceable to:

SRM # / Sample # / Cylinder #: NTRM / 170701 / DT0010287
SRM Concentration (enter with units): 9.875% / ± 0.040%
SRM Expiration Date: 11/18/2022

Second Analysis Data:		Date	
Z:	R:	C:	Conc:
0	0	0	0
R:	0	Z:	0
		C:	0
Z:	0	R:	0
		C:	0
UOM: %		Mean Test Assay: %	

Analyzed By

Amelia Real

Certified By

Jose Vasquez

Continuous Emissions Monitoring System (CEMS)

Fourth Quarter Test Report

Cylinder Gas Audit

Test Date(s): November 26 and 27, 2024

CEMTEK Project No.: SN00192

Prepared for:

Tajiguas Landfill

Anaerobic Digesting Facility (ADF), Units A and B

Goleta, CA

Prepared by:

CEMTEK KVB-Enertec



3041 S. Orange Avenue, Santa Ana, CA 92707 • Phone: 714-437-7100 • Fax: 714-437-7177 • Toll Free: 888-400-0200
2849 Sterling Drive, Hatfield, PA 19440 • Phone: 215-996-9200 • Fax: 330-860-8982 • Tech Support Phone: 800-582-1670
Houston, TX Office • Phone: 281-729-8228

Contents

1	Introduction	1
2	Monitor Information	2
3	Summary of Results	2
4	Cylinder Gas Audit Test Procedure	3
5	Worksheets and Supporting Documentation	5
	Table 1: Unit A CGA Test Results Summary	2
	Table 2: Unit B CGA Test Results Summary	3

**Quarter Audit Test Report
Tajiguas Landfill**

1 Introduction

This quarterly audit report outlines the procedures and results of the Cylinder Gas Audit (CGA) check performed on the monitors at this facility. All testing was done in accordance with 40 CFR 60, Appendix F Procedure 1.

Tajiguas Landfill is located at 14470 Calle Real in Goleta, California that is approximately 26 miles west of the City of Santa Barbara. The landfill began receiving refuse in 1967 to serve the City of Santa Barbara, City of Goleta, unincorporated areas of Montecito and Summerland, rural areas of southern Santa Barbara County, the Santa Ynez Valley and Cuyama Valley. It is located in a canyon known as Cañada de la Pila. Immediately south of the landfill site are U.S. Highway 101, which provides access to the site, Union Pacific Railroad tracks, and the Pacific Ocean. The southern portion of the site is within the California Coastal Zone. For District regulatory purposes, the facility location is in the Southern Zone of Santa Barbara County.

Municipal solid waste (MSW) is delivered to a tipping area inside the Material Recovery Facility (MRF) building at Tajiguas. The material is subsequently sorted into organics, recyclables, and residue in the materials sorting area. Recyclables collected in the materials sorting area are sold to the market while waste residue is landfilled. The sorted organics are placed in the anaerobic digesters to generate biogas in the Anaerobic Digester Facility (ADF). The biogas is treated and combusted in combined heat and power (CHP) internal combustion (IC) engines for power generation, or an enclosed flare located at the ADF. Following biogas generation, the digestate is processed into soil amendments and compost at the Compost Management Unit (CMU). The MRF, ADF, and CMU are designed and constructed by MSB and owned by Santa Barbara County Public Works Department (SBCPWD).

The waste residue placed in the landfill generates LFG in the subsurface landfill through anaerobic biological decomposition. The LFG is collected onsite using a vapor extraction system and handled using a collection and transportation system. A leachate management system collects the groundwater found in the landfill subsurface. The LFG is scrubbed of moisture, particulates, and hydrogen sulfide. The landfill, LFG collection system, hydrogen sulfide scrubber system, and leachate management system are owned and operated by the SBCPWD and permitted separately under PT-70/Reeval 9788-R4.

Currently, treated LFG is combusted in an onsite enclosed flare or IC engine. The LFG treatment system, two LFG-fired CHP engines, and MRF enclosed flare subject to the ATC 14500-02 permit will replace the existing equipment.

Two of the processes involved at the stationary source are as follows:

Anaerobic Digestion Facility: The organic (food and green) waste from the MRF is placed into digesters. An anaerobic digestion process generates biogas. This biogas is sent to the ADF combustion equipment. After the anaerobic digestion process is complete, the residual organic waste is sent to the CMU.

Anaerobic Digestion Facility Combustion Equipment: Biogas from the ADF digesters is sent to two CHP engines to produce electricity to the grid and for onsite needs. Treated LFG is used as a supplemental fuel. If one of the engines is offline or if one of the ADF digesters is being purged, biogas is routed to the ADF enclosed flare.

**Quarter Audit Test Report
Tajiguas Landfill**

2 Monitor Information

The following table provides information on the monitors that were subject to this test program.

ADF Unit A

Analyzer	Manufacturer/Model	Range(s)	Serial Number
Stack NO _x /O ₂	TAPI T200M	NO _x : 0-30/0-100 ppm O ₂ : 0-25%	1301
CO	TAPI T300M	0-150/0-300 ppm	668

ADF Unit B

Analyzer	Manufacturer/Model	Range(s)	Serial Number
Stack NO _x /O ₂	TAPI T200M	NO _x : 0-30/0-100 ppm O ₂ : 0-25%	1302
CO	TAPI T300M	0-150/0-300 ppm	669

3 Summary of Results

The results for the Cylinder Gas Audit (CGA) checks performed on the facility monitors are summarized in the following results table.

Table 1: Unit A CGA Test Results Summary

Analyzer	Results	Criteria	Status	Test Date
NO_x Low range	Low = -4.85% Mid = -5.62%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	11/26/24
NO_x High range	Low = -2.28% Mid = -2.31%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	11/26/24
CO Low range	Low = -0.31% Mid = -0.56%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	11/26/24
CO High range	Low = 1.30% Mid = 1.20%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	11/26/24
O₂	Low = 2.03% Mid = 0.56%	≤15% (40 CFR 60, Appendix F)	Pass	11/26/24

**Quarter Audit Test Report
Tajiguas Landfill**

Table 2: Unit B CGA Test Results Summary

Analyzer	Results	Criteria	Status	Test Date
NO_x Low range	Low = -6.38% Mid = -5.33%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	11/27/24
NO_x High range	Low = 2.82% Mid = 1.41%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	11/27/24
CO Low range	Low = 2.81% Mid = 0.48%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	11/27/24
CO High range	Low = -0.08% Mid = 0.61%	≤15% or alternately based on a range based tiered difference (refer to section 4)	Pass	11/27/24
O₂	Low = 1.24% Mid = 0.70%	≤15% (40 CFR 60, Appendix F)	Pass	11/27/24

4 Cylinder Gas Audit Test Procedure

The Cylinder Gas Audit (CGA) is performed for each pollutant concentration monitor at least once during each unit operating quarter based on the requirements of 40 CFR 60, Appendix F. CGAs are conducted in three consecutive quarters. Separate calibration gas cylinders are used for each concentration during the audit.

1. All audit gas cylinders are connected to the proper transport lines. EPA Protocol certified gases are used. Cylinders are checked to ensure that each audit gas has at least 200 psi.
2. The analyzers are challenged with an audit gas of known concentration at two points within the following concentration ranges (40 CFR 60, Appendix F):

Audit Point	Pollutant Monitors % of span	O₂ % by volume
Low level	20-30% of span	4-6% by volume
Mid Level	50-60% of span	8-12% by volume

3. The analyzers are challenged three times at each audit point. Calibration gas injections are done alternately between the two audit values. The average of the three responses for each audit point is used in determining accuracy. The monitor is challenged at each audit point for a sufficient time to assure that any absorption-desorption phenomena at the CEMS sample transport surfaces have stabilized. The injection time also takes into account the response time of the analyzers and sample system.

**Quarter Audit Test Report
Tajiguas Landfill**

4. Each monitor is operated in its normal sampling mode, that is, the audit gas passes through all filters, scrubbers, conditioners, and other monitor components used during normal sampling, and through as much of the sampling probe as is practical.
5. The difference between the actual concentration of the audit gas and the concentration indicated by the monitor will determine the accuracy of the CEMS.

The accuracy values for each concentration should not exceed 15% of reference value as the primary pass/fail criteria. As of May 30, 2023, the EPA has implemented an alternate pass/fail for pollutant analyzers using a tiered approach based on analyzer range as follows (reference 40 CFR 60, Appendix F, Procedure 1, section 5.2.3):

<i>Analyzer range</i>	<i>Alternate criteria, ppm difference</i>
>50 ppm	±5 ppm
≤50 ppm but >20 ppm	±3 ppm
≤20 ppm	±2 ppm

Cylinder Gas Audit Accuracy 40 CFR 60, Appendix F, Section 6.3	
$A = \frac{C_m - C_a}{C_a} \times 100$	<p>A = Percent accuracy of the CEM</p> <p>C_m = The average monitor response to the specific audit gas (high or low) in units of concentration</p> <p>C_a = Certified value of audit gas (value according to EPA Protocol certification) in units of concentration</p>

5 Worksheets and Supporting Documentation

The attached pages contain worksheets and supporting documentation for the CGA checks.

**Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA**

Project# SN00170A

Cylinder Gas Audit - NOx Low Range

For quarter ending: **12/31/24**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1301
 Analyzer Range: 30
 Test Date: 11/26/24

Reference Gas Value (C)	% of Span	Status	Bottle #	Exp. Date	Status	
Low	8.04	26.80	OK	SA19336	08/29/25	OK
Mid	17.2	57.33	OK	CC499039	06/23/25	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	13:18	7.57	13:23	16.17
2	13:28	7.66	13:33	16.24
3	13:38	7.72	13:43	16.29
Average Response (Cm)		7.65		16.23
Difference (Cm-Ca)		-0.39		-0.97
Status (for alt. criteria of +/- 3 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		-4.85		-5.62
Status (for primary criteria of 15%)		PASS		PASS

range >20 but ≤ 50 ppm

Cylinder Gas Audit - NOx High Range

Analyzer Range: 100
 Test Date: 11/26/24

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Status	
Low	24.6	24.60	OK	CC748576	05/31/27	OK
Mid	54.5	54.50	OK	CC3035	11/16/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	13:53	23.91	13:58	53.20
2	14:04	24.09	14:09	53.20
3	14:13	24.12	14:19	53.32
Average Response (Cm)		24.04		53.24
Difference (Cm-Ca)		-0.56		-1.26
Status (for alt. criteria of +/- 5 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		-2.28		-2.31
Status (for primary criteria of 15%)		PASS		PASS

range > than 50 ppm

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:

>50 ppm: +/- 5 ppm difference

>20 ppm and ≤ 50 ppm: +/- 3 ppm difference

<= 20 ppm: +/- 2 ppm difference

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA

Project# SN00170A

Cylinder Gas Audit - CO Low Range

For quarter ending: **12/31/24**

Manufacturer: TAPI
 Model: T300M
 Serial Number: 668
 Analyzer Range: 150
 Test Date: 11/26/24

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	40.1	26.73	OK	CC748576	05/31/27	OK
Mid	82.8	55.20	OK	CC3035	11/16/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	13:53	39.91	13:59	82.34
2	14:03	40.04	14:09	82.37
3	14:14	39.98	14:18	82.29
Average Response (Cm)		39.98		82.33
Difference (Cm-Ca)		-0.12		-0.47
Status (for alt. criteria of +/- 5 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		-0.31		-0.56
Status (for primary criteria of 15%)		PASS		PASS

range > than 50 ppm

Cylinder Gas Audit - CO High Range

Analyzer Range: 300
 Test Date: 11/26/24

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	79.7	26.57	OK	CC283311	01/13/31	OK
Mid	169.1	56.37	OK	CC73183	03/19/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	12:34	80.7	12:39	171.2
2	12:43	80.8	12:47	171.2
3	12:54	80.7	12:58	171.0
Average Response (Cm)		80.73		171.13
Difference (Cm-Ca)		1.03		2.03
Status (for alt. criteria of +/- 5 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		1.30		1.20
Status (for primary criteria of 15%)		PASS		PASS

range > than 50 ppm

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:

>50 ppm: +/- 5 ppm difference

>20 ppm and ≤ 50 ppm: +/- 3 ppm difference

<= 20 ppm: +/- 2 ppm difference

**Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit A
Goleta, CA**

Project# SN00170A

Cylinder Gas Audit - O2

For quarter ending: **12/31/24**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1301
 Analyzer Range: 25
 Test Date: 11/26/24

Reference Gas Value (Ca)	Status	Bottle #	Exp. Date	Exp. Date	Status
Low	5.10	OK	CC283311	01/13/31	OK
Mid	10.03	OK	CC73183	03/19/29	OK

Cal gas values must be between 4-6% by volume for low and 8-12% by volume for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	12:32	5.21	12:38	10.08
2	12:43	5.20	12:47	10.09
3	12:54	5.20	12:58	10.09
Average Response (Cm)		5.20		10.09
Difference (Cm-Ca)		0.10		0.06
Accuracy %, ((Cm-Ca)/Ca) * 100		2.03		0.56
Status (for primary criteria of 15%)		PASS		PASS

Notes:

Pass/Fail Criteria: +/- 15% of reference value (no alternate)
 (40 CFR 60, Appendix F)

Average Values Report
Generated: 11/26/2024 14:35

Company: SB County Public Works
Plant: 14470 Calle Real
City/St: Goleta, CA 93101
Source: ADF1

Period Start: 11/26/2024 13:13
Period End: 11/26/2024 13:47
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average A1_NOxLo ppm
11/26/2024 13:13	-0.02
11/26/2024 13:14	-0.01
11/26/2024 13:15	1.84
11/26/2024 13:16	7.52
11/26/2024 13:17	7.58
11/26/2024 13:18	7.57
11/26/2024 13:19	7.59
11/26/2024 13:20	8.30
11/26/2024 13:21	15.41
11/26/2024 13:22	16.16
11/26/2024 13:23	16.17
11/26/2024 13:24	16.20
11/26/2024 13:25	14.80
11/26/2024 13:26	7.70
11/26/2024 13:27	7.67
11/26/2024 13:28	7.66
11/26/2024 13:29	7.66
11/26/2024 13:30	8.36
11/26/2024 13:31	16.19
11/26/2024 13:32	16.25
11/26/2024 13:33	16.24
11/26/2024 13:34	16.28
11/26/2024 13:35	14.31
11/26/2024 13:36	7.78
11/26/2024 13:37	7.72
11/26/2024 13:38	7.72
11/26/2024 13:39	7.71
11/26/2024 13:40	9.78
11/26/2024 13:41	16.24
11/26/2024 13:42	16.29
11/26/2024 13:43	16.29
11/26/2024 13:44	16.31
11/26/2024 13:45	12.40
11/26/2024 13:46	0.25
11/26/2024 13:47	0.13
Final Average*	10.17
Maximum*	16.31
	11/26/2024 13:44
Minimum*	-0.02
	11/26/2024 13:13

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 11/26/2024 14:37

Company: SB County Public Works
Plant: 14470 Calle Real
City/St: Goleta, CA 93101
Source: ADF1

Period Start: 11/26/2024 13:48
Period End: 11/26/2024 14:22
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average A1_NOxHi ppm	Average A1_COLo ppm
11/26/2024 13:48	0.35	0.55
11/26/2024 13:49	0.30	0.50
11/26/2024 13:50	3.73	11.39
11/26/2024 13:51	21.64	39.20
11/26/2024 13:52	23.85	39.92
11/26/2024 13:53	23.91	39.91
11/26/2024 13:54	23.95	39.99
11/26/2024 13:55	25.88	44.20
11/26/2024 13:56	46.90	80.57
11/26/2024 13:57	53.23	82.33
11/26/2024 13:58	53.20	82.39
11/26/2024 13:59	53.21	82.34
11/26/2024 14:00	50.86	77.31
11/26/2024 14:01	26.67	42.19
11/26/2024 14:02	24.09	40.03
11/26/2024 14:03	24.08	40.04
11/26/2024 14:04	24.09	40.06
11/26/2024 14:05	26.46	44.75
11/26/2024 14:06	50.57	79.92
11/26/2024 14:07	53.20	82.32
11/26/2024 14:08	53.22	82.36
11/26/2024 14:09	53.20	82.37
11/26/2024 14:10	51.06	75.57
11/26/2024 14:11	24.49	42.25
11/26/2024 14:12	24.13	40.07
11/26/2024 14:13	24.12	39.93
11/26/2024 14:14	24.07	39.98
11/26/2024 14:15	26.17	47.05
11/26/2024 14:16	52.79	80.13
11/26/2024 14:17	53.25	82.21
11/26/2024 14:18	53.31	82.29
11/26/2024 14:19	53.32	82.40
11/26/2024 14:20	49.13	67.92
11/26/2024 14:21	5.45	3.95
11/26/2024 14:22	0.54	0.43
Final Average*	33.10	52.54
Maximum*	53.32	82.40
	11/26/2024 14:19	11/26/2024 14:19
Minimum*	0.30	0.43
	11/26/2024 13:49	11/26/2024 14:22

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 11/26/2024 14:31

Company: SB County Public Works
Plant: 14470 Calle Real
City/St: Goleta, CA 93101
Source: ADF1

Period Start: 11/26/2024 12:28
Period End: 11/26/2024 13:02
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average A1_COHi ppm	Average A1_O2 %
11/26/2024 12:28	0.6	21.00
11/26/2024 12:29	12.8	20.35
11/26/2024 12:30	52.7	6.53
11/26/2024 12:31	79.0	5.21
11/26/2024 12:32	80.7	5.21
11/26/2024 12:33	80.6	5.20
11/26/2024 12:34	80.7	5.20
11/26/2024 12:35	95.8	6.33
11/26/2024 12:36	167.4	10.03
11/26/2024 12:37	170.9	10.09
11/26/2024 12:38	171.1	10.08
11/26/2024 12:39	171.2	10.10
11/26/2024 12:40	145.6	9.41
11/26/2024 12:41	82.6	5.30
11/26/2024 12:42	80.8	5.19
11/26/2024 12:43	80.8	5.20
11/26/2024 12:44	80.8	5.19
11/26/2024 12:45	100.4	6.83
11/26/2024 12:46	168.8	10.04
11/26/2024 12:47	171.2	10.09
11/26/2024 12:48	114.4	13.43
11/26/2024 12:49	158.0	10.90
11/26/2024 12:50	152.9	10.67
11/26/2024 12:51	55.5	14.55
11/26/2024 12:52	80.3	5.29
11/26/2024 12:53	80.8	5.21
11/26/2024 12:54	80.7	5.20
11/26/2024 12:55	84.0	5.75
11/26/2024 12:56	163.2	9.93
11/26/2024 12:57	171.0	10.09
11/26/2024 12:58	171.0	10.09
11/26/2024 12:59	171.1	10.09
11/26/2024 13:00	104.8	13.25
11/26/2024 13:01	2.7	20.85
11/26/2024 13:02	0.8	20.96
Final Average*	104.7	9.68
Maximum*	171.2	21.00
	11/26/2024	11/26/2024
	12:47	12:28
Minimum*	0.6	5.19
	11/26/2024	11/26/2024
	12:28	12:44

* Does not include Invalid Averaging Periods ("N/A")

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit B
Goleta, CA

Project# SN00170A

Cylinder Gas Audit - NOx Low Range

For quarter ending: **12/31/24**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1302
 Analyzer Range: 30
 Test Date: 11/27/24

	Reference Gas Value (C)	% of Span	Status	Bottle #	Exp. Date	Status
Low	8.04	26.80	OK	SA19336	08/29/25	OK
Mid	17.2	57.33	OK	CC499039	06/23/25	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response	
1	11:33	7.78	11:39	16.53	
2	11:43	7.47	11:48	16.18	
3	11:53	7.33	11:58	16.14	
Average Response (Cm)		7.53		16.28	
Difference (Cm-Ca)		-0.51		-0.92	
Status (for alt. criteria of +/- 3 ppm difference)		PASS		PASS	range >20 but ≤ 50 ppm
Accuracy %, ((Cm-Ca)/Ca) * 100		-6.38		-5.33	
Status (for primary criteria of 15%)		PASS		PASS	

Cylinder Gas Audit - NOx High Range

Analyzer Range: 100
 Test Date: 11/27/24

	Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Status
Low	24.6	24.60	OK	CC748576	05/31/27	OK
Mid	54.5	54.50	OK	CC3035	11/16/29	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response	
1	12:23	26.26	12:29	55.49	
2	12:34	24.90	12:38	55.15	
3	12:43	24.72	12:48	55.16	
Average Response (Cm)		25.29		55.27	
Difference (Cm-Ca)		0.69		0.77	
Status (for alt. criteria of +/- 5 ppm difference)		PASS		PASS	range > than 50 ppm
Accuracy %, ((Cm-Ca)/Ca) * 100		2.82		1.41	
Status (for primary criteria of 15%)		PASS		PASS	

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:

>50 ppm: +/- 5 ppm difference

>20 ppm and ≤ 50 ppm: +/- 3 ppm difference

<= 20 ppm: +/- 2 ppm difference

Tajiguas Landfill
Anaerobic Digesting Facility (ADF), Unit B
Goleta, CA

Project# SN00170A

Cylinder Gas Audit - CO Low Range

For quarter ending: **12/31/24**

Manufacturer: TAPI
 Model: T300M
 Serial Number: 669
 Analyzer Range: 150
 Test Date: 11/27/24

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	40.1	26.73	OK	CC748576	05/31/27 OK
Mid	82.8	55.20	OK	CC3035	11/16/29 OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	12:22	41.32	12:29	83.32
2	12:34	41.15	12:38	83.23
3	12:42	41.21	12:48	83.03
Average Response (Cm)		41.23		83.19
Difference (Cm-Ca)		1.13		0.39
Status (for alt. criteria of +/- 5 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		2.81		0.48
Status (for primary criteria of 15%)		PASS		PASS

range > than 50 ppm

Cylinder Gas Audit - CO High Range

Analyzer Range: 300
 Test Date: 11/27/24

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	79.7	26.57	OK	CC283311	01/13/31 OK
Mid	169.1	56.37	OK	CC73183	03/19/29 OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	10:29	79.7	10:33	170.1
2	10:39	79.6	10:44	170.1
3	10:48	79.6	10:54	170.2
Average Response (Cm)		79.63		170.13
Difference (Cm-Ca)		-0.07		1.03
Status (for alt. criteria of +/- 5 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		-0.08		0.61
Status (for primary criteria of 15%)		PASS		PASS

range > than 50 ppm

Notes:

Pass/Fail Criteria: +/- 15% of reference value

Tiered alternate based on analyzer range:
 >50 ppm: +/- 5 ppm difference
 >20 ppm and ≤ 50 ppm: +/- 3 ppm difference
 <= 20 ppm: +/- 2 ppm difference

**Tajiguas Landfill
 Anaerobic Digesting Facility (ADF), Unit B
 Goleta, CA**

Project# SN00170A

Cylinder Gas Audit - O2

For quarter ending: **12/31/24**

Manufacturer: TAPI
 Model: T200M
 Serial Number: 1302
 Analyzer Range: 25
 Test Date: 11/27/24

Reference Gas Value (Ca)	Status	Bottle #	Exp. Date	Status	
Low	5.10	OK	CC283311	01/13/31	OK
Mid	10.03	OK	CC73183	03/19/29	OK

Cal gas values must be between 4-6% by volume for low and 8-12% by volume for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	10:29	5.16	10:33	10.10
2	10:39	5.16	10:43	10.10
3	10:48	5.17	10:53	10.10
Average Response (Cm)		5.16		10.10
Difference (Cm-Ca)		0.06		0.07
Accuracy %, ((Cm-Ca)/Ca) * 100		1.24		0.70
Status (for primary criteria of 15%)		PASS		PASS

Notes:

Pass/Fail Criteria: +/- 15% of reference value (no alternate)
 (40 CFR 60, Appendix F)

Average Values Report
 Generated: 11/27/2024 12:52

Company: SB County Public Works
 Plant: 14470 Calle Real
 City/St: Goleta, CA 93101
 Source: ADF2

Period Start: 11/27/2024 11:28
 Period End: 11/27/2024 12:02
 Validation Type: 1/1 min
 Averaging Period: 1 min
 Type: Block Avg

Period Start:	Average A2_NOxLo ppm
11/27/2024 11:28	9.00
11/27/2024 11:29	8.48
11/27/2024 11:30	8.28
11/27/2024 11:31	8.08
11/27/2024 11:32	7.88
11/27/2024 11:33	7.78
11/27/2024 11:34	7.71
11/27/2024 11:35	9.76
11/27/2024 11:36	16.31
11/27/2024 11:37	16.50
11/27/2024 11:38	16.56
11/27/2024 11:39	16.53
11/27/2024 11:40	15.69
11/27/2024 11:41	7.61
11/27/2024 11:42	7.49
11/27/2024 11:43	7.47
11/27/2024 11:44	7.42
11/27/2024 11:45	9.42
11/27/2024 11:46	16.08
11/27/2024 11:47	16.18
11/27/2024 11:48	16.18
11/27/2024 11:49	16.20
11/27/2024 11:50	16.22
11/27/2024 11:51	8.87
11/27/2024 11:52	7.34
11/27/2024 11:53	7.33
11/27/2024 11:54	7.29
11/27/2024 11:55	7.99
11/27/2024 11:56	16.04
11/27/2024 11:57	16.11
11/27/2024 11:58	16.14
11/27/2024 11:59	16.15
11/27/2024 12:00	16.17
11/27/2024 12:01	N/A
11/27/2024 12:02	N/A
Final Average*	11.77
Maximum*	16.56
	11/27/2024
	11:38
Minimum*	7.29
	11/27/2024
	11:54

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 11/27/2024 12:54

Company: SB County Public Works
Plant: 14470 Calle Real
City/St: Goleta, CA 93101
Source: ADF2

Period Start: 11/27/2024 12:18
Period End: 11/27/2024 12:52
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average A2_NOxHi ppm	Average A2_COLo ppm
11/27/2024 12:18	36.41	65.65
11/27/2024 12:19	30.24	41.73
11/27/2024 12:20	29.02	41.44
11/27/2024 12:21	27.76	41.33
11/27/2024 12:22	26.94	41.32
11/27/2024 12:23	26.26	41.38
11/27/2024 12:24	25.97	41.29
11/27/2024 12:25	25.81	48.74
11/27/2024 12:26	45.61	80.88
11/27/2024 12:27	55.46	83.46
11/27/2024 12:28	55.51	83.19
11/27/2024 12:29	55.49	83.32
11/27/2024 12:30	55.54	74.20
11/27/2024 12:31	27.76	42.92
11/27/2024 12:32	25.03	41.22
11/27/2024 12:33	24.96	41.02
11/27/2024 12:34	24.90	41.15
11/27/2024 12:35	29.27	49.32
11/27/2024 12:36	54.90	81.27
11/27/2024 12:37	55.14	83.25
11/27/2024 12:38	55.15	83.23
11/27/2024 12:39	55.20	83.22
11/27/2024 12:40	47.91	74.37
11/27/2024 12:41	25.04	42.96
11/27/2024 12:42	24.70	41.21
11/27/2024 12:43	24.72	41.01
11/27/2024 12:44	24.65	40.95
11/27/2024 12:45	31.44	49.75
11/27/2024 12:46	54.88	80.94
11/27/2024 12:47	55.14	83.21
11/27/2024 12:48	55.16	83.03
11/27/2024 12:49	55.17	83.00
11/27/2024 12:50	55.15	82.99
11/27/2024 12:51	N/A	N/A
11/27/2024 12:52	N/A	N/A
Final Average*	39.46	61.15
Maximum*	55.54	83.46
	11/27/2024	11/27/2024
	12:30	12:27
Minimum*	24.65	40.95
	11/27/2024	11/27/2024
	12:44	12:44

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 11/27/2024 12:50

Company: SB County Public Works
Plant: 14470 Calle Real
City/St: Goleta, CA 93101
Source: ADF2

Period Start: 11/27/2024 10:23
Period End: 11/27/2024 10:57
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average A2_COHi ppm	Average A2_O2 %
11/27/2024 10:23	N/A	7.80
11/27/2024 10:24	N/A	7.79
11/27/2024 10:25	N/A	6.63
11/27/2024 10:26	113.0	5.14
11/27/2024 10:27	80.3	5.15
11/27/2024 10:28	79.6	5.16
11/27/2024 10:29	79.7	5.16
11/27/2024 10:30	132.4	6.37
11/27/2024 10:31	182.8	10.07
11/27/2024 10:32	170.1	10.10
11/27/2024 10:33	170.1	10.10
11/27/2024 10:34	170.1	10.09
11/27/2024 10:35	183.6	10.03
11/27/2024 10:36	172.4	5.55
11/27/2024 10:37	81.0	5.17
11/27/2024 10:38	79.6	5.16
11/27/2024 10:39	79.6	5.16
11/27/2024 10:40	87.8	6.21
11/27/2024 10:41	200.0	10.06
11/27/2024 10:42	170.6	10.10
11/27/2024 10:43	170.0	10.10
11/27/2024 10:44	170.1	10.10
11/27/2024 10:45	190.6	8.79
11/27/2024 10:46	93.7	5.17
11/27/2024 10:47	79.8	5.16
11/27/2024 10:48	79.6	5.17
11/27/2024 10:49	79.4	5.17
11/27/2024 10:50	150.2	6.60
11/27/2024 10:51	178.6	10.07
11/27/2024 10:52	170.2	10.10
11/27/2024 10:53	170.0	10.10
11/27/2024 10:54	170.2	10.09
11/27/2024 10:55	173.2	9.56
11/27/2024 10:56	N/A	7.86
11/27/2024 10:57	N/A	7.87
Final Average*	136.9	7.68
Maximum*	200.0	10.10
	11/27/2024	11/27/2024
	10:41	10:53
Minimum*	79.4	5.14
	11/27/2024	11/27/2024
	10:49	10:26

* Does not include Invalid Averaging Periods ("N/A")



Making our world more productive

DocNumber: 491479



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22022

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

LGPKG BAKERSFIELD CA HP8
3505 BUCK OWENS BLVD
BAKERSFIELD CA 93308-4919

Certificate Issue Date: 08/29/2022

Linde Order Number: 72183095

Part Number: NI N08ME-A3

Customer PO Number: 80187623

Fil Date: 08/12/2022

Lot Number: 70086222405

Cylinder Style & Outlet: A3

CGA 660

Cylinder Pressure and Volume: 2000 psig 140 A3

Certified Concentration

Expiration Date:	08/29/2025	NIST Traceable
Cylinder Number:	SA19336	Expanded Uncertainty
8.04 ppm	Nitric oxide	± 0.04 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only:

NOx 8.00 ppm

Certification Information:

Certification Date: 08/29/2022

Term: 36 Months

Expiration Date: 08/29/2025

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document REP-500R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do not use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Certificate)

1. Component:

Nitric oxide

Requested Concentration: 8 ppm

Certified Concentration: 8.04 ppm

Instrument Used: Thermo Electron 42-LS S/N 1030645077

Analytical Method: Chemiluminescence

Last Multi-point Calibration: 08/11/2022

Reference Standard: Type / Cylinder #: GMS / DT0038022

Concentration / Uncertainty: 9.42 ppm ± 0.05 ppm

Expiration Date: 04/08/2025

Traceable to: SRM # / Sample # / Cylinder #: PRM / C1837210.02 / APEX1324301

SRM Concentration / Uncertainty: 10.00 ppm / ± 0.05 ppm

SRM Expiration Date: 04/17/2022

First Analysis Data:				Date					
Z:	0	R:	9.42	C:	8.03	Conc:	8.03	Date	08/21/2022
R:	9.42	Z:	0	C:	8.05	Conc:	8.05		
Z:	0	C:	8.04	R:	8.41	Conc:	8.04		
UOM:	ppm	Mean Test Assay:	8.04	ppm					

Second Analysis Data:				Date					
Z:	0	R:	9.42	C:	8.05	Conc:	8.04	Date	08/29/2022
R:	9.44	Z:	0	C:	8.06	Conc:	8.05		
Z:	0	C:	8.04	R:	9.43	Conc:	8.03		
UOM:	ppm	Mean Test Assay:	8.04	ppm					

Analyzed By: Lisette Morales

Certified By: Henry Koung

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

IN CASE OF EMERGENCY: CALL 1-800-645-4633

SDS ID: P-18-1884-NI

DO NOT REMOVE THIS LABEL

Lot No. 70086216106
Cylinder No. CC499039
Part No. NI NO17ME-AS
Volume: 142 lbs
Fill Date: 06/10/2022
Expiration Date: 06/23/2025
Cust. Ref. # MUSTANG



ProSpec
By Linde



Linde Gas & Equipment Inc.
5700 Alameda Street
Los Angeles, CA USA 90058

UN1956

Compressed gas, n.o.s. (Nitrogen, Nitric oxide)



EPA Protocol		CAS
Water Concentration	Component	10102-43-9
17.2 ppm	- Nitric oxide	7727-37-9
Balance	Nitrogen	

Warning



CONTAINS GAS UNDER PRESSURE; MAY EXPLODE IF HEATED. MAY DISPLACE OXYGEN AND CAUSE RAPID SUFFOCATION.

TLV: Nitric oxide 25 ppm

Use and store only outdoors or in a well-ventilated place; Use a back flow preventive device in the piping; Use only with equipment rated for cylinder pressure; Close valve after each use and when empty; Protect from sunlight when ambient temperature exceeds 52°C (125°F); Do not handle until all safety precautions have been read and understood; If inhaled, remove person to fresh air and have them rest in a position comfortable for breathing. Get medical advice/attention; Do not vomit while connected to equipment.

FIRST AID

If not breathing, give artificial respiration. If breathing is difficult, oxygen should be given. Call a physician. If inhaled, flush the eyes and nose thoroughly with water for at least 15 minutes. Hold the eyelids open and allow flow to be flushed thoroughly. Contact an ophthalmologist immediately.



Making our world
more productive

DocNumber: 573298



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22024

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

LGEPKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA 93455-1123

Certificate Issuance Date: 05/31/2024
Linde Order Number: 72814852
Part Number: NI CO4GM120E-AS
Customer PO Number: 80828173

Fill Date: 05/15/2024
Lot Number: 70095413603
Cylinder Style & Outlet: AS CGA 660
Cylinder Pressure and Volume: 2000 psig 140 R3

Certified Concentration

Expiration Date:	05/31/2027	NIST Traceable
Cylinder Number:	CC748576	Expanded Uncertainty
40.1 ppm	Carbon monoxide	± 0.2 ppm
24.6 ppm	Nitric oxide	± 0.1 ppm
Balance	Nitrogen	

ProSpec EZ Cert



For Reference Only:

NOx 24.7 ppm

Certification Information:

Certification Date: 05/31/2024

Term: 36 Months

Expiration Date: 05/31/2027

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component:

Carbon monoxide

Requested Concentration: 40 ppm
Certified Concentration: 40.1 ppm
Instrument Used: Horiba VIA-510 S/N 578878015
Analytical Method: NDIR
Last Multipoint Calibration: 04/30/2024

Reference Standard:

Type / Cylinder #: GMIS / DT0013574

Concentration / Uncertainty: 50.4 ppm ± 0.2 ppm

Expiration Date: 09/19/2031

Traceable to: SRM # / Sample # / Cylinder #: SRM 1678c / 4-L-1 / FF18402

SRM Concentration / Uncertainty: 49.136 PPM / ± 0.065 PPM

SRM Expiration Date: 04/22/2029

First Analysis Data:				Date			
Z:	0	R:	50.4	C:	40.1	Conc:	40.1
R:	50.5	Z:	0	C:	40.2	Conc:	40.2
Z:	0	C:	40.2	R:	50.4	Conc:	40.2
UOM: ppm				Mean Test Assay: 40.1 ppm			

Second Analysis Data:				Date			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM: ppm				Mean Test Assay: ppm			

2. Component:

Nitric oxide

Requested Concentration: 25 ppm
Certified Concentration: 24.6 ppm
Instrument Used: Thermo Electron 42i-LS S/N 1030645077
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 05/09/2024

Reference Standard:

Type / Cylinder #: GMIS / ND67519

Concentration / Uncertainty: 49.6 ppm ± 0.2 ppm

Expiration Date: 02/09/2032

Traceable to: SRM # / Sample # / Cylinder #: PRM / C2305301.04 / APE1516620

SRM Concentration / Uncertainty: 50.20 ppm / ± 0.20 ppm

SRM Expiration Date: 02/22/2026

First Analysis Data:				Date			
Z:	0	R:	49.6	C:	24.5	Conc:	24.5
R:	49.6	Z:	0	C:	24.6	Conc:	24.6
Z:	0	C:	24.6	R:	49.5	Conc:	24.6
UOM: ppm				Mean Test Assay: 24.6 ppm			

Second Analysis Data:				Date			
Z:	0	R:	49.6	C:	24.5	Conc:	24.5
R:	49.7	Z:	0	C:	24.6	Conc:	24.6
Z:	0	C:	24.6	R:	49.7	Conc:	24.6
UOM: ppm				Mean Test Assay: 24.5 ppm			

Analyzed By

Henry Koung

Certified By

Lissette Morales

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.



CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

LGEPKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA 93455-1123

Certificate Issuance Date: 11/16/2021

Linde Order Number: 71855448

Part Number: 18 CO80MITE-AS

Customer PG Number: 79855521

Fill Date: 10/22/2021

Lot Number: 70096129501

Cylinder Style & Outlet: AS

Cylinder Pressure and Volume: 2000 psi / 140 ft³

CGA 600
140 ft³

Certified Concentration

Expiration Date:	11/16/2029	NIST Traceable	
Cylinder Number:	CC3035	Expanded Uncertainty	
82.8 ppm	Carbon monoxide	± 0.4 ppm	
54.5 ppm	Nitric oxide	± 0.3 ppm	
Balance	Nitrogen		

ProSpec EZ Cert



For Reference Only:

NOx 54.7 ppm

Certification Information:

Certification Date: 11/16/2021

Term: 96 Months

Expiration Date: 11/16/2029

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon monoxide

Requested Concentration: 80 ppm
 Certified Concentration: 82.8 ppm
 Instrument Used: Horiba VIA-510 S/N 43627090042
 Analytical Method: NDIR
 Last Multipoint Calibration: 10/18/2021

First Analysis Data:		Date: 11/09/2021	
Z: 0	R: 98.1	C: 82.7	Conc: 82.7
R: 98.2	Z: 0	C: 82.9	Conc: 82.9
Z: 0	C: 82.8	R: 98.1	Conc: 82.8
UOM: ppm		Mean Test Assay: 82.8 ppm	

Reference Standard: Type / Cylinder #: GMIS / DT0019705

Concentration / Uncertainty: 98.1 ppm ± 0.4 ppm
 Expiration Date: 01/23/2028

Traceable to: SRM # / Sample # / Cylinder #: SRM 1679c / 3-1-15 / FF28593

SRM Concentration / Uncertainty: 98.40 ppm / ± 0.40 ppm
 SRM Expiration Date: 01/28/2020

Second Analysis Data:		Date: 11/09/2021	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: ppm		Mean Test Assay: ppm	

2. Component: Nitric oxide

Requested Concentration: 55 ppm
 Certified Concentration: 54.5 ppm
 Instrument Used: Thermo Electron 42i-LS S/N 1030645077
 Analytical Method: Chemiluminescence
 Last Multipoint Calibration: 10/25/2021

First Analysis Data:		Date: 11/09/2021	
Z: 0	R: 48.8	C: 54.3	Conc: 54.4
R: 48.8	Z: 0	C: 54.4	Conc: 54.5
Z: 0	C: 54.4	R: 48.7	Conc: 54.5
UOM: ppm		Mean Test Assay: 54.4 ppm	

Reference Standard: Type / Cylinder #: GMIS / DT0037980

Concentration / Uncertainty: 48.83 ppm ± 0.22 ppm
 Expiration Date: 09/22/2024

Traceable to: SRM # / Sample # / Cylinder #: PRM / C1765710.01 / APEX1324323

SRM Concentration / Uncertainty: 50.04 ppm / ± 0.20 ppm
 SRM Expiration Date: 12/09/2022

Second Analysis Data:		Date: 11/16/2021	
Z: 0	R: 48.8	C: 54.5	Conc: 54.6
R: 48.7	Z: 0	C: 54.4	Conc: 54.5
Z: 0	C: 54.4	R: 48.7	Conc: 54.5
UOM: ppm		Mean Test Assay: 54.5 ppm	

Analyzed By

Henry Koung

Certified By

Lissette Morales

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.



Making our world more productive

DocNumber: 531956



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22023

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

LGEPKG SANTA MARIA CA HPS
916 W BETTERAVIA RD
SANTA MARIA CA 93455-1123

Certificate Issuance Date: 01/17/2023
Linde Order Number: 72203369
Part Number: NI CO80MO14E-AS
Customer PO Number: 80309977

Fill Date: 12/27/2022
Lot Number: 70086236102
Cylinder Style and Outlet: AS CGA 350
Cylinder Pressure and Volume: 2000 psig 140 ltr

Certified Concentration

Expiration Date:	01/13/2031	NIST Traceable
Cylinder Number:	CC283311	Expanded Uncertainty
79.7 ppm	Carbon monoxide	± 0.7 ppm
5.10 %	Oxygen	± 0.04 %
Balance	Nitrogen	

ProSpec EZ Cert



Certification Information:

Certification Date: 01/13/2023

Term: 96 Months

Expiration Date: 01/13/2031

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon monoxide

Requested Concentration: 80 ppm
Certified Concentration: 79.7 ppm
Instrument Used: Horiba VIA-510 S/N 576876015
Analytical Method: NDIR
Last Multipoint Calibration: 12/15/2022

First Analysis Data:				Date
Z:	R:	C:	Conc:	01/13/2023
0	100.1	79.7	79.7	
0	0	79.7	79.8	
0	0	100.4	79.7	
Mean Test Assay: 79.7 ppm				

Reference Standard: Type / Cylinder #: NTRM / CC1050
Concentration / Uncertainty: 100.1 ppm ± 0.7 ppm
Expiration Date: 07/09/2027

Traceable to: SRM # / Sample # / Cylinder #: NTRM / 190703 / CC872
SRM Concentration / Uncertainty: 100.1 ppm ± 0.8 ppm
SRM Expiration Date: 07/09/2027

Second Analysis Data:				Date
Z:	R:	C:	Conc:	0
0	0	0	0	
0	0	0	0	
0	0	0	0	
Mean Test Assay: ppm				

2. Component: Oxygen

Requested Concentration: 5 %
Certified Concentration: 5.10 %
Instrument Used: Siemens Oxymat 8E S/N 7MS20211AA000CA1
Analytical Method: Paramagnetic
Last Multipoint Calibration: 12/15/2022

First Analysis Data:				Date
Z:	R:	C:	Conc:	01/13/2023
0	9.978	5.098	5.09	
0	9.988	5.102	5.1	
0	5.105	9.988	5.1	
Mean Test Assay: 5.1 %				

Reference Standard: Type / Cylinder #: GMS / DT0018893
Concentration / Uncertainty: 9.978 % ± 0.024 %
Expiration Date: 12/20/2030

Traceable to: SRM # / Sample # / Cylinder #: SRM 2658a / 72-D-28 / CAL016862
SRM Concentration / Uncertainty: 9.918 % ± 0.022 %
SRM Expiration Date: 02/03/2024

Second Analysis Data:				Date
Z:	R:	C:	Conc:	0
0	0	0	0	
0	0	0	0	
0	0	0	0	
Mean Test Assay: %				

Analyzed By

Courtney Ziehl

Certified By

Amalia Rest

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc. arising out of the use of the information contained herein exceed the fee established for providing such information.

IN CASE OF EMERGENCY: CA CL 1-800-645-4633 SDS ID: P-18-0267 DO NOT REMOVE THIS LABEL

Lot No. 70086107102
Cylinder No. CC73183
Part No. NI CO170D10E-AS
Volume: 140 ft³
Fill Date: 03/12/2021
Expiration Date: 03/19/2029



ProSpec
by Praxair

Praxair Distribution, Inc.
5700 S. Alameda Street
Los Angeles, CA USA 90058



UN1956 Compressed gas, n.o.s. (Nitrogen, Oxygen)



EPA Protocol		Component
Molar Concentration	169.1 ppm	Carbon monoxide
	10.03 %	Oxygen
	Balance	Nitrogen

Warning



CONTAINS GAS UNDER PRESSURE; MAY EXPLODE IF HEATED. MAY DISPLACE OXYGEN AND CAUSE RAPID SUFFOCATION.

TLV:

Carbon monoxide 25 ppm

Protect from sunlight when ambient temperature exceeds 52°C (125°F); Use and store only outdoors or in a well-ventilated area.
FIRST AID
If inhaled: Remove to fresh air and keep at rest in a position comfortable for breathing. If not breathing, give artificial respiration. If breathing is difficult, trained personnel should give oxygen. Call a physician.
If in eyes: Immediately flush eyes thoroughly with water for at least 15 minutes. Hold the eyes open. Contact an ophthalmologist.
If on skin or clothes: Wash thoroughly. Contact an ophthalmologist.
If on hands: Wash thoroughly. Contact an ophthalmologist.

January 9, 2024

Kevin Brown
County of Santa Barbara - Public Works Dpt
130 E. Victoria Street, Suite 100
Santa Barbara, CA 93101

FID: 11480
Permit: P 14500
SSID: 03707

Re: Incomplete Permit to Operate Application 14500

Dear Kevin Brown:

On June 30, 2023, the Santa Barbara County Air Pollution Control District (District) received your application for Permit to Operate (PTO) No. 14500 for the Tajiguas ReSource Center project at Tajiguas Landfill. Additional information and/or clarification of information already submitted is required. In order to complete the application, please respond to each of the items listed in the attachment. After we receive the requested information, we will inform you within 30 days if the application is complete.

According to Rule 208.D.4, the application will be denied 120 days after the date of filing if sufficient information needed to deem the application complete has not been submitted, unless the District has, in writing, extended the time.

Please include the Facility Identification (FID) and Permit numbers shown above on all correspondence regarding this permit application. If you have any questions, please contact me at (805) 979-8314 or MountainC@sbcapcd.org. Thank you for your cooperation.

Sincerely,



Charlotte Mountain, Air Quality Engineer III
Engineering Division

Attachment: Incompleteness Items

cc: County of Santa Barbara - Tajiguas Anaerobic Digestion 11480 Project File
Engr Chron File
Noah Dooley
William Sarraf

\\sbcapcd.org\shares\Groups\ENGR\WP\Landfills & WWT\03707 Tajiguas\FID 11480 Tajiguas Anaerobic Digestion\PTOs\PTO 14500\PTO 14500 - PTO Incompleteness - 1-9-2024.docx

ATTACHMENT

PTO NO. 14500 INCOMPLETENESS ITEM LIST

1. ATC Mod 14500-05 Condition C.21.b.

This permit condition requires submission of data for CEMS downtime and CEMS detected excess emissions on a quarterly basis. The District has not received this data since issuance of the ATC. Please submit a downtime report and an excess emissions report.

2. ADF Ammonia CEMS Report

On 9/12/2023, an Ammonia CEMS report was submitted by John Dewey in response to an incompleteness letter issued on 7/26/2023. This report shows exceedances in Ammonia (ppmv) per Table 4.5 of ATC Mod 14500-05. Please submit an ATC to increase the Ammonia limit or to install Ammonia controls.

In addition, this report only includes data for the ADF facility. Please include the Ammonia CEMS report for the MRF facility.

3. CEMS Plan

3.a – Section 4.7.1 Calibration Procedures

Calibration of the analyzer is required on a monthly basis. Please provide calibration records.

3.b – Section 6.2.3 Cylinder Gas Audit

Cylinder Gas Audit (CGA) Reports are required to be conducted on concentration analyzers for three out of four quarters. The following reports have been received by the District:

Q2 2022 CEMS CGA Report
Q3 2022 CEMS CGA Report
Q4 2022 CEMS CGA Report
Q1 2023 CEMS CGA Report

However, each of these reports are missing measurements for Ammonia in [lb/hr] and [ppmv]. Please provide the Ammonia measurements for each of these reports, and also the CGA Reports for Q2 – Q4 of 2023.

In addition, these reports only include data for the ADF Engines. Please include the CGA Reports for concentration analyzers on the MRF Engines.

3.c – Section 7 Data Acquisition and Reporting

Please submit all required reports per Section 7 of the CEMS Plan, including a quarterly written summary report, quarterly emission totals, data recovery efficiency, and audit reports.

Kevin Brown
County of Santa Barbara - Public Works Dpt
130 E. Victoria Street, Suite 100
Santa Barbara, CA 93101

FID: 11480
Permit: P 14500
SSID: 03707

Re: Incomplete Permit to Operate Application 14500

Dear Kevin Brown:

On June 30, 2023, the Santa Barbara County Air Pollution Control District (District) received your application for Permit to Operate (PTO) No. 14500 for the Tajiguas ReSource Center project at Tajiguas Landfill. Additional information and/or clarification of information already submitted is required. In order to complete the application, please respond to each of the items listed in the attachment. After we receive the requested information, we will inform you within 30 days if the application is complete.

According to Rule 208.D.4, the application will be denied 120 days after the date of filing if sufficient information needed to deem the application complete has not been submitted, unless the District has, in writing, extended the time.

Please include the Facility Identification (FID) and Permit numbers shown above on all correspondence regarding this permit application. If you have any questions, please contact me at (805) 979-8314 or MountainC@sbcapcd.org. Thank you for your cooperation.

Sincerely,



Charlotte Mountain, Air Quality Engineer III
Engineering Division

Attachment: Incompleteness Items

cc: County of Santa Barbara - Tajiguas Anaerobic Digestion 11480 Project File
John Dewey
Engr Chron File

\\sbcapcd.org\shares\Groups\ENGR\WP\Landfills & WWT\03707 Tajiguas\FID 11480 Tajiguas Anaerobic Digestion\PTOs\PTO 14500\PTO 14500 - PTO Incompleteness - 7-26-2023.docx

ATTACHMENT

PTO NO. 14500 INCOMPLETENESS ITEM LIST

1. Ammonia CEMS: Table 3-1 of the approved *Continuous Emissions Monitoring System Plan* dated November 2019 indicates that ammonia will be monitored in the exhaust stacks for each CHP engine. As requested by Noah Dooley via email on July 11, 2023, submit the monitored ammonia data.